

**IEC****IECEE**

Ref. Certif. No.

**FR\_716143**

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

**CB TEST CERTIFICATE**

Product

**Luminaire for emergency lighting**  
*Self-contained luminaires for emergency lighting*

Name and address of the applicant

**LEGRAND FRANCE**  
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY  
87045 LIMOGES CEDEX  
FRANCE

Name and address of the manufacturer

**LEGRAND FRANCE**  
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY  
87045 LIMOGES CEDEX  
FRANCE

Name and address of the factory

**LEGRAND FRANCE.**  
1 RUE HENRI FREYSSINET  
17140 LAGORD  
FRANCE

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)

legrand

Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

Range U33  
6 621 20, 6 621 22

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR\_701861 dated 01/12/2017. Update the list of product references, update further to the evolution of the standard(s)

 Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60598-1:2014+A1:2017  
IEC 60598-2-22:2014+A1:2017


As shown in the Test Report Ref. No. which forms part of this Certificate

173002-766669-A Version : 01

This CB Test Certificate is issued by the National Certification Body

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
33 avenue du Général Leclerc  
92260 Fontenay-aux-Roses, FRANCE  
[www.lcie.fr](http://www.lcie.fr)

Date: 12/01/2023

Signature: **Jérôme REYSSON**  
Certification Officer

## ANNEX


Caractéristiques / Characteristics :

Caractéristiques / Characteristics	Valeur / Value
Type / Type	6 621 20 : NM 6 621 22 : C
Tension assignée / Rated voltage	230V
Nature du courant / Nature of supply	~
Fréquence assignée / Rated frequency	50/60 Hz
Puissance assignée / Rated power	/
Classe de protection contre les chocs électriques / Class of protection from electric shock	II
Degré IP / IP degree	42
Degré IK / IK degree	07
Flux assigné / Rated lumen output	6 621 20 : 250 lm à 1h 6 621 22 : 250/120 lm à 1h
Nature accumulateur (Type, Nombre, Tension, Capacité) / Battery type	6 621 20, 6 621 22 : Ni-Cd [(4 x 1,2 / 1,5 Ah) + (2 x 1,2 / 1,5 Ah)] BYD SC1500mAh Ni-Cd [(4 x 1,2 / 1,6 Ah) + (2 x 1,2 / 1,6 Ah)] ARTS ENERGY VNT Cs U
Lampe de secours (nature, nombre) / Emergency lamp (type, number)	6 621 20 : 1 tube x 8 W 6 621 22 : 2 tubes x 8 W



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
33 avenue du Général Leclerc  
92260 Fontenay-aux-Roses, FRANCE  
[www.lcie.fr](http://www.lcie.fr)

Date: 12/01/2023


 Signature: Jérôme REYSSON  
Certification Officer