

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Surge protective device

Name and address of the applicant

Legrand France
128 Avenue du Maréchal de Lattre de Tassigny,
87045 Limoges Cedex, France

Name and address of the manufacturer

Legrand France
128 Avenue du Maréchal de Lattre de Tassigny,
87045 Limoges Cedex, France

Name and address of the factory

Legrand Polska Sp.z.o.o.
ul. Warynskiego 20,
57-200 Zabkowice Slaskie, Poland

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

L-N: Uc= AC 320V; In= 5 or 20kA; Imax= 20 or 40kA;
N-PE: Uc= AC 255V; In= 20kA; Imax= 20 or 40kA;
see also test reports

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

--

Model / Type Ref.

4 122 ...
see type spectrum on page 10 of test report CTI-CB 1015-1

Additional information (if necessary may also be reported on page 2)

--

 Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61643-11:2011

As shown in the Test Report Ref. No. which forms part of this Certificate

CTI-CB 1015-1 to 1015-3

This CB Test Certificate is issued by the National Certification Body