



Ref. Certif. No.

FR_716150

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Luminaire for emergency lighting
Self-contained luminaire for emergency lighting

Name and address of the applicant

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX
FRANCE

Name and address of the manufacturer

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX
FRANCE

Name and address of the factory

LEGRAND FRANCE.
1 RUE HENRI FREYSSINET
17140 LAGORD
FRANCE

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)

legrand

Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

Range U34 LED
6 621 62, 6 621 82

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR_701988 dated 15/12/2017. Update further to the evolution of the standard(s)

☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60598-1:2014+A1:2017
IEC 60598-2-22:2014+A1:2017

As shown in the Test Report Ref. No. which forms part of this Certificate

173002-766673-A Version : 01


This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 12/01/2023

Signature: Jérôme REYSSON
Certification Officer



ANNEX

Caractéristiques / Characteristics :

Caractéristiques / Characteristics	Valeur / Value
Type / Type	LED M / NM
Tension assignée / Rated voltage	230V
Nature du courant / Nature of supply	~
Fréquence assignée / Rated frequency	50/60 Hz
Puissance assignée / Rated power	6 621 62 : M:2,3W – NM:0,5W 6 621 82 : M:3W – NM:1W
Classe de protection contre les chocs électriques / Class of protection from electric shock	II
Degré IP / IP degree	42
Degré IK / IK degree	07
Flux assigné / Rated lumen output	6 621 62 : 250 lm à 1h 6 621 82 : 450 lm à 1h
Nature accumulateur (Type, Nombre, Tension, Capacité) / Battery type	6 621 62 : Ni-MH (3 x 1,2 V / 2,2 Ah) GP GP220SCHT 6 621 82 : Ni-MH 2 x (3 x 1,2 V / 2,2 Ah) GP GP220SCHT
Lampe de secours (nature, nombre) / Emergency lamp (type, number)	6 Leds



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 12/01/2023



Signature: Jérôme REYSSON
Certification Officer