



Ref. Certif. No.

SE-106714

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Three and Four poles Switch Disconnecter

Name and address of the applicant

LEGRAND FRANCE
128 avenue du Maréchal de Lattre de Tassigny 87045 Limoges
Cedex (France)

Name and address of the manufacturer

BTICINO SpA - Legrand Group
Viale Borri 231, Varese 21100
Italy

Name and address of the factory

See page 2

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

U_e=220-690V (50.0-60.0Hz) – I_e=250A
I_{cw}=3.00kA (1.00s) – I_{cm}=4.30kA, Pattern No. 3 and 4

Trademark (if any)

Legrand

Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

DPX³-I 250 HP

Additional information (if necessary may also be reported on page 2)

See page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-3:2020

As shown in the Test Report Ref. No. which forms part of this Certificate

2026746STO-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

intertek

Signature:

Date: 22 December, 2021

Quan Li

Factories

Bticino S.p.a. – Via dei Folzoni, 5 – 24052, Azzano, San Paolo, Bergamo (Italy)

Legrand Low Voltage Electrical (Wuxi) CO., LTD, No.88, Ximei Road, New Zone, Wuxi, Jiangsu Province (P.R. China)

Novateur Electrical & Digital Systems Private Limited, D-4, MIDC Area, Jalgaon-425003 Maharashtra, INDIA

OA0 KOHTAKTOP 12 Karl Marx str., Ulyanovsk 432001, Russian Federation

Additional information

Characteristics:

Voltage ratings $U_e=220-690V$ (50-60Hz)

Rated current $I_e=250A$

$U_{imp} = 8kV$ $U_i = 800V$

Utilization Category: AC23A

U_e (V)	I_e (A)	I_{cm} (kA)	I_{cw} (1s) (kA)
415	250	4,3	3,0
690	200	4,3	3,0

Utilization Category: AC22A

U_e (V)	I_e (A)	I_{cm} (kA)	I_{cw} (1s) (kA)
690	250	4,3	3,0

Date: 22 December, 2021

Signature: 