



Ref. Certif. No.
SE-105578

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Fixed socket-outlet, flush-type
Name and address of the applicant	Legrand Intelligent Electrical (Huizhou) Co., Ltd. Bldg. B1-B3, East No.39 Hechang 6th Rd.,HZZK Hi-tech Industrial Development Zone, Huizhou, Guangdong CHINA
Name and address of the manufacturer	LEGRAND FRANCE 128, Avenue du Maréchal de Lattre de Tassigny 87045 LIMOGES Cedex-FRANCE
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	Same as applicant
Ratings and principal characteristics	13A 250V~, IP20
Trademark (if any)	legrand
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	281112, 283112, 283312, 283512, 283912, 282112
Additional information (if necessary may also be reported on page 2)	See page 2
A sample of the product was tested and found to be in conformity with	IEC 60884-1:2002+A1+A2
As shown in the Test Report Ref. No. which forms part of this Certificate	210402079SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

intertek
Signature:

Date: 02 August, 2021

Hyden Li

Additional information

Class I, rewirable, with two-way Type G outlets (configuration of BS 1363-2), with shutters, with screw-type terminals, with plastic front cover, see below for details:

Model lists:

281112: with white front cover.
283112: with silver front cover.
283312: with pearl cream front cover.
283512: with dark grey front cover.
283912: with champ front cover.
282112: with matt black front cover.
Total 6 models.

Note: All tests are evaluated when mated with plastic cover which provided by the manufacturer as far as possible.

Date: 02 August, 2021

Signature: 