



Ref. Certif. No.

SE-85308

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Key card switch
Name and address of the applicant	Legrand (Beijing) Electrical Co. Ltd No. 4 Chaoqian Road, Changping Kejiyuanqu, Beijing, China
Name and address of the manufacturer	Same as applicant
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	Same as applicant
Ratings and principal characteristics	See page 2
Trademark (if any)	legrand
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	281048, 282048, 283848
Additional information (if necessary may also be reported on page 2)	Pattern No.1, Micro-gap, IP20, Actuated by key card, Flush-type, Design A, With screw terminals
A sample of the product was tested and found to be in conformity with	IEC 60669-1:1998+A1+A2 IEC 60669-2-1:2002+A1+A2
As shown in the Test Report Ref. No. which forms part of this Certificate	160702529SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00

Date: 13 December 2016



Signature:

Gary Hu



Ref. Certif. No.

SE-85308

Ratings and principal characteristics

220-240V~, 50/60Hz, 15A resistive,
Max.1800W incandescent lamps,
Max.1800W iron core transformer for extra low-voltage incandescent lamps,
Max.800W motors,
Max.400VA compensated fluorescent lamps,
Max.800VA fluorescent lamps

Date: 13 December 2016

Signature: