



Ref. Certif. No.

FR_719973

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Socket-outlet for fixed-electrical installations

Name and address of the applicant

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX - FRANCE

Name and address of the manufacturer

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX - FRANCE

Name and address of the factory

Note: When more than one factory, please report on page 2

☒ Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

Series : MOSAIC
References : See Annex

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC 593474B dated 15/03/2010. Update further to the evolution of the standard(s)

☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60884-1:2022

As shown in the Test Report Ref. No. which forms part of this Certificate

20693577-795633

This CB Test Certificate is issued by the National Certification Body




LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 09/09/2024



LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Signature: 
Julien GAUTHIER
Certification Officer

ANNEX

Name and address of the factories:**LEGRAND FRANCE**

128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX – FRANCE


LEGRAND FRANCE SILLE LE GUILLAUME

80 ROUTE D'EVRON
72140 SILLE LE GUILLAUME - FRANCE



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 09/09/2024



Signature: **Julien GAUTHIER**
Certification Officer

ANNEX

References, ratings and main characteristics:

Mechanisms

Trademark	References White Antimicrobien	Function	Specificities
LEGRAND	0 771 31	2P+E	Easy to handle socket-outlets

Characteristics of appliances

Standard sheet	V (CEE7)
Rated current (A)	16A
Rated voltage (V)	250V~
Degree of protection	IP20
Provision for earthing	With earthing contact
Method of connecting the cable	Rewirable
Type of terminals	Screwless type (rigid and flexible)
Number of socket-outlets	/
Degree of protection against electric shock	Normal protection
Existence of shutters	With shutters
Method of mounting	Flush type
Method of installation	Design A


Accessories

Reference	References White	Designation
0 802 52	-	Frame
-	0 788 25L	Cover plate



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 09/09/2024



Signature: Julien GAUTHIER
Certification Officer