



Ref. Certif. No.

**SE-95911**

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**

**CB TEST CERTIFICATE**

Product	Switched socket-outlet (flush-type)
Name and address of the applicant	TCL-Legrand International Electrical (Huizhou) Co., Ltd. Bldg. B1-B3, East No.39 Hechang 6th Rd. HZZK Hi-tech Industrial Development Zone, Huizhou Guangdong P-R. China
Name and address of the manufacturer	Same as applicant
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	Same as applicant
Ratings and principal characteristics	See page 2
Trademark (if any)	LEGRAND
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	6 176 41, 6 176 42, 6 177 41, 6 177 42, 6 178 41, 6 178 42
Additional information (if necessary may also be reported on page 2)	See page 2
A sample of the product was tested and found to be in conformity with	IEC 60884-1:2002 + A1 + A2 IEC 60884-2-3:2006
As shown in the Test Report Ref. No. which forms part of this Certificate	190300916SHA-001

This CB Test Certificate is issued by the National Certification Body

**Intertek Semko AB**  
Box 1103  
SE-164 22 Kista, Sweden  
Int +46 8 750 00 00

Date: 28 October 2019



Signature:

Hyden Li



**Ratings and principal characteristics**

13A 250V~, flush type, IP20, Class I, rewirable, with 1 gang switched socket outlets comply with type G (configuration of BS 1363-2), with shutters, with single pole switch, with plastic cover plate.

**Additional information**

Model Explanation:

- 6 176 41: with white front cover and white cover plate
- 6 176 42: with white front cover and white cover plate, with indicator lamp
- 6 177 41: with dark front cover and dark cover plate
- 6 177 42: with dark front cover and dark cover plate, with indicator lamp
- 6 178 41: with ivory front cover and ivory cover plate
- 6 178 42: with ivory front cover and ivory cover plate, with indicator lamp

Date: 28 October 2019

Signature:

