

IEC

IECEE

Ref. Certif. No.

FR\_714680

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Socket-outlet for fixed-electrical installations

Name and address of the applicant

Legrand Intelligent Electrical (Huizhou) Co., Ltd.  
Bldg. B1-B3, East No. 39 Hechang 6th Rd., HZZK Hi-tech  
Industrial Development Zone  
516001 Huizhou, Guangdong - CHINA

Name and address of the manufacturer

LEGRAND FRANCE  
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY  
87045 LIMOGES CEDEX - FRANCE

Name and address of the factory

Legrand Intelligent Electrical (Huizhou) Co., Ltd.  
Bldg. B1-B3, East No. 39 Hechang 6th Rd., HZZK Hi-tech  
Industrial Development Zone  
516001 Huizhou, Guangdong - CHINA

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)

 legrand tenby

Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

See Annex

Additional information (if necessary may also be reported on page 2)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60884-1:2002(ed.3) +A1:2006 +A2:2013

As shown in the Test Report Ref. No. which forms part of this Certificate


ARLI-ESH-P22011267


This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
33 avenue du Général Leclerc  
92260 Fontenay-aux-Roses, FRANCE

[www.lcie.fr](http://www.lcie.fr)




Signature:   
Julien GAUTHIER  
Certification Officer

Date: 19/05/2022

## ANNEX

**References, ratings and main characteristics:**

Reference	Trademark	Product description	Color of enclosure
618040		1G BS 13A UNSWITCHED SOCKET	WHITE
838017	tenby	1G BS 13A UNSWITCHED SOCKET	WHITE


**CLASSIFICATION**

standard Sheet:	standard sheet of BS 1363-2
rated current (A)	13A
rated load (W)	-
rated voltage (V)	250V
household voltage (V)	-
degree of protection	IP20
provision for earthing	with earthing contact
method of connecting the cable	rewirable
type of terminals	screw-type
type of connections	-
colour	White
<b>socket-outlets</b>	
multiple socket-outlets	
number of socket-outlets	13A : 1
degree of protection against electric shock	normal protection
existence of shutters	with shutters
method of application - mounting	flush-type
method of installation	design A
<b>plugs:</b>	
class of equipment	-
entry of cable	-



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
33 avenue du Général Leclerc  
92260 Fontenay-aux-Roses, FRANCE

[www.lcie.fr](http://www.lcie.fr)



Signature:  **Julien GAUTHIER**  
Certification Officer

Date: 19/05/2022