



# Certificate of Conformity

LOVAG-Certificate No.: IT 16.039  
Page 1 of 2

**Apparatus: Low-voltage Assembly - Distribution Board**  
230V ( $U_n$ ) - 500V ( $U_i$ ) - 4kV ( $U_{imp}$ ) - 63A ( $I_{nA}$ ) - 50/60 Hz ( $f_n$ ) - IP40 - IK05

**Designation Type: Practibox**

**Manufacturer: Legrand s.n.c.**

Av. Du Marechal de Lattre De Tassigny, 128  
87045 Limoges (France)

**Applicant: Legrand s.n.c.**

Av. Du Marechal de Lattre De Tassigny, 128  
87045 Limoges (France)

**Verified by: ACAE Laboratory IB 01**

This Certificate applies only to the apparatus verified. The responsibility for conformity of any apparatus having the same designation with that verified rests with the manufacturer or responsible vendor.

This certificate has been prepared according to LOVAG (Low Voltage Agreement Group) Objectives and Operating Principles of mutual recognition. The responsible certification body as a member of LOVAG issues a Certificate of Conformity with the above mentioned Standard(s) following the exclusive use of LOVAG Verification instruction wherever applicable.

Only integral reproduction of this Certificate or reproductions of this page accompanied by any page(s) on which are stated the verifications performed and the assigned rated characteristics of the apparatus verified, are permitted without written permission from the LOVAG Signatory responsible for this Certificate

The apparatus, constructed in accordance with the description mentioned in the Report listed in this Certificate has been subjected to the series of proving verifications in accordance with IEC 61439-3 Ed.1.0 (2012-02)

- Information (6.1)
- Properties of insulating materials (10.2.3)
- Mechanical impact (10.2.6)
- Degree of protection (10.3)
- Clearances and creepage distances (10.4)
- Dielectric properties (10.9)
- Verification of temperature-rise (10.10)
- Short-circuit withstand strength (10.11)
- Mechanical operation (10.13)

The results are shown in the Report in accordance to LOVAG. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the characteristics assigned by the manufacturer in page n.2



**Responsible Certification Body: ACAE**  
Via Tito Livio, 5 - 24123 - BERGAMO (Italy)



**PRD N°070B**  
Signatory of EA, IAF and ILAC  
Mutual Recognition Agreements

Authorized Signature: Virginio Scarioni

Date: 2016.07.04



## Certificate of Conformity

LOVAG-Certificate No.: IT 16.039  
Page 2 of 2

Rated operational voltage ( $U_e$ )	230 V
Rated insulation voltage ( $U_i$ )	500 V
Rated impulse voltage ( $U_{imp}$ )	4 kV
Rated current ( $I_{nA}$ )	63 A
Degree of protection	IP40
Mechanical impact	IK05

This document includes: Comparison Report No.: 804  
Issue Date : 2016/06/22  
Test Report No.: 804-1  
Issue Date : 2016/06/22  
Test Report No.: 804-2  
Issue Date : 2016/06/22  
Test Report No.: 804-3  
Issue Date : 2016/06/22  
Test Report No.:127071-654744-Cr2015-04-03  
Issue Date : 2015/04/03



**PRD N°070B**  
Signatory of EA, IAF and ILAC  
Mutual Recognition Agreements

**Responsible Certification Body: ACAE**  
Via Tito Livio, 5 – 24123 – BERGAMO (Italy)

Authorized Signature: Virginio Scarioni  
Date: 2016.07.04