

---

**DECLARATION DES PERFORMANCES**      N° 0333-CPD-075318

---

Nous, **LEGRAND France SNC**  
**128, Avenue de Lattre-de-Tassigny - F 87 045 LIMOGES Cedex – France**

**Déclarons que le produit : DSAF/DSNA 90 dB encastré réf URA 367210**

Satisfait aux dispositions du règlement du Conseil 305/2011/UE du 9 mars 2011 "Règlement Produits Construction - RPC" - Le système d'évaluation et de vérification de la constance des performances du produit de construction, conformément à l'annexe V est : système 1.

Ces dispositions sont assurées pour le règlement 305/2011/UE par la conformité à la (aux) norme(s) suivante(s) :

- EN 54-3 : 2002,

AFNOR Certification, notifié n°0333, a réalisé la détermination du produit type. La conformité est attestée par le certificat de constance des performances n° **0333-CPR-075318-1**.

**Produit : Système de détection et d'alarme incendie – Dispositifs sonores d'alarme feu.**

**Usage prévu : Dispositifs d'alarme feu utilisés dans les systèmes de détection d'incendie pour émettre un signal d'alarme incendie vers les occupants d'un bâtiment.**

---

**PERFORMANCES DECLAREES**

Caractéristiques essentielles	Performances	Spécification technique harmonisée
<b>Fiabilité de fonctionnement</b>	<b>Conforme</b>	EN 54-3: 2002 art: 4.4, 4.5, 4.6, 5.4, 5.17
<b>Performances dans des conditions d'incendie</b>	<b>Conforme</b>	EN 54-3: 2002 art: 4.2, 4.3, 5.2, 5.3
<b>Durabilité de la fiabilité de fonctionnement, résistance à la température</b>	<b>Conforme</b>	EN 54-3: 2002 art: 5.5, 5.6*, 5.7 *Dispositifs extérieurs uniquement
<b>Durabilité de la fiabilité de fonctionnement, résistance aux vibrations</b>	<b>Conforme</b>	EN 54-3: 2002 art: 5.12, 5.13, 5.14, 5.15
<b>Durabilité de la fiabilité de fonctionnement, résistance à l'humidité</b>	<b>Conforme</b>	EN 54-3: 2002 art: 5.8, 5.9, 5.10*, 5.17 *Dispositifs extérieurs uniquement
<b>Durabilité de la fiabilité de fonctionnement, résistance à la corrosion</b>	<b>Conforme</b>	EN 54-3: 2002 art: 5.11
<b>Durabilité de la fiabilité de fonctionnement, stabilité électrique</b>	<b>Conforme</b>	EN 54-3: 2002 art: 5.16* *Dispositifs comportant des composants électroniques actifs uniquement

La présente déclaration est sous la seule responsabilité de LEGRAND France SNC.

A Pau,  
 Le 26 janvier 2017

Danilo BERNASCONI,  
 Directeur R&D Système du bâtiment

Signature



---

**DECLARATION OF PERFORMANCES No. 0333-CPD-075318**

---

**We, LEGRAND France SNC**  
**128, Avenue de Lattre-de-Tassigny - F 87 045 LIMOGES Cedex – France**

**Hereby declare that the following product:** Fire alarm device – Sounder 90 dB  
 ref URA 367210

satisfy the provisions of Council Regulation 305/2011/UE dated March 9, 2011 "Construction Products Regulation (CPR)" - System of assessment and verification of constancy of performance of the construction product as set out in Annex V is : System 1.

These provisions are ensured for Regulation 305/2011/UE by conformity to the following standard(s):

- EN 54-3 : 2002,

AFNOR Certification, notified No.0333, performed the determination of the typical product. The conformity is attested by the certificate of constancy of performances No. **0333-CPR-075318-1**.

**Product :** Fire detection and alarm system – Fire alarm devices – Sounders.

**Planned use :** Warning devices fire used in the systems of detection of fire to emit an alarm sets fire to towards the occupants of a building.

---

**DECLARED PERFORMANCES**

Essential characteristics	Performances	Harmonized technical specification
<b>Operational reliability</b>	<b>Pass</b>	EN 54-3: 2002 art: 4.4, 4.5, 4.6, 5.4, 5.17
<b>Performance under fire condition</b>	<b>Pass</b>	EN 54-3: 2002 art: 4.2, 4.3, 5.2, 5.3
<b>Durability of operational reliability, temperature resistance</b>	<b>Pass</b>	EN 54-3: 2002 art: 5.5, 5.6*, 5.7 *For outdoor devices only
<b>Durability of operational reliability: vibration resistance</b>	<b>Pass</b>	EN 54-3: 2002 art: 5.12, 5.13, 5.14, 5.15
<b>Durability of operational reliability: humidity resistance</b>	<b>Pass</b>	EN 54-3: 2002 art: 5.8, 5.9, 5.10*, 5.17 *For outdoor devices only
<b>Durability of operational reliability: corrosion resistance</b>	<b>Pass</b>	EN 54-3: 2002 art: 5.11
<b>Durability of operational reliability; electrical stability</b>	<b>Pass</b>	EN 54-3: 2002 art: 5.16* *For devices with active electronic components only

The presente declaration is solo responsibility of LEGRAND France SNC.

Signed at Pau,  
 On January 26<sup>th</sup>, 2017

Danilo BERNASCONI,  
 Building System R&D Manager

Signature

