

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Fixed switched socket-outlet Switched socket-outlets for fixed installations
Name and address of the applicant	LEGRAND MAGYARORSZAG VILLAMOSSAGI RENDSZEREK ZRt IPARTELEPI UT 14 PF 10 6600 SZENTES - HUNGARY
Name and address of the manufacturer	LEGRAND MAGYARORSZAG VILLAMOSSAGI RENDSZEREK ZRt IPARTELEPI UT 14 PF 10 6600 SZENTES - HUNGARY
Name and address of the factory	LEGRAND MAGYARORSZAG VILLAMOSSAGI RENDSZEREK ZRt IPARTELEPI UT 14 PF 10 6600 SZENTES - HUNGARY
Note: When more than one factory, please report on page 2	<input type="checkbox"/> Additional Information on page 2
Ratings and principal characteristics	13A 250V~ See Annex
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	/
Model / Type Ref.	572130, 572630, 570044, 571044
Additional information (if necessary may also be reported on page 2)	/ <input type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60884-1:2002+A1:2006 +A2:2013 IEC 60884-2-3:2006
As shown in the Test Report Ref. No. which forms part of this Certificate	ARFH-19MY0492ACSHP

This CB Test Certificate is issued by the National Certification Body



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 22/07/2019



LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Signature: 
Julien Gauthier
Certification Officer

ANNEX

References, ratings and main characteristics:

Reference	Range*	Description	Color of enclosure	with cover plate	with support frame
572130	ARTEOR	2P+E 13A British Standard Single Pole switched 1 gang	White	575070	576002
572630	ARTEOR	2P+E 13A British Standard Single Pole switched 1 gang	Magnesium cover with black cover plate	575072	576002
570044	ARTEOR	2P+E 13A British Standard Single Pole switched 1 gang	Champagne cover with black cover plate	575072	576002
571044	ARTEOR	2P+E 13A British Standard Single Pole switched 1 gang	Alu cover with black cover plate	575072	576002

* The "range" denotes applicant's categorization.

standard Sheet:	standard sheet of BS 1363-2
rated current (A)	13A
rated voltage (V)	250V
degree of protection	IP20
provision for earthing	with earthing contact
method of connecting the cable	rewirable
type of terminals	screw-type
colour	White, Magnesium, Champagne, Alu, Red, Green, Orange
socket-outlets	
multiple socket-outlets number of socket-outlets	13A : 1
degree of protection against electric shock	normal protection
existence of shutters	with shutters
method of application - mounting	flush-type
method of installation	design A
Intended for circuits where	a single earthing circuit provides protective earthing
Switched socket-outlets without interlock	
According to the method of actuating the switch	rocker
According to the switching of the neutral	unswitched neutral



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Signature: 
Julien Gauthier
Certification Officer

Date: 22/07/2019