

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Three and Four poles Switch Disconnecter

Name and address of the applicant

LEGRAND SNC
128 avenue du Maréchal de Lattre de Tassigny 87045 Limoges
Cedex (France)

Name and address of the manufacturer

Same as applicant

Name and address of the factory

See page 2

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Ue=220-550Vac (50.0-60.0Hz) – Ie=125A
Icw=1,50kA (1.00s) - Icm=2,50kA Pattern No. 3 and 4

Trademark (if any)

Legrand

Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

DRX-I 125^{HP}

Additional information (if necessary may also be reported on page 2)

See page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-3:2020

As shown in the Test Report Ref. No. which forms part of this Certificate

2026729STO-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden**intertek**

Signature:


Henrik Wikström

Date: 12 March, 2021

Factories

Bticino S.p.a. – Via dei Folzoni, 5 – 24052, Azzano, San Paolo, Bergamo (Italy)

Legrand Low Voltage Electrical (Wuxi) CO., LTD, No.88, Ximei Road, New Zone, Wuxi, Jiangsu Province (P.R. China)

Novateur Electrical & Digital Systems Private Limited, D-4, MIDC Area, Jalgaon-425003 Maharashtra

ОАО КОХТАКТОП - 12 Karl Marx str. Ulyanovsk 432001- Russian Federation

Additional information

Characteristics:

Voltage ratings $U_e=220-550V$ (50-60Hz)

Rated current $I_e=125A$

$U_{imp} = 8kV$ $U_i = 800V$

Utilization Category: AC23A

U_e (V)	I_e (A)	I_{cm} (kA)	I_{cw} (1s) (kA)
220 -550	125	2,5	1,5

Date: 12 March, 2021

Signature: 