



Ref. Certif. No.

FR_711903

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Switch for household and similar fixed-electrical installation

Switches for fixed electrical installations

Name and address of the applicant

Legrand Intelligent Electrical (Huizhou) Co., Ltd.
Bldg. B1-B3, East No. 39 Hechang 6th Rd., HZZK Hi-tech Industrial Development Zone, Huizhou, Guangdong - CHINA

Name and address of the manufacturer

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX - FRANCE

Name and address of the factory

Legrand Intelligent Electrical (Huizhou) Co., Ltd.
Bldg. B1-B3, East No. 39 Hechang 6th Rd., HZZK Hi-tech Industrial Development Zone, Huizhou, Guangdong - CHINA

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

See Annex

Additional information (if necessary may also be reported on page 2)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60669-1:2017

As shown in the Test Report Ref. No. which forms part of this Certificate


ARLI-ESH-P21031174

This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE

www.lcie.fr



Signature:
Julien Gauthier
Certification Officer

Date: 09/07/2021

ANNEX

References, ratings and main characteristics:


References	Nominal values	Pattern number	Method of actuating	Characteristics
283066	20AX 250V~	2	Rocker	With cable outlet & indicator, Silver colour
283266	20AX 250V~	2	Rocker	With cable outlet & indicator, Pearl colour
283060	20AX 250V~	2	Rocker	Without cable outlet, without indicator, Silver colour
283466	20AX 250V~	2	Rocker	With cable outlet & indicator, Dark Silver colour

Pattern number	2
Contact opening	normal gap
Protection degree	IP20
Method of actuating	rocker
Method of mounting	flush-type
Method of installation	design A
Type of terminals	screw-type (rigid and flexible)
Flexible cable outlet	see above table
Ratings	20AX 250V~
Colour	Silver, Pearl, Dark Silver



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 09/07/2021



Signature: *Julien Gauthier*
 Certification Officer