



Ref. Certif. No.

SE-106717

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Circuit breakers Thermal-magnetic release

Name and address of the applicant

LEGRAND FRANCE
128 AVENUE DU MARÉCHAL DE LATTRE DE TASSIGNY
FR-87045 LIMOGES CEDEX, FRANCE

Name and address of the manufacturer

BTICINO SpA - Legrand Group
Viale Borri 231, Varese 21100
Italy

Name and address of the factory

See page 2

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

U_e=240-690Vac (50.0-60.0Hz) – I_n=16-250A
U_i=800V, U_{imp}= 8.00kV, Pattern No. 3 and 4

Trademark (if any)

Legrand

Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

DPX³ 250 HP

Additional information (if necessary may also be reported on page 2)

See page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-2:2016+A1

As shown in the Test Report Ref. No. which forms part of this Certificate

2026735STO-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

intertek

Signature:

Date: 22 December, 2021

Quan Li

Factories

Bticino S.P.A Via Folzoni 5, IT-24052 Azzano San Paolo, Bergamo, ITALY.

Novateur Electrical & Digital Systems Private Ltd. MIDC Jalgaon Pin, Jalgaon-425003 Maharashtra, INDIA.

OA0 KOHTAKTOP. 12, Karl Marx str., Ulyanovsk, 432001, RUSSIAN FEDERATION

Legrand Low Voltage Electrical (Wuxi) Co., Ltd. No. 88, Ximei Road, New Zone Wuxi, Jiangsu Province, CHINA.

Additional information

DPX³ 250 HP (Traffic Red label)

U_e (V)	I_{cm} (kA)	I_{cu} (kA)	I_{cs} (kA)	I_{cw} (kA)
240	154	70,0	70,0	N/A
415	75,6	36,0	36,0	N/A
500	32,0	16,0	16,0	N/A
690	11,9	7,00	7,00	N/A

DPX³ 250 HP (Blue Lilac label)

U_e (V)	I_{cm} (kA)	I_{cu} (kA)	I_{cs} (kA)	I_{cw} (kA)
240	198	90,0	90,0	N/A
415	105	50,0	50,0	N/A
500	36,0	18,0	18,0	N/A
690	13,6	8,00	8,00	N/A

Date: 22 December, 2021

Signature: 