

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Plug of connecting device for luminaire

Name and address of the applicant

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX
FRANCE

Name and address of the manufacturer

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX
FRANCE

Name and address of the factory

ILIRIA ELECTRIC SH.P.K.
Autostrada Tirana Durazzo Km 5
TIRANA
ALBANIA

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

0 601 34

Additional information (if necessary may also be reported on page 2)

/

☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61995-1:2005 +A1:2016

As shown in the Test Report Ref. No. which forms part of this Certificate

167159-750766


This CB Test Certificate is issued by the National Certification Body



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 27/08/2020

Signature: **Jerôme REYSSON**
Certification Officer





Ref. Certif. No.

FR_709356

ANNEX

Ratings and main characteristics:

Classification

Standard sheet	NF EN 61995-2 : 1-2
Rated current (A)	6 A
Rated voltage (V)	250 V ~
Connecting the cable	rewirable
Type of terminals	screw-type
Class of luminaire	I
Degree of protection	IP20
Provision of signal contacts	without provision



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 27/08/2020

Signature

