



Ref. Certif. No.

FR 593738/M2

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE
CERTIFICATS D'ESSAIS DES EQUIPEMENTS
ELECTRIQUES (IECEE) METHODE OC**CB TEST CERTIFICATE / CERTIFICAT D'ESSAI OC**Product
Produit

Connecting devices for low voltage circuits

Name and address of the applicant
Nom et adresse du demandeur**LEGRAND FRANCE**128, avenue du Maréchal de Lattre de Tassigny, B.P. 523 - 87045 LIMOGES
CEDEX - FranceName and address of the manufacturer
Nom et adresse du fabricant**LEGRAND FRANCE**128, avenue du Maréchal de Lattre de Tassigny B.P. 523 - 87045 LIMOGES
CEDEX - FranceName and address of the factory
Nom et adresse de l'usine**LEGRAND POLSKA Sp. zo.o**

ul. Warynskiego 20 - 57-200 ZABKOWICE SLASKIE - Poland

Note : When more than one factory, please report on page 2
Note : Lorsqu'il y a plus d'une usine, veuillez utiliser la 2ème pageRatings and principal characteristics
Valeurs nominales et caractéristiques principales

See annex 1

Trademark (if any)
Marque de fabrique (si elle existe)Type of Manufacturer's Testing Laboratories used
Type de programme du laboratoire d'essais constructeur

/

Model / Type Ref.
Ref. De type

References see annex 1

Additional information (if necessary may also be
reported on page 2)
Informations complémentaires (si nécessaire, peuvent
être indiquées sur la 2ème page)Supersedes the CBTC n° FR 593738/M1 dated 2011-02-25 (addition
of references)A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à la**PUBLICATION****EDITION**

IEC 60998-2-1:2002

IEC 60998-2-2:2002

As shown in the Test Report Ref. No. which forms part
of this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce CertificatSMT/AP08/PR000204-1, SMT/AP08/PR000204-2, 139004-680285,
139004-680285, 139004-680285A, 139004-680285BThis CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme National de Certification**Laboratoire Central des Industries Électriques**33, av du Général Leclerc – BP 8
FR 92266 Fontenay-aux-Roses cedex
www.lcie.fr

Date:

2016-03-07

Signature:

Jean-François BRUEL
Certification Officer

Annex 1

RATING AND PRINCIPAL CHARACTERISTICS

List of references of connecting devices BCA PR000204

References	Type of connecting devices	Length (mm)	Number of adjacent terminals		
			from 1,5 to 4 mm ²	from 6 to 25 mm ²	from 10 to 35 mm ²
AG00358AA	screw-type	63	-	1	-
	screwless-type		6	-	-
0 050 50	screw-type	63	-	1	-
	screwless-type		6	-	-
AG01090AA	screw-type	98	-	3	-
	screwless-type		9	-	-
0 050 51	screw-type	98	-	3	-
	screwless-type		9	-	-
AG00359AA	screw-type	217	-	5	-
	screwless-type		9	-	-
AG00360AA	screw-type	217	-	5	-
	screwless-type		18	-	-
AG00361AA	screw-type	217	-	5	-
	screwless-type		27	-	-
0 050 52	screw-type	217	-	5	-
	screwless-type		27	-	-
AG02628AA	screw-type	227	-	5	-
	screwless-type		9	-	-
AG02628BA	screw-type	227	-	5	-
	screwless-type		9	-	-
AG02628CA	screw-type	227	-	5	-
	screwless-type		9	-	-
AG02629AA	screw-type	227	-	5	-
	screwless-type		18	-	-
AG02629BA	screw-type	227	-	5	-
	screwless-type		18	-	-
AG02629CA	screw-type	227	-	5	-
	screwless-type		18	-	-
AG02630AA	screw-type	227	-	5	-
	screwless-type		27	-	-
AG02630BA	screw-type	227	-	5	-
	screwless-type		27	-	-
AG02630CA	screw-type	227	-	5	-
	screwless-type		27	-	-
4 050 56	screw-type	227	-	5	-
	screwless-type		27	-	-
4 050 55	screw-type	227	-	5	-
	screwless-type		27	-	-

Additional Information (if necessary)
Informations complémentaires (si nécessaire)



Laboratoire Central des Industries Électriques
33, av du Général Leclerc – BP 8
FR 92266 Fontenay-aux-Roses cedex
www.lcie.fr



Date: 2016-03-07

Signature:

Jean-François BRUNET
Certification Officer

List of references of connecting devices BCA PR000204

References	Type of connecting devices	Length (mm)	Number of adjacent terminals		
			from 1,5 to 4 mm ²	from 6 to 25 mm ²	from 10 to 35 mm ²
AG00362AA	screw-type	266	-	5	-
	screwless-type		9	-	-
AG00363AA	screw-type	266	-	5	-
	screwless-type		18	-	-
AG00364AA	screw-type	266	-	5	-
	screwless-type		27	-	-
AG01091AA	screw-type	266	-	5	-
	screwless-type		36	-	-
0 050 53	screw-type	266	-	5	-
	screwless-type		36	-	-
AG02631AA	screw-type	332	-	5	-
	screwless-type		27	-	-
AG02631BA	screw-type	332	-	5	-
	screwless-type		27	-	-
AG02631CA	screw-type	332	-	5	-
	screwless-type		27	-	-
AG02632AA	screw-type	332	-	5	-
	screwless-type		36	-	-
AG02632BA	screw-type	332	-	5	-
	screwless-type		36	-	-
AG02632CA	screw-type	332	-	5	-
	screwless-type		36	-	-
AG02633AA	screw-type	332	-	5	-
	screwless-type		45	-	-
AG02633BA	screw-type	332	-	5	-
	screwless-type		45	-	-
AG02633CA	screw-type	332	-	5	-
	screwless-type		45	-	-
4 050 57	screw-type	332	-	5	-
	screwless-type		45	-	-
AG00365AA	screw-type	375	-	5	-
	screwless-type		18	-	-
AG00366AA	screw-type	375	-	5	-
	screwless-type		27	-	-
AG00367AA	screw-type	375	-	5	-
	screwless-type		36	-	-
AG00369AA	screw-type	375	-	5	5
	screwless-type		45	-	-
0 050 54	screw-type	375	-	5	5
	screwless-type		45	-	-

Additional Information (if necessary)
Informations complémentaires (si nécessaire)



Laboratoire Central des Industries Électriques
33, av du Général Leclerc – BP 8
FR 92266 Fontenay-aux-Roses cedex
www.lcie.fr

Date: 2016-03-07

Signature:

Jean-François BRUJE
Certification Officer



CLASSIFICATION

Rated insulation voltage: 400V

Rated connecting capacity:

Screwless type terminals: - 1,5 to 4mm² rigid (solid and stranded) and flexible
andScrew type terminals: - 6 to 25mm² rigid (solid and stranded) and flexible
- 10 to 35mm² rigid (solid and stranded) and flexible

Technical characteristics

Number of terminals	multiway terminal devices
Function	tapping devices
Protection against electric shock	devices with protection
Means of fixing	devices with means of fixing devices
Maximum ambient temperature of use of the connecting device (rated temperature)	without T marking
Protection degree	IP20
Types of conductors which the terminal can accept	universal terminal (see above)
Colour	green (earthing terminals)

Additional Information (if necessary)
Informations complémentaires (si nécessaire)**Laboratoire Central des Industries Électriques**33,av du Général Leclerc – BP 8
FR 92266 Fontenay-aux-Roses cedex
www.lcie.fr

Date: 2016-03-07

Signature:

Jean-François BRUEL
Certification Officer