

**IEC****IECEE**

®

™

Ref. Certif. No.

**FR\_722774/M1****IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

**Portable socket-outlet**  
Rewirable portable socket-outlets

Name and address of the applicant

**LEGRAND FRANCE**  
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY  
87045 LIMOGES CEDEX - FRANCE

Name and address of the manufacturer

**LEGRAND FRANCE**  
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY  
87045 LIMOGES CEDEX - FRANCE

Name and address of the factory

**JIANDE HUNLEE ELECTRICAL APPLIANCE CO., LTD**  
CHENGNAN INDUSTRIAL PARK, MEICHENG TOWN IN  
JIANDE CITY, HANGZHOU, ZHEJIANG - CHINA

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)

legrand

Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

See Annex

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR\_722774 dated 10/10/2025.  
Addition of components Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60884-1:2022

As shown in the Test Report Ref. No. which forms part of this Certificate

ABND-ESH-P25091436

This CB Test Certificate is issued by the National Certification Body

**LCIE**LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
33 avenue du Général Leclerc  
92260 Fontenay-aux-Roses, FRANCE  
[www.lcie.fr](http://www.lcie.fr)

Date: 09/12/2025

Signature:   
**Julien GAUTHIER**  
Certification Officer

## ANNEX

### References, ratings and main characteristics:

Model	Reference	Number of socket-outlets	Color of enclosure
RNHS102X	0 496 38	3	WHITE/ GREY
	0 496 39	3	BLACK
	0 496 40	4	WHITE/ GREY
	0 496 41	4	BLACK
	0 496 42	5	WHITE/ GREY
	0 496 43	5	BLACK

### CLASSIFICATION

standard Sheet:	Standard sheet V of CEE 7
rated current (A)	16 A
rated load (W)	3680 W
rated voltage (V)	250 V~
household voltage (V)	230 V~
degree of protection	ordinary
provision for earthing	with earthing contact (Solid earthing pin)
method of connecting the cable	rewirable
type of terminals	Screw type
type of connections	-
colour	See tabel above
<b>socket-outlets</b>	
multiple socket-outlets	16 A : 3, 4, 5
number of socket-outlets	
degree of protection against electric shock	normal protection
existence of shutters	with shutters
method of application - mounting	portable type
method of installation	-
<b>plugs:</b>	
class of equipment	-
entry of cable	-

Type of components	Manufacturer	Certification
Switch	Cixi City Minghe Xinghua	SE-S-2200608
	HUIYANG ZING EAR INDUSTRY CO LTD	ENEC-05522



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
 33 avenue du Général Leclerc  
 92260 Fontenay-aux-Roses, FRANCE  
[www.lcie.fr](http://www.lcie.fr)

Date: 09/12/2025

Signature: *Julien GAUTHIER*

