

IEC

IECEE

Ref. Certif. No.

FR_723020

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Electronic remote-control switch
CONNECTED LATCHING RELAY (Electronic remote switch for fixed-electrical installations)

Name and address of the applicant

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX
FRANCE

Name and address of the manufacturer

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX
FRANCE

Name and address of the factory

BTICINO SPA
4 VIA LUCIANO MANARE
22036 ERBA
ITALY

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)

BTICINO

Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

BTDIN Series
See Annex

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR_715669/A1 dated 22/11/2022. Update further to the evolution of the standard(s)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60669-1:2017
IEC 60669-2-1:2021

As shown in the Test Report Ref. No. which forms part of this Certificate

26180375-811280

This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 13/11/2025

Signature:

J. Gauchier

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES
 RCS N° 459 459 845 984 €
 RCS N° 459 459 845 984 174
 33 avenue du Général Leclerc
 F - 92266 FONTENAY AUX ROSES

J. GAUCHIER
Certification Officer

ANNEX

References, ratings and main characteristics:

Trademark	Range	Reference	PRO / DIY	Designation
BTICINO	BTDIN	FC80RC	PRO	CONNECTED LATCHING RELAY

"All the commercial references listed above may be supplemented with a prefix of type LG-, BT-, ... (to indicate the brand) and/or suffix of type 0, 1, 2, 3, 4, FI, EX, ... In this case, the products are technically the same."

ACCESSORIES

Type Reference	Trademark	Range	References	Designation
ZLG09	BTICINO	BTDIN	FC80GT	ZIGBEE GATEWAY

CHARACTERISTICS

Rated current (A) or (AX)	16A / 100-240V~
Rated frequency	50/60 Hz
Load controlled	Declared load
Pattern number	1
Contact opening (gap)	micro gap
Degree of protection	IP20
Method of actuating	push-button / other external influences
Method of mounting	panel type on rail
Méthod of installation	design A
Type of terminals	screw terminals - see declared capacity



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 13/11/2025

Signature

