

**IEC****IECEE**

®

™

Ref. Certif. No.

**FR\_719966****IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

**Fixed socket-outlet**

Name and address of the applicant

**LEGRAND FRANCE**  
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY  
87045 LIMOGES CEDEX  
FRANCE

Name and address of the manufacturer

**LEGRAND FRANCE**  
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY  
87045 LIMOGES CEDEX  
FRANCE

Name and address of the factory

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

Gamme/ Serie: CELIANE  
Références / Reference ; 067133, 067134

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC 593472B dated 15/03/2010. Update further to the evolution of the standard(s)

 Additional Information on page 2


A sample of the product was tested and found to be in conformity with

IEC 60884-1:2022

As shown in the Test Report Ref. No. which forms part of this Certificate

20693577-795633

This CB Test Certificate is issued by the National Certification Body

**LCIE**LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
33 avenue du Général Leclerc  
92260 Fontenay-aux-Roses, FRANCE[www.lcie.fr](http://www.lcie.fr)LABORATOIRE CENTRAL DES  
INDUSTRIES ELECTRIQUES

S.A.S au capital de 15.745.984 €

RCS Nanterre B 408.363.174

33 avenue du Général Leclerc

F - 92266 FONTENAY AUX ROSES

Signature:   
**Julien GAUTHIER**  
Certification Officer

Date: 03/09/2024

IEC

IECEE

Ref. Certif. No.

FR\_719966

## ANNEX

**Name and address of the factories:**

**LEGRAND FRANCE**

128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY  
87045 LIMOGES CEDEX  
FRANCE


**LEGRAND FRANCE SILLE LE GUILLAUME**

80 ROUTE D'EVRON  
72140 SILLE LE GUILLAUME  
FRANCE



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
33 avenue du Général Leclerc  
92260 Fontenay-aux-Roses, FRANCE  
[www.lcie.fr](http://www.lcie.fr)

Date: 03/09/2024



Signature:  **Julien GAUTHIER**  
Certification Officer

## ANNEX

**References, ratings and main characteristics:**

References White	References Titanium	Function	Specificities
0 671 33	0 671 34	2P+E	Easy to handle socket-outlets

**Accessories**

Reference	References White	References Titanium	References Aluminium	Designation
0 802 52	-	-	-	Frame
-	0 666 35	0 689 05	0 689 25	Cover plate

Standard sheet	V (CCE7)
Rated current (A)	16A
Rated voltage (V)	250V~
Degree of protection	IP20
Provision for earthing	With earthing contact
Method of connecting the cable	Rewirable
Type of terminals	Screwless type ( rigid and flexible )
Degree of protection against electric shock	Normal protection
Existence of shutters	With shutters
Method of mounting	Flush type
Method of installation	Design A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
33 avenue du Général Leclerc  
92260 Fontenay-aux-Roses, FRANCE  
[www.lcie.fr](http://www.lcie.fr)

Date: 03/09/2024



LABORATOIRE CENTRAL DES  
INDUSTRIES ELECTRIQUES  
S.A.S au capital de 15.745.984 €  
RCS Nanterre B 488 363 174  
33 avenue du Général Leclerc  
F - 92266 FONTENAY AUX ROSES

Signature: *Julien Gauthier*  
**Julien GAUTHIER**  
Certification Officer