

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Switch Switches for fixed electrical installations
Name and address of the applicant	TCL Legrand International electrical (Huizhou) Co Ltd Bldg.B1-B3, East No.39 Hechang 6th Rd., HZZK Hi-tech Industrial Development Zone, HUIZHOU, GUANGDONG - CHINA
Name and address of the manufacturer	TCL Legrand International electrical (Huizhou) Co Ltd Bldg.B1-B3, East No.39 Hechang 6th Rd., HZZK Hi-tech Industrial Development Zone HUIZHOU, GUANGDONG - CHINA
Name and address of the factory	TCL Legrand International electrical (Huizhou) Co Ltd Bldg.B1-B3, East No.39 Hechang 6th Rd., HZZK Hi-tech Industrial Development Zone, HUIZHOU, GUANGDONG - CHINA
Note: When more than one factory, please report on page 2	<input type="checkbox"/> Additional Information on page 2
Ratings and principal characteristics	See Annex
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	/
Model / Type Ref.	617678, 617778, 617878
Additional information (if necessary may also be reported on page 2)	/
A sample of the product was tested and found to be in conformity with	<input type="checkbox"/> Additional Information on page 2 IEC 60669-1:2017
As shown in the Test Report Ref. No. which forms part of this Certificate	ARLI-19MY3197ACSHP

This CB Test Certificate is issued by the National Certification Body



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 06/09/2019



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Signature:  Julien GAUTHIER
Certification Officer

ANNEX

REFERENCES - PRINCIPAL CHARACTERISTICS

Reference	Range*	Description	Color of enclosure
617678	Belanko S	Cooker Control unit 2 gang (45A double pole switch with red neon + 2P+E 13A British Standard Double Pole switched + red neon)	White
617778	Belanko S	Cooker Control unit 2 gang (45A double pole switch with red neon + 2P+E 13A British Standard Double Pole switched + red neon)	Anthracite
617878	Belanko S	Cooker Control unit 2 gang (45A double pole switch with red neon + 2P+E 13A British Standard Double Pole switched + red neon)	Ivory

* The "range" denotes applicant's categorization.

Pattern number	2
Contact opening	normal gap
Protection degree	IP20
Method of actuating	rocker
Method of mounting	flush-type
Method of installation	design A
Type of terminals	screw-type (rigid and flexible)
Flexible cable outlet	without
Ratings	45A 250V~
Color	White, Anthracite, Ivory

Components	Model	Manufacturer	Conformity
Combined 13A switched socket-outlet	617678, 617778, 617878	TCL-Legrand International Electrical(Huizhou) Co., Ltd.	LCIE test report No. ARLI-19MY3195ACSHP



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 06/09/2019



LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Signature: Julien GAUTHIER
Certification Officer