

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Fixed switched socket-outlet Switched socket-outlets for fixed installations
Name and address of the applicant	TCL-Legrand International Electrical(Huizhou) Co., Ltd Bldg. B1-B3, East No.39 Hechang 6th Rd., HZZK Hi-tech Industrial Development Zone, Huizhou, Guangdong - China
Name and address of the manufacturer	TCL-Legrand International Electrical(Huizhou) Co., Ltd Bldg. B1-B3, East No.39 Hechang 6th Rd., HZZK Hi-tech Industrial Development Zone, Huizhou, Guangdong - China
Name and address of the factory	TCL-Legrand International Electrical(Huizhou) Co., Ltd Bldg. B1-B3, East No.39 Hechang 6th Rd., HZZK Hi-tech Industrial Development Zone, Huizhou, Guangdong - China
Note: When more than one factory, please report on page 2	<input type="checkbox"/> Additional Information on page 2
Ratings and principal characteristics	See Annex
Trademark / Brand (if any)	
Customer's Testing Facility (CTF) Stage used	/
Model / Type Ref.	See Annex
Additional information (if necessary may also be reported on page 2)	/
A sample of the product was tested and found to be in conformity with	<input checked="" type="checkbox"/> Additional Information on page 2 IEC 60884-1:2002 +A1:2006 +A2:2013 IEC 60884-2-3:2006
As shown in the Test Report Ref. No. which forms part of this Certificate	ARLI-19MY2824ACSHP

This CB Test Certificate is issued by the National Certification Body



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 31/10/2019

Signature: Didier BOURGES
Manager of Certification Operations




REFERENCES RATING AND MAIN CHARACTERISTICS

References	Description		Color of enclosure
617651	15 A 250 V~	1G BS 15A SP SWTD SOCKET WH	White
617751	15 A 250 V~	1G BS 15A SP SWTD SOCKET AN	Anthracite
617851	15 A 250 V~	1G BS 15A SP SWTD SOCKET CH	Ivory
617652	15 A 250 V~	1G BS 15A SP SWTD + LED Indicator light WH	White
617752	15 A 250 V~	1G BS 15A SP SWTD + LED Indicator light AN	Anthracite
617852	15 A 250 V~	1G BS 15A SP SWTD + LED Indicator light CH	Ivory
617653	15 A 250 V~	2G BS 15A SP SWITCHED WH	White
617753	15 A 250 V~	2G BS 15A SP SWITCHED AN	Anthracite
617853	15 A 250 V~	2G BS 15A SP SWITCHED CH	Ivory
617654	5 A 250 V~	1G BS 5A SWITCHED SOCKET WH	White
617754	5 A 250 V~	1G BS 5A SWITCHED SOCKET AN	Anthracite
617854	5 A 250 V~	1G BS 5A SWITCHED SOCKET CH	Ivory
282437	15 A 250 V~	1G BS 15A SWITCHED SOCKET	White
282437-C	15 A 250 V~	1G BS 15A SWITCHED SOCKET	Matt black
282437-C1	15 A 250 V~	1G BS 15A SWITCHED SOCKET	Rose gold
282437-C2	15 A 250 V~	1G BS 15A SWITCHED SOCKET	Champagne
282437-C3	15 A 250 V~	1G BS 15A SWITCHED SOCKET	Dark silver
282438	5 A 250 V~	1G BS 5A SWITCHED SOCKET	White
282438-C	5 A 250 V~	1G BS 5A SWITCHED SOCKET	Matt black
282438-C1	5 A 250 V~	1G BS 5A SWITCHED SOCKET	Rose gold

standard Sheet:	standard sheet of BS 546
rated current (A)	15 A or 5 A
rated voltage (V)	250 V~
degree of protection	IP20
provision for earthing	with earthing contact
method of connecting the cable	rewirable
type of terminals	screw-type
colour	See above table
Socket-outlets	
multiple socket-outlets	15 A : 1 or 2
number of socket-outlets	5 A : 1
degree of protection against electric shock	normal protection
existence of shutters	with shutters
method of application - mounting	flush-type
method of installation	design A
Intended for circuits where	a single earthing circuit provides protective earthing
Switched socket-outlets without interlock	
According to the method of actuating the switch	rocker
According to the switching of the neutral	Unswitched neutral



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



Date: 31/10/2019

Signature: Didier BOURGEOIS
Manager of Certification Operations