



Ref. Certif. No.

FR\_722223

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Socket-outlet for fixed-electrical installations

Name and address of the applicant

**LEGRAND FRANCE**  
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY  
87045 LIMOGES CEDEX  
FRANCE

Name and address of the manufacturer

**LEGRAND FRANCE**  
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY  
87045 LIMOGES CEDEX  
FRANCE

Name and address of the factory

Note: When more than one factory, please report on page 2

☒ Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

Series CELIANE  
CB0117, CT0117

Additional information (if necessary may also be reported on page 2)

/

☒ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60884-1:2022

As shown in the Test Report Ref. No. which forms part of this Certificate

24631550-807572


This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
33 avenue du Général Leclerc  
92260 Fontenay-aux-Roses, FRANCE  
[www.lcie.fr](http://www.lcie.fr)

Date: 31/07/2025

Signature: **Julien GAUTHIER**



**Name and address of the factories:**

**LEGRAND FRANCE**

128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY  
87045 LIMOGES CEDEX  
FRANCE

**LEGRAND FRANCE SILLE LE GUILLAUME**

80 ROUTE D'EVRON  
72140 SILLE LE GUILLAUME  
FRANCE



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
33 avenue du Général Leclerc  
92260 Fontenay-aux-Roses, FRANCE  
[www.lcie.fr](http://www.lcie.fr)

Date: 31/07/2025

Signature: **Julien GAUTHIER**



## ANNEX

### Classification

|                                             |                                       |
|---------------------------------------------|---------------------------------------|
| Standard sheet                              | V (CEE7)                              |
| Rated current (A)                           | 16A                                   |
| Rated voltage (V)                           | 250V~                                 |
| Degree of protection                        | IP20                                  |
| Provision for earthing                      | With earthing contact                 |
| Method of connecting the cable              | Rewirable                             |
| Type of terminals                           | Screwless type ( rigid and flexible ) |
| Number of socket-outlets                    |                                       |
| Degree of protection against electric shock | Normal protection                     |
| Existence of shutters                       | With shutters                         |
| Method of mounting                          | Flush type                            |
| Method of installation                      | Design A                              |

### Accessories

| Reference | References White | References Gris Cendré | References Alu Satiné | Designation |
|-----------|------------------|------------------------|-----------------------|-------------|
| 0 802 52  | -                | -                      | -                     | Frame       |
| -         | CP0008           | CP1008                 | CP1708                | Cover plate |

### Mechanisms

| Trademark | References White | References Titanium | Function | Specificities                 |
|-----------|------------------|---------------------|----------|-------------------------------|
| LEGRAND   | CB0117           | CT0117              | 2P+E     | Easy to handle socket-outlets |



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
33 avenue du Général Leclerc  
92260 Fontenay-aux-Roses, FRANCE  
[www.lcie.fr](http://www.lcie.fr)

Date: 31/07/2025

Signature: Julien GAUTHIER

