



Ref. Certif. No.

FR_715848

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Measurement device

Connected measurement module / Connected load shedder

Name and address of the applicant

LEGRAND FRANCE

128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX
FRANCE

Name and address of the manufacturer

LEGRAND FRANCE

128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX
FRANCE

Name and address of the factory

BTICINO SPA

4 VIA LUCIANO MANARE
22036 ERBA
ITALY

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)

BTICINO

Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

See Annex

Additional information (if necessary may also be reported on page 2)

/ ☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61010-1:2010 + A1:2016

As shown in the Test Report Ref. No. which forms part of this Certificate

172063-763851-A Version : 01

This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr



Date: 15/11/2022

Signature: **Gilles LEMONNIER**
Certification Officer

ANNEX

REFERENCES – MAIN CHARACTERISTICS

Trademark	Range	Reference	Designation
BTICINO	BTDIN	F20T60A	CONNECTED MEASUREMENT MODULE
		FC80GCS	CONNECTED LOAD SHEDDER

Accessoires

Trademark	Range	Reference	Designation
BTICINO	BTDIN	FG80GT	ZIGBEE GATEWAY

Characteristics	
Rated current (A) or (AX)	100-240V~
Rated frequency	50/60 Hz
Pattern number	1
Degree of protection	IP20
Method of actuating	other external influences
Method of mounting	panel type on rail
Méthod of installation	design A
Type of terminals	screw terminals – capacity 2x1,5mm ²



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 15/11/2022

Signature: 
 Certification Officer