



Ref. Certif. No.

FR_718536

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Switch-disconnector

Name and address of the applicant

LEGRAND FRANCE
159 RUE JEAN JOANNON
ZI DES TROIS MOULINS
06606 ANTIBES
FRANCE

Name and address of the manufacturer

LEGRAND FRANCE
159 RUE JEAN JOANNON
ZI DES TROIS MOULINS
06606 ANTIBES
FRANCE

Name and address of the factory

LEGRAND ELEKTRIK SANAYI A.S
GOSB GEBZE ORGANIZE SANAYI BOLGESI
IHSAN DEDE CADDESİ N° 112
41480 GEBZE KOCAELI
TURKEY

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

CTF3

Model / Type Ref.

Series DX³
References see annex

Additional information (if necessary may also be reported on page 2)

Initial certification based on existing certificate (Supersedes CBTC FR_701840 dated 16/11/2017).

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-3:2020

As shown in the Test Report Ref. No. which forms part of this Certificate

19277794-790920, 19277794-790920/1 to 19277794-790920/4

This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 01/02/2024



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 263 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES
Signature:
Julien GAUTHIER
Certification Officer

ANNEX

References, ratings and main characteristics:

References	Ue	Ie	Poles
4064 23	250V~	100A	1 P
LG1262	250V~	125A	1 P
4064 49	400V~	100A	2 P
4064 55*			
4064 50	400V~	125A	2 P
4064 69	400V~	100A	3 P
4064 75*			
4064 70	400V~	125A	3 P
4064 89	400V~	100A	4 P
4064 95*			
4064 90	400V~	125A	4 P


* switch-disconnectors with a red actuator for United Kingdom

Utilization category	AC-22A
Method of manually operated equipment	Dependent manual operation
Suitability for isolation	Suitable
Protection degree :	IP20
Number of poles :	1-2-3-4
Nature of supply :	AC ~
Number of positions of the main contact	2
Rated operational voltage Ue : (V)	250V (1P) 400V (2P/3P/4P)
Rated insulation voltage Ui : (V)	500V
Rated impulse withstand voltage Uimp : (V)	6000V
Conventional free air thermal current Ith : (A)	100/125A
Conventional enclosed thermal current Ithe : (A)	100/125A
Rated operational current Ie : (A)	100/125A
Rated uninterrupted current Iu : (A)	100/125A
Rated frequency : (Hz)	50/60Hz
Rated duty	
Eight-hour duty	yes
Uninterrupted duty	yes
Ability to withstand motor switching overload currents	no
Rated short-time withstand current : Icw (A)	2500A
Rated short-circuit making capacity : Icm (A)	3700A
Material group :	II
Type of terminals:	screw
Diameter of thread terminals : (mm)	6,0mm
Tightening torque : (Nm)	2,5Nm
Connecting capacity:	
Min .cross-section (mm ²) / Number of conductors	4mm ² / 2 (rigid and flexible)
Max. cross-section (mm ²) / Number of conductors	50mm ² / 1 (rigid) 35mm ² / 1 (flexible)
Min./Max .cross-section (mm ²) / Number of conductors	4+16mm ² / 1 (rigid and flexible)



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE

www.lcie.fr



Signature: **Julien GAUTHIER**
Certification Officer

Date: 01/02/2024