

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product	Switched socket-outlet (flush-type)
Name and address of the applicant	TCL-Legrand International Electrical (Huizhou) Co., Ltd. Bldg. B1-B3, East No.39 Hechang 6th Rd., HZZK Hi-tech Industrial Development Zone, Huizhou, Guangdong, P. R. China
Name and address of the manufacturer	LEGRAND FRANCE 128, Avenue du Maréchal de Lattre de Tassigny 87045 LIMOGES Cedex- FRANCE
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	Same as applicant
Ratings and principal characteristics	13A, 250V~, IP20
Trademark (if any)	Legrand
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	6 176 48, 6 177 48, 6 178 48
Additional information (if necessary may also be reported on page 2)	See page 2
A sample of the product was tested and found to be in conformity with	IEC 60884-1:2002+A1+A2, IEC 60884-2-3:2006
As shown in the Test Report Ref. No. which forms part of this Certificate	201102362SHA-001

This CB Test Certificate is issued by the National Certification Body

**Intertek Semko AB**  
Torshamnsgatan 43  
Box 1103  
SE-164 22 Kista, Sweden

**intertek**  
Signature:   
Hyden Li

Date: 08 December, 2020



Ref. Certif. No.

**SE-103249**

**Additional information**

13A 250V~, flush type, IP20, Class I, rewirable, with screw-type terminals, with 2 gang switched socket outlets comply with type G (configuration of BS 1363-2), with shutters, with one double pole switch for each socket-outlet, with plastic cover plate.

6 176 48: with white front cover and white cover plate;

6 177 48: with dark front cover and dark cover plate;

6 178 48: with ivory front cover and ivory cover plate.

Date: 08 December, 2020

Signature: 