



Ref. Certif. No.

CN41372-A1/M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

**CB TEST CERTIFICATE**

Product

Single-phase Flush-type Two-pole Socket-outlet with Earthing-contact with Shutters

Name and address of the applicant

Legrand Intelligent Electrical (Huizhou) Co., Ltd.  
Bldg. B1-B3, East No.39 Hechang 6th Rd., HZZK Hi-tech Industrial Development Zone, Huizhou, Guangdong, P.R. China

Name and address of the manufacturer

LEGRAND FRANCE  
128, Avenue du Maréchal de Lattre de Tassigny 87045 LIMOGES CedexFRANCE

Name and address of the factory

Legrand Intelligent Electrical (Huizhou) Co., Ltd.  
Bldg. B1-B3, East No.39 Hechang 6th Rd., HZZK Hi-tech Industrial Development Zone, Huizhou, Guangdong, P.R. China*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

13A 250V~

Trademark / Brand (if any)

Graphic Trademark, See the report

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

K8/426/13/2-HK, K8/426/13-HK, 282431, 282431-C, 282431-C1, 282431-C2, 282431-C3, 282430, 282430-C, 282430-C1, 282430-C2, 282430-C3

Additional information (if necessary may also be reported on page 2)

IEC60884-1(ed.3);am1;am2

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

CVC2017-0699-A1/M1

This CB Test Certificate is issued by the National Certification Body

**CHINA QUALITY CERTIFICATION CENTRE**Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China  
Tel: +86-10-83886666 Fax: +86-10-83886282  
website: <http://www.cqc.com.cn>

Date: May.26,2021

Signature:

Lu Mei

**CB 0062242**