

IEC**IECEE**

®

TM

Ref. Certif. No.

JPTUV-139105

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Uninterruptible Power Systems

Name and address of the applicant

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX, France

Name and address of the manufacturer

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX, France

Name and address of the factory

See additional page(s)

Ratings and principal characteristics

i/p: 1) 1Ø; AC 240V; 50/60Hz; 10.84A; 2) 1Ø, AC 230V;
50/60Hz; 11.31A; 3) 1Ø; AC 220V; 50/60Hz; 11.82A;
4) 1Ø; AC 208V; 50/60Hz; 11.25A; 5) 1Ø; AC 200V;
50/60Hz; 11.70A; Class I
o/p: refer to the test report

Trademark (if any)

legrand

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

3 110 70, 3 110 71

Additional information (if necessary may also be reported on page 2)

For model differences, refer to the test report.

A sample of the product was tested and found to be in conformity with

IEC 62040-1:2017+A1

As shown in the Test Report Ref. No. which forms part of this Certificate

CN22KAHW 001

This CB Test Certificate is issued by the National Certification Body

TÜV Rheinland Japan Ltd.
Global Technology Assessment Center
4-25-2 Kita-Yamata, Tsuzuki-ku
Yokohama 224-0021, Japan
Phone + 81 45 914-3888
Fax + 81 45 914-3354
Mail: info@jpn.tuv.com
Web : www.tuv.com

Date: 2022-09-05

Signature:

Dipl.-Ing. (FH) A. Klinker


1. Delta Electronics (Dongguan) Co., Ltd.
No.33, Pantao Road, Shijie Town,
Dongguan, Guangdong 523308,
P.R. China
2. Delta Electronics (Jiangsu) Ltd.
215200, No.1688, Jiangxing East Road,
Wujiang Economic and Technological
Development Zone
Suzhou City, Jiangsu Province, P.R. China
3. DELTA ELECTRONICS (WUHU) LTD.
No. 138, Jiuhua North Road
LongShan Street
Economic-technical Development Area
Wuhu City, Anhui Province, P.R. China
4. Delta Electronics (Thailand) Public
Co., Ltd.
111/6 Moo 9, Wellgrow Industrial Estate,
Bangna-Trad Road, Tambol Bangwua,
Amphur Bangpakong, Chachoengsao 24180, Thailand
5. Delta Electronics (Dongguan) Co., Ltd.
Southwest Branch
No.33, Pantao Road, Shijie Town,
Dongguan, Guangdong 523308,
P.R. China
6. Delta Electronics India Private
Limited-SEZ Unit
Delta SEZ Notified at SY No. 16/1B2B
Part & 16/1B2A Part Plot No.1,
Industrial Park, Kurubarapalli Village, Krishnagiri Dist, Tamil Nadu,
635115, India

Additional information (if necessary)

Report Ref. No. : CN22KAHW 001

Date: 2022-09-05

Signature:


Dipl.-Ing. (FH) A. Klinker



Test Report issued under the responsibility of:



TEST REPORT
IEC 62040-1
Uninterruptible power systems (UPS) –
Part 1: General and safety requirements for UPS

Report Number..... : CN22KAHW 001

Date of issue..... : Aug. 15, 2022

Total number of pages : 126

Name of Testing Laboratory preparing the Report : TÜV Rheinland Taiwan Ltd., Taoyuan Testing Laboratories

Applicant's name : LEGRAND FRANCE

Address..... : 128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY 87045 LIMOGES CEDEX, France

Test specification:

Standard : IEC 62040-1:2017, IEC 62040-1:2017/AMD1:2021

Test procedure : CB Scheme

Non-standard test method : N/A

TRF template used..... : IECEE OD-2020-F1:2021, Ed.1.4

Test Report Form No. : IEC62040_1F

Test Report Form(s) Originator : TÜV Rheinland Japan Ltd.

Master TRF : Dated 2021-08-27

Copyright © 2021 IEC System of Conformity Assessment Schemes for Electrotechnical Equipment and Components (IECEE System). All rights reserved.

This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.

If this Test Report Form is used by non-IECEE members, the IECEE/IEC logo and the reference to the CB Scheme procedure shall be removed.

This report is not valid as a CB Test Report unless signed by an approved IECEE Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IECEE 02.

General disclaimer:

The test results presented in this report relate only to the object tested.

This report shall not be reproduced, except in full, without the written approval of the Issuing NCB. The authenticity of this Test Report and its contents can be verified by contacting the NCB, responsible for this Test Report.