



Ref. Certif. No.

FR\_705078

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCB's)

Name and address of the applicant

LEGRAND FRANCE  
159 RUE JEAN JOANNON ZI DES TROIS MOULINS  
06606 ANTIBES - FRANCE

Name and address of the manufacturer

LEGRAND FRANCE  
159 RUE JEAN JOANNON ZI DES TROIS MOULINS  
06606 ANTIBES - FRANCE

Name and address of the factory

See Annex

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark (if any)



Customer's Testing Facility (CTF) Stage used

CTF2

Model / Type Ref.

Series: TX<sup>3</sup>, RX<sup>3</sup>, XC<sup>3</sup>, DX<sup>3</sup>  
References: see annex

Additional information (if necessary may also be reported on page 2)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61008-1:2010(ed.3) +A1:2012 +A2:2013  
IEC 61008-2-1:1990(ed.1)


As shown in the Test Report Ref. No. which forms part of this Certificate

154382-718396, 154382-718396-1 to 154382-718396-39

This CB Test Certificate is issued by the National Certification Body



LCIE – Laboratoire Central des Industries Electriques  
33, avenue du Général Leclerc – BP8  
FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)



LABORATOIRE CENTRAL DES  
INDUSTRIES ELECTRIQUES  
S.A.S au capital de 15746084 €  
RCS Nanterre 408 563 174  
33 Avenue du Général Leclerc  
F – 92266 FONTENAY AUX ROSES

Date: 19/02/2019

Signature: **Jean-François BRUEL**  
Certification Officer

## ANNEX

## Name and address of the factories:

**LEGRAND FRANCE**  
 290 AVENUE DE COLMAR  
 67100 STRASBOURG - FRANCE

**LEGRAND FRANCE**  
 159 RUE JEAN JOANNON ZI DES TROIS MOULINS  
 06606 ANTIBES - FRANCE


**LEGRAND ELEKTRIK SANAYI A.S**  
 GOSB GEBZE ORGANIZE SANAYI BOLGESI - IHSAN DEDE CADDESİ N°112  
 41480 GEBZE KOCAELI - TURKEY

## REFERENCES, RATINGS AND MAIN CHARACTERISTICS

Reference TX <sup>3</sup> « Germanique » series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
4117 07	25 A	400 V~	right	30 mA	AC	500 A	1000 A	10000 A	10000 A
4117 08	40 A	400 V~	right	30 mA	AC	500 A	1000 A	10000 A	10000 A
4117 09	63 A	400 V~	right	30 mA	AC	630 A	1000 A	10000 A	10000 A
4117 10	80 A	400 V~	right	30 mA	AC	800 A	1000 A	10000 A	10000 A
LG1293	100 A	400 V~	right	30 mA	AC	1000 A	1000 A	10000 A	10000 A
4117 17	25 A	400 V~	right	100 mA	AC	500 A	1000 A	10000 A	10000 A
4117 18	40 A	400 V~	right	100 mA	AC	500 A	1000 A	10000 A	10000 A
4117 19	63 A	400 V~	right	100 mA	AC	630 A	1000 A	10000 A	10000 A
4117 20	80 A	400 V~	right	100 mA	AC	800 A	1000 A	10000 A	10000 A
LG1294	100 A	400 V~	right	100 mA	AC	1000 A	1000 A	10000 A	10000 A
4117 27	25 A	400 V~	right	300 mA	AC	500 A	1000 A	10000 A	10000 A
4117 28	40 A	400 V~	right	300 mA	AC	500 A	1000 A	10000 A	10000 A
4117 29	63 A	400 V~	right	300 mA	AC	630 A	1000 A	10000 A	10000 A
4117 30	80 A	400 V~	right	300 mA	AC	800 A	1000 A	10000 A	10000 A
LG1295	100 A	400 V~	right	300 mA	AC	1000 A	1000 A	10000 A	10000 A
4117 37	25 A	400 V~	right	500 mA	AC	500 A	1000 A	10000 A	10000 A
4117 38	40 A	400 V~	right	500 mA	AC	500 A	1000 A	10000 A	10000 A
4117 39	63 A	400 V~	right	500 mA	AC	630 A	1000 A	10000 A	10000 A
4117 40	80 A	400 V~	right	500 mA	AC	800 A	1000 A	10000 A	10000 A
LG1296	100 A	400 V~	right	500 mA	AC	1000 A	1000 A	10000 A	10000 A



LCIE – Laboratoire Central des Industries Electriques  
 33, avenue du Général Leclerc – BP8  
 FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)



Date: 19/02/2019

 Signature: **Jean-François BRUEL**  
 Certification Officer


## ANNEX (continued)

Reference TX <sup>3</sup> « Germanique » series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
411764 4119 31 (a)	25 A	400 V~	right	30 mA	A	500 A	1000 A	10000 A	10000 A
4117 65 4119 32 (a)	40 A	400 V~	right	30 mA	A	500 A	1000 A	10000 A	10000 A
4117 66 4119 33 (a)	63 A	400 V~	right	30 mA	A	630 A	1000 A	10000 A	10000 A
4117 67	80 A	400 V~	right	30 mA	A	800 A	1000 A	10000 A	10000 A
4117 68	100 A	400 V~	right	30 mA	A	1000 A	1000 A	10000 A	10000 A
411774 4119 36 (a)	25 A	400 V~	right	100 mA	A	500 A	1000 A	10000 A	10000 A
4117 75 4119 37 (a)	40 A	400 V~	right	100 mA	A	500 A	1000 A	10000 A	10000 A
4117 76 4119 38 (a)	63 A	400 V~	right	100 mA	A	630 A	1000 A	10000 A	10000 A
4117 77	80 A	400 V~	right	100 mA	A	800 A	1000 A	10000 A	10000 A
4117 78	100 A	400 V~	right	100 mA	A	1000 A	1000 A	10000 A	10000 A
4117 84	25 A	400 V~	right	300 mA	A	500 A	1000 A	10000 A	10000 A
4117 85 4119 42 (a)	40 A	400 V~	right	300 mA	A	500 A	1000 A	10000 A	10000 A
4117 86 4119 43 (a)	63 A	400 V~	right	300 mA	A	630 A	1000 A	10000 A	10000 A
4117 87	80 A	400 V~	right	300 mA	A	800 A	1000 A	10000 A	10000 A
4117 88	100 A	400 V~	right	300 mA	A	1000 A	1000 A	10000 A	10000 A
4117 94	25 A	400 V~	right	500 mA	A	500 A	1000 A	10000 A	10000 A
4117 95	40 A	400 V~	right	500 mA	A	500 A	1000 A	10000 A	10000 A
4117 96	63 A	400 V~	right	500 mA	A	630 A	1000 A	10000 A	10000 A
4117 97	80 A	400 V~	right	500 mA	A	800 A	1000 A	10000 A	10000 A
4117 98	100 A	400 V~	right	500 mA	A	1000 A	1000 A	10000 A	10000 A

(a) RCCB's dedicated to Belgium market



LCIE – Laboratoire Central des Industries Electriques  
33, avenue du Général Leclerc – BP8  
FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)




Date: 19/02/2019

Signature: **Jean-François BRUEL**  
Certification Officer

## ANNEX (continued)

Reference TX <sup>3</sup> « Germanique » series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
LG1309	25 A	400 V~	right	100 mA	AC-S	500 A	1000 A	10000 A	10000 A
4117 42	40 A	400 V~	right	100 mA	AC-S	500 A	1000 A	10000 A	10000 A
4117 43	63 A	400 V~	right	100 mA	AC-S	630 A	1000 A	10000 A	10000 A
LG1310	80 A	400 V~	right	100 mA	AC-S	800 A	1000 A	10000 A	10000 A
LG1311	100 A	400 V~	right	100 mA	AC-S	1000 A	1000 A	10000 A	10000 A
LG1312	25 A	400 V~	right	300 mA	AC-S	500 A	1000 A	10000 A	10000 A
4117 48	40 A	400 V~	right	300 mA	AC-S	500 A	1000 A	10000 A	10000 A
4117 49	63 A	400 V~	right	300 mA	AC-S	630 A	1000 A	10000 A	10000 A
LG1313	80 A	400 V~	right	300 mA	AC-S	800 A	1000 A	10000 A	10000 A
LG1314	100 A	400 V~	right	300 mA	AC-S	1000 A	1000 A	10000 A	10000 A
LG1315	25 A	400 V~	right	500 mA	AC-S	500 A	1000 A	10000 A	10000 A
LG1316	40 A	400 V~	right	500 mA	AC-S	500 A	1000 A	10000 A	10000 A
LG1317	63 A	400 V~	right	500 mA	AC-S	630 A	1000 A	10000 A	10000 A
LG1318	80 A	400 V~	right	500 mA	AC-S	800 A	1000 A	10000 A	10000 A
LG1319	100 A	400 V~	right	500 mA	AC-S	1000 A	1000 A	10000 A	10000 A
Reference TX <sup>3</sup> « Germanique » series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
4119 51	25 A	400 V~	right	100 mA	A-S	500 A	1000 A	10000 A	10000 A
4119 52	40 A	400 V~	right	100 mA	A-S	500 A	1000 A	10000 A	10000 A
4119 53	63 A	400 V~	right	100 mA	A-S	630 A	1000 A	10000 A	10000 A
LG1304	80 A	400 V~	right	100 mA	A-S	800 A	1000 A	10000 A	10000 A
LG1305	100 A	400 V~	right	100 mA	A-S	1000 A	1000 A	10000 A	10000 A
4118 03	25 A	400 V~	right	300 mA	A-S	500 A	1000 A	10000 A	10000 A
4118 04	40 A	400 V~	right	300 mA	A-S	500 A	1000 A	10000 A	10000 A
4119 47 (a)	40 A	400 V~	right	300 mA	A-S	500 A	1000 A	10000 A	10000 A
4118 05	63 A	400 V~	right	300 mA	A-S	630 A	1000 A	10000 A	10000 A
4119 48 (a)	63 A	400 V~	right	300 mA	A-S	630 A	1000 A	10000 A	10000 A
4118 06	80 A	400 V~	right	300 mA	A-S	800 A	1000 A	10000 A	10000 A
LG1306	100 A	400 V~	right	300 mA	A-S	1000 A	1000 A	10000 A	10000 A
LG1307	25 A	400 V~	right	500 mA	A-S	500 A	1000 A	10000 A	10000 A
4118 07	40 A	400 V~	right	500 mA	A-S	500 A	1000 A	10000 A	10000 A
4118 08	63 A	400 V~	right	500 mA	A-S	630 A	1000 A	10000 A	10000 A
4118 09	80 A	400 V~	right	500 mA	A-S	800 A	1000 A	10000 A	10000 A
LG1308	100 A	400 V~	right	500 mA	A-S	1000 A	1000 A	10000 A	10000 A

(a) RCCB's dedicated to Belgium market


 LCIE – Laboratoire Central des Industries Electriques  
 33, avenue du Général Leclerc – BP8  
 FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)


Date: 19/02/2019

 Signature: **Jean-François BRUEL**  
 Certification Officer


## ANNEX (continued)

Reference TX <sup>a</sup> « Germanique » series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
LG1297	25 A	400 V~	right	30 mA	AC*	500 A	1000 A	10000 A	10000 A
4117 52	40 A	400 V~	right	30 mA	AC*	500 A	1000 A	10000 A	10000 A
4117 53	63 A	400 V~	right	30 mA	AC*	630 A	1000 A	10000 A	10000 A
LG1298	80 A	400 V~	right	30 mA	AC*	800 A	1000 A	10000 A	10000 A
LG2732	100 A	400 V~	right	30 mA	AC*	1000 A	1000 A	10000 A	10000 A
LG1299	25 A	400 V~	right	100 mA	AC*	500 A	1000 A	10000 A	10000 A
4117 56	40 A	400 V~	right	100 mA	AC*	500 A	1000 A	10000 A	10000 A
4117 57	63 A	400 V~	right	100 mA	AC*	630 A	1000 A	10000 A	10000 A
LG1300	80 A	400 V~	right	100 mA	AC*	800 A	1000 A	10000 A	10000 A
LG2734	100 A	400 V~	right	100 mA	AC*	1000 A	1000 A	10000 A	10000 A
LG2736	25 A	400 V~	right	300 mA	AC*	500 A	1000 A	10000 A	10000 A
LG2737	40 A	400 V~	right	300 mA	AC*	500 A	1000 A	10000 A	10000 A
LG2738	63 A	400 V~	right	300 mA	AC*	630 A	1000 A	10000 A	10000 A
LG2739	80 A	400 V~	right	300 mA	AC*	800 A	1000 A	10000 A	10000 A
LG2740	100 A	400 V~	right	300 mA	AC*	1000 A	1000 A	10000 A	10000 A

\* RCCB's dedicated to Austria market



LCIE – Laboratoire Central des Industries Electriques  
33, avenue du Général Leclerc – BP8  
FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)



Signature: **Jean-François BRUEL**  
Certification Officer


Date: 19/02/2019

## ANNEX (continued)

Reference TX <sup>3</sup> « Germanique » series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
LG7245	25 A	400 V~	left	30 mA	AC	500 A	1000 A	10000 A	10000 A
LG7246	40 A	400 V~	left	30 mA	AC	500 A	1000 A	10000 A	10000 A
LG7247	63 A	400 V~	left	30 mA	AC	630 A	1000 A	10000 A	10000 A
LG7248	80 A	400 V~	left	30 mA	AC	800 A	1000 A	10000 A	10000 A
LG7249	100 A	400 V~	left	30 mA	AC	1000 A	1000 A	10000 A	10000 A
								10000 A	10000 A
LG7250	25 A	400 V~	left	100 mA	AC	500 A	1000 A	10000 A	10000 A
LG7251	40 A	400 V~	left	100 mA	AC	500 A	1000 A	10000 A	10000 A
LG7252	63 A	400 V~	left	100 mA	AC	630 A	1000 A	10000 A	10000 A
LG7253	80 A	400 V~	left	100 mA	AC	800 A	1000 A	10000 A	10000 A
LG7254	100 A	400 V~	left	100 mA	AC	1000 A	1000 A	10000 A	10000 A
LG7255	25 A	400 V~	left	300 mA	AC	500 A	1000 A	10000 A	10000 A
LG7256	40 A	400 V~	left	300 mA	AC	500 A	1000 A	10000 A	10000 A
LG7257	63 A	400 V~	left	300 mA	AC	630 A	1000 A	10000 A	10000 A
LG7258	80 A	400 V~	left	300 mA	AC	800 A	1000 A	10000 A	10000 A
LG7259	100 A	400 V~	left	300 mA	AC	1000 A	1000 A	10000 A	10000 A
								10000 A	10000 A
LG7260	25 A	400 V~	left	500 mA	AC	500 A	1000 A	10000 A	10000 A
LG7261	40 A	400 V~	left	500 mA	AC	500 A	1000 A	10000 A	10000 A
LG7262	63 A	400 V~	left	500 mA	AC	630 A	1000 A	10000 A	10000 A
LG7263	80 A	400 V~	left	500 mA	AC	800 A	1000 A	10000 A	10000 A
LG7264	100 A	400 V~	left	500 mA	AC	1000 A	1000 A	10000 A	10000 A



LCIE – Laboratoire Central des Industries Electriques  
33, avenue du Général Leclerc – BP8  
FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)



Signature: **Jean-François BRUEL**  
Certification Officer


Date: 19/02/2019

## ANNEX (continued)

Reference TX <sup>3</sup> « Germanique » series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
LG2701	25 A	400 V~	left	30 mA	A	500 A	1000 A	10000 A	10000 A
LG2702	40 A	400 V~	left	30 mA	A	500 A	1000 A	10000 A	10000 A
LG2703	63 A	400 V~	left	30 mA	A	630 A	1000 A	10000 A	10000 A
LG2704	80 A	400 V~	left	30 mA	A	800 A	1000 A	10000 A	10000 A
LG2705	100 A	400 V~	left	30 mA	A	1000 A	1000 A	10000 A	10000 A
LG2707	25 A	400 V~	left	100 mA	A	500 A	1000 A	10000 A	10000 A
LG2708	40 A	400 V~	left	100 mA	A	500 A	1000 A	10000 A	10000 A
LG2709	63 A	400 V~	left	100 mA	A	630 A	1000 A	10000 A	10000 A
LG2710	80 A	400 V~	left	100 mA	A	800 A	1000 A	10000 A	10000 A
LG2711	100 A	400 V~	left	100 mA	A	1000 A	1000 A	10000 A	10000 A
LG2713	25 A	400 V~	left	300 mA	A	500 A	1000 A	10000 A	10000 A
LG2714	40 A	400 V~	left	300 mA	A	500 A	1000 A	10000 A	10000 A
LG2715	63 A	400 V~	left	300 mA	A	630 A	1000 A	10000 A	10000 A
LG2716	80 A	400 V~	left	300 mA	A	800 A	1000 A	10000 A	10000 A
LG2717	100 A	400 V~	left	300 mA	A	1000 A	1000 A	10000 A	10000 A
LG2719	25 A	400 V~	left	500 mA	A	500 A	1000 A	10000 A	10000 A
LG2720	40 A	400 V~	left	500 mA	A	500 A	1000 A	10000 A	10000 A
LG2721	63 A	400 V~	left	500 mA	A	630 A	1000 A	10000 A	10000 A
LG2722	80 A	400 V~	left	500 mA	A	800 A	1000 A	10000 A	10000 A
LG2723	100 A	400 V~	left	500 mA	A	1000 A	1000 A	10000 A	10000 A



LCIE – Laboratoire Central des Industries Electriques  
33, avenue du Général Leclerc – BP8  
FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)



Signature: **Jean-François BRUEL**  
Certification Officer


Date: 19/02/2019

## ANNEX (continued)

Reference TX <sup>3</sup> « Germanique » series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
LG7265	25 A	400 V~	left	100 mA	AC-S	500 A	1000 A	10000 A	10000 A
LG7266	40 A	400 V~	left	100 mA	AC-S	500 A	1000 A	10000 A	10000 A
LG7267	63 A	400 V~	left	100 mA	AC-S	630 A	1000 A	10000 A	10000 A
LG7268	80 A	400 V~	left	100 mA	AC-S	800 A	1000 A	10000 A	10000 A
LG7269	100 A	400 V~	left	100 mA	AC-S	1000 A	1000 A	10000 A	10000 A
LG7270	25 A	400 V~	left	300 mA	AC-S	500 A	1000 A	10000 A	10000 A
LG7271	40 A	400 V~	left	300 mA	AC-S	500 A	1000 A	10000 A	10000 A
LG7272	63 A	400 V~	left	300 mA	AC-S	630 A	1000 A	10000 A	10000 A
LG7273	80 A	400 V~	left	300 mA	AC-S	800 A	1000 A	10000 A	10000 A
LG7274	100 A	400 V~	left	300 mA	AC-S	1000 A	1000 A	10000 A	10000 A
LG7275	25 A	400 V~	left	500 mA	AC-S	500 A	1000 A	10000 A	10000 A
LG7276	40 A	400 V~	left	500 mA	AC-S	500 A	1000 A	10000 A	10000 A
LG7277	63 A	400 V~	left	500 mA	AC-S	630 A	1000 A	10000 A	10000 A
LG7278	80 A	400 V~	left	500 mA	AC-S	800 A	1000 A	10000 A	10000 A
LG7279	100 A	400 V~	left	500 mA	AC-S	1000 A	1000 A	10000 A	10000 A
Reference TX <sup>3</sup> « Germanique » series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
LG7295	25 A	220/380 V~	left	30 mA	AC	500 A	1000 A	10000 A	10000 A
LG7296	40 A	220/380 V~	left	30 mA	AC	500 A	1000 A	10000 A	10000 A
LG7297	63 A	220/380 V~	left	30 mA	AC	630 A	1000 A	10000 A	10000 A
LG7298	80 A	220/380 V~	left	30 mA	AC	800 A	1000 A	10000 A	10000 A
LG7299	100 A	220/380 V~	left	30 mA	AC	1000 A	1000 A	10000 A	10000 A
LG7300	25 A	220/380 V~	left	300 mA	AC	500 A	1000 A	10000 A	10000 A
LG7301	40 A	220/380V~	left	300 mA	AC	500 A	1000 A	10000 A	10000 A
LG7302	63 A	220/380 V~	left	300 mA	AC	630 A	1000 A	10000 A	10000 A
LG7303	80 A	220/380 V~	left	300 mA	AC	800 A	1000 A	10000 A	10000 A
LG7304	100 A	220/380 V~	left	300 mA	AC	1000 A	1000 A	10000 A	10000 A



LCIE – Laboratoire Central des Industries Electriques  
33, avenue du Général Leclerc – BP8  
FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)



Date: 19/02/2019

Signature: **Jean-François BRUEL**  
Certification Officer




## ANNEX (continued)

Reference TX <sup>3</sup> « Germanique » series	In	Un	Neutral position	IΔn	Type	I <sub>m</sub>	IΔm	I <sub>nc</sub>	IΔc
LG7305	25 A	220/380 V~	left	30 mA	A	500 A	1000 A	10000 A	10000 A
LG7306	40 A	220/380 V~	left	30 mA	A	500 A	1000 A	10000 A	10000 A
LG7307	63 A	220/380 V~	left	30 mA	A	630 A	1000 A	10000 A	10000 A
LG7308	80 A	220/380 V~	left	30 mA	A	800 A	1000 A	10000 A	10000 A
LG7309	100 A	220/380 V~	left	30 mA	A	1000 A	1000 A	10000 A	10000 A
LG7310	25 A	220/380 V~	left	300 mA	A	500 A	1000 A	10000 A	10000 A
LG7311	40 A	220/380 V~	left	300 mA	A	500 A	1000 A	10000 A	10000 A
LG7312	63 A	220/380 V~	left	300 mA	A	630 A	1000 A	10000 A	10000 A
LG7313	80 A	220/380 V~	left	300 mA	A	800 A	1000 A	10000 A	10000 A
LG7314	100 A	220/380 V~	left	300 mA	A	1000 A	1000 A	10000 A	10000 A

Products dedicated to Brazilian and Mexican market (voltage 220/380V)



LCIE – Laboratoire Central des Industries Electriques  
33, avenue du Général Leclerc – BP8  
FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)



Date: 19/02/2019


Signature: **Jean-François BRUEL**  
Certification Officer

## ANNEX (continued)

Reference TX <sup>3</sup> « Latin » series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
4030 08	25 A	400 V~	right	30 mA	AC	500 A	1000 A	10000 A	10000 A
4030 09	40 A	400 V~	right	30 mA	AC	500 A	1000 A	10000 A	10000 A
4030 10	63 A	400 V~	right	30 mA	AC	630 A	1000 A	10000 A	10000 A
LG1266	80 A	400 V~	right	30 mA	AC	800 A	1000 A	10000 A	10000 A
LG1267	100 A	400 V~	right	30 mA	AC	1000 A	1000 A	10000 A	10000 A
LG2621	25 A	400 V~	right	100 mA	AC	500 A	1000 A	10000 A	10000 A
LG2622	40 A	400 V~	right	100 mA	AC	500 A	1000 A	10000 A	10000 A
LG2623	63 A	400 V~	right	100 mA	AC	630 A	1000 A	10000 A	10000 A
LG2624	80 A	400 V~	right	100 mA	AC	800 A	1000 A	10000 A	10000 A
LG2625	100 A	400 V~	right	100 mA	AC	1000 A	1000 A	10000 A	10000 A
4030 42	25 A	400 V~	right	300 mA	AC	500 A	1000 A	10000 A	10000 A
4030 43	40 A	400 V~	right	300 mA	AC	500 A	1000 A	10000 A	10000 A
4030 44	63 A	400 V~	right	300 mA	AC	630 A	1000 A	10000 A	10000 A
LG2627	80 A	400 V~	right	300 mA	AC	800 A	1000 A	10000 A	10000 A
LG2628	100 A	400 V~	right	300 mA	AC	1000 A	1000 A	10000 A	10000 A
LG2630	25 A	400 V~	right	500 mA	AC	500 A	1000 A	10000 A	10000 A
LG2631	40 A	400 V~	right	500 mA	AC	500 A	1000 A	10000 A	10000 A
LG2632	63 A	400 V~	right	500 mA	AC	630 A	1000 A	10000 A	10000 A
LG2633	80 A	400 V~	right	500 mA	AC	800 A	1000 A	10000 A	10000 A
LG2634	100 A	400 V~	right	500 mA	AC	1000 A	1000 A	10000 A	10000 A



LCIE – Laboratoire Central des Industries Electriques  
33, avenue du Général Leclerc – BP8  
FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)



Signature: **Jean-François BRUEL**  
Certification Officer


Date: 19/02/2019

## ANNEX (continued)

Reference TX <sup>3</sup> « Latin » series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
LG1260	25 A	400 V~	right	30 mA	A	500 A	1000 A	10000 A	10000 A
LG1261	40 A	400 V~	right	30 mA	A	500 A	1000 A	10000 A	10000 A
LG1262	63 A	400 V~	right	30 mA	A	630 A	1000 A	10000 A	10000 A
LG1263	80 A	400 V~	right	30 mA	A	800 A	1000 A	10000 A	10000 A
LG1264	100 A	400 V~	right	30 mA	A	1000 A	1000 A	10000 A	10000 A
LG2637	25 A	400 V~	right	100 mA	A	500 A	1000 A	10000 A	10000 A
LG2638	40 A	400 V~	right	100 mA	A	500 A	1000 A	10000 A	10000 A
LG2639	63 A	400 V~	right	100 mA	A	630 A	1000 A	10000 A	10000 A
LG2640	80 A	400 V~	right	100 mA	A	800 A	1000 A	10000 A	10000 A
LG2641	100 A	400 V~	right	100 mA	A	1000 A	1000 A	10000 A	10000 A
LG2643	25 A	400 V~	right	300 mA	A	500 A	1000 A	10000 A	10000 A
LG2644	40 A	400 V~	right	300 mA	A	500 A	1000 A	10000 A	10000 A
LG2645	63 A	400 V~	right	300 mA	A	630 A	1000 A	10000 A	10000 A
LG2646	80 A	400 V~	right	300 mA	A	800 A	1000 A	10000 A	10000 A
LG2647	100 A	400 V~	right	300 mA	A	1000 A	1000 A	10000 A	10000 A
LG2649	25 A	400 V~	right	500 mA	A	500 A	1000 A	10000 A	10000 A
LG2650	40 A	400 V~	right	500 mA	A	500 A	1000 A	10000 A	10000 A
LG2651	63 A	400 V~	right	500 mA	A	630 A	1000 A	10000 A	10000 A
LG2652	80 A	400 V~	right	500 mA	A	800 A	1000 A	10000 A	10000 A
LG2653	100 A	400 V~	right	500 mA	A	1000 A	1000 A	10000 A	10000 A



LCIE – Laboratoire Central des Industries Electriques  
33, avenue du Général Leclerc – BP8  
FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)



Date: 19/02/2019


Signature: **Jean-François BRUEL**  
Certification Officer

## ANNEX (continued)

Reference TX <sup>3</sup> « Latin » series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
4030 04	25 A	400 V~	left	30 mA	AC	500 A	1000 A	10000 A	10000 A
4030 05	40 A	400 V~	left	30 mA	AC	500 A	1000 A	10000 A	10000 A
4030 06	63 A	400 V~	left	30 mA	AC	630 A	1000 A	10000 A	10000 A
LG1268	80 A	400 V~	left	30 mA	AC	800 A	1000 A	10000 A	10000 A
LG1269	100 A	400 V~	left	30 mA	AC	1000 A	1000 A	10000 A	10000 A
LG2602	25 A	400 V~	left	100 mA	AC	500 A	1000 A	10000 A	10000 A
LG2603	40 A	400 V~	left	100 mA	AC	500 A	1000 A	10000 A	10000 A
LG2604	63 A	400 V~	left	100 mA	AC	630 A	1000 A	10000 A	10000 A
LG2605	80 A	400 V~	left	100 mA	AC	800 A	1000 A	10000 A	10000 A
LG2606	100 A	400 V~	left	100 mA	AC	1000 A	1000 A	10000 A	10000 A
LG2608	25 A	400 V~	left	300 mA	AC	500 A	1000 A	10000 A	10000 A
LG2609	40 A	400 V~	left	300 mA	AC	500 A	1000 A	10000 A	10000 A
LG2610	63 A	400 V~	left	300 mA	AC	630 A	1000 A	10000 A	10000 A
LG2611	80 A	400 V~	left	300 mA	AC	800 A	1000 A	10000 A	10000 A
LG2612	100 A	400 V~	left	300 mA	AC	1000 A	1000 A	10000 A	10000 A
LG2614	25 A	400 V~	left	500 mA	AC	500 A	1000 A	10000 A	10000 A
LG2615	40 A	400 V~	left	500 mA	AC	500 A	1000 A	10000 A	10000 A
LG2616	63 A	400 V~	left	500 mA	AC	630 A	1000 A	10000 A	10000 A
LG2617	80 A	400 V~	left	500 mA	AC	800 A	1000 A	10000 A	10000 A
LG2618	100 A	400 V~	left	500 mA	AC	1000 A	1000 A	10000 A	10000 A



LCIE – Laboratoire Central des Industries Electriques  
33, avenue du Général Leclerc – BP8  
FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)



Date: 19/02/2019

Signature: **Jean-François BRUEL**  
Certification Officer

## ANNEX (continued)

Reference XC <sup>3</sup> series	I <sub>n</sub>	U <sub>n</sub>	Neutral position	I $\Delta$ <sub>n</sub>	Type	I <sub>m</sub>	I $\Delta$ <sub>m</sub>	I <sub>nc</sub>	I $\Delta$ <sub>c</sub>
4031 90	25 A	400 V~	left	30 mA	AC	500 A	1000 A	10000 A	10000 A
4031 91	40 A	400 V~	left	30 mA	AC	500 A	1000 A	10000 A	10000 A
4031 92	63 A	400 V~	left	30 mA	AC	630 A	1000 A	10000 A	10000 A
4031 93	80 A	400 V~	left	30 mA	AC	800 A	1000 A	10000 A	10000 A
4031 94	25 A	400 V~	left	300 mA	AC	500 A	1000 A	10000 A	10000 A
4031 95	40 A	400 V~	left	300 mA	AC	500 A	1000 A	10000 A	10000 A
4031 96	63 A	400 V~	left	300 mA	AC	630 A	1000 A	10000 A	10000 A
4031 97	80 A	400 V~	left	300 mA	AC	800 A	1000 A	10000 A	10000 A
Reference XC <sup>3</sup> series	I <sub>n</sub>	U <sub>n</sub>	Neutral position	I $\Delta$ <sub>n</sub>	Type	I <sub>m</sub>	I $\Delta$ <sub>m</sub>	I <sub>nc</sub>	I $\Delta$ <sub>c</sub>
4032 32	25 A	400 V~	left	30 mA	A	500 A	1000 A	10000 A	10000 A
4032 33	40 A	400 V~	left	30 mA	A	500 A	1000 A	10000 A	10000 A
4032 34	63 A	400 V~	left	30 mA	A	630 A	1000 A	10000 A	10000 A
4032 35	80 A	400 V~	left	30 mA	A	800 A	1000 A	10000 A	10000 A
4032 36	25 A	400 V~	left	300 mA	A	500 A	1000 A	10000 A	10000 A
4032 37	40 A	400 V~	left	300 mA	A	500 A	1000 A	10000 A	10000 A
4032 38	63 A	400 V~	left	300 mA	A	630 A	1000 A	10000 A	10000 A
4032 39	80 A	400 V~	left	300 mA	A	800 A	1000 A	10000 A	10000 A

RCCB's XC<sup>3</sup> dedicated to Turkish market.



LCIE – Laboratoire Central des Industries Electriques  
33, avenue du Général Leclerc – BP8  
FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)



Date: 19/02/2019


Signature: **Jean-François BRUEL**  
Certification Officer

## ANNEX (continued)

Reference RX <sup>3</sup> series	I <sub>n</sub>	U <sub>n</sub>	Neutral position	I $\Delta$ n	Type	I <sub>m</sub>	I $\Delta$ m	I <sub>nc</sub>	I $\Delta$ c
4020 62	25 A	400 V~	right	30 mA	AC	500 A	1000 A	10000 A	10000 A
4020 63	40 A	400 V~	right	30 mA	AC	500 A	1000 A	10000 A	10000 A
4020 64	63 A	400 V~	right	30 mA	AC	630 A	1000 A	10000 A	10000 A
LG1282	80 A	400 V~	right	30 mA	AC	800 A	1000 A	10000 A	10000 A
LG1283	100 A	400 V~	right	30 mA	AC	1000 A	1000 A	10000 A	10000 A
4020 66	25 A	400 V~	right	100 mA	AC	500 A	1000 A	10000 A	10000 A
4020 67	40 A	400 V~	right	100 mA	AC	500 A	1000 A	10000 A	10000 A
4020 68	63 A	400 V~	right	100 mA	AC	630 A	1000 A	10000 A	10000 A
LG1284	80 A	400 V~	right	100 mA	AC	800 A	1000 A	10000 A	10000 A
LG1285	100 A	400 V~	right	100 mA	AC	1000 A	1000 A	10000 A	10000 A
4020 70	25 A	400 V~	right	300 mA	AC	500 A	1000 A	10000 A	10000 A
4020 71	40 A	400 V~	right	300 mA	AC	500 A	1000 A	10000 A	10000 A
4020 72	63 A	400 V~	right	300 mA	AC	630 A	1000 A	10000 A	10000 A
LG1286	80 A	400 V~	right	300 mA	AC	800 A	1000 A	10000 A	10000 A
LG1287	100 A	400 V~	right	300 mA	AC	1000 A	1000 A	10000 A	10000 A
LG2804	25 A	400 V~	right	500 mA	AC	500 A	1000 A	10000 A	10000 A
LG2805	40 A	400 V~	right	500 mA	AC	500 A	1000 A	10000 A	10000 A
LG2806	63 A	400 V~	right	500 mA	AC	630 A	1000 A	10000 A	10000 A
LG2807	80 A	400 V~	right	500 mA	AC	800 A	1000 A	10000 A	10000 A
LG2808	100 A	400 V~	right	500 mA	AC	1000 A	1000 A	10000 A	10000 A



LCIE – Laboratoire Central des Industries Electriques  
33, avenue du Général Leclerc – BP8  
FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)



Date: 19/02/2019

Signature: **Jean-François BRUEL**  
Certification Officer

## ANNEX (continued)

Reference RX <sup>3</sup> series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
4020 74	25 A	400 V~	right	30 mA	A	500 A	1000 A	10000 A	10000 A
4020 75 4025 39 (4)	40 A	400 V~	right	30 mA	A	500 A	1000 A	10000 A	10000 A
4020 76 4025 40 (4)	63 A	400 V~	right	30 mA	A	630 A	1000 A	10000 A	10000 A
LG1270	80 A	400 V~	right	30 mA	A	800 A	1000 A	10000 A	10000 A
LG1271	100 A	400 V~	right	30 mA	A	1000 A	1000 A	10000 A	10000 A
LG1272	25 A	400 V~	right	100 mA	A	500 A	1000 A	10000 A	10000 A
LG1273	40 A	400 V~	right	100 mA	A	500 A	1000 A	10000 A	10000 A
LG1274	63 A	400 V~	right	100 mA	A	630 A	1000 A	10000 A	10000 A
LG1275	80 A	400 V~	right	100 mA	A	800 A	1000 A	10000 A	10000 A
LG1276	100 A	400 V~	right	100 mA	A	1000 A	1000 A	10000 A	10000 A
LG1277	25 A	400 V~	right	300 mA	A	500 A	1000 A	10000 A	10000 A
LG1278 4025 41 (4)	40 A	400 V~	right	300 mA	A	500 A	1000 A	10000 A	10000 A
LG1279 4025 42 (4)	63 A	400 V~	right	300 mA	A	630 A	1000 A	10000 A	10000 A
LG1280	80 A	400 V~	right	300 mA	A	800 A	1000 A	10000 A	10000 A
LG1281	100 A	400 V~	right	300 mA	A	1000 A	1000 A	10000 A	10000 A
LG2814	25 A	400 V~	right	500 mA	A	500 A	1000 A	10000 A	10000 A
LG2815	40 A	400 V~	right	500 mA	A	500 A	1000 A	10000 A	10000 A
LG2816	63 A	400 V~	right	500 mA	A	630 A	1000 A	10000 A	10000 A
LG2817	80 A	400 V~	right	500 mA	A	800 A	1000 A	10000 A	10000 A
LG2818	100 A	400 V~	right	500 mA	A	1000 A	1000 A	10000 A	10000 A

(4) RCCB's dedicated to Belgium market


Reference RX <sup>3</sup> series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
4020 90	25 A	220/380 V~	left	30 mA	AC	500 A	1000 A	10000 A	10000 A
4020 91	40 A	220/380 V~	left	30 mA	AC	500 A	1000 A	10000 A	10000 A
4020 92	63 A	220/380 V~	left	30 mA	AC	630 A	1000 A	10000 A	10000 A
LG1288	80 A	220/380 V~	left	30 mA	AC	800 A	1000 A	10000 A	10000 A
LG1289	100 A	220/380 V~	left	30 mA	AC	1000 A	1000 A	10000 A	10000 A

Products dedicated to Brazilian and Mexican market (voltage 220/380V)

## ANNEX (continued)



LCIE – Laboratoire Central des Industries Electriques  
33, avenue du Général Leclerc – BP8  
FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)




Date: 19/02/2019

Signature: **Jean-François BRUEL**  
Certification Officer

Reference DX <sup>3</sup> series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
4117 02	25 A	400 V~	right	30 mA	AC	500 A	1000 A	10000 A	10000 A
4117 03	40 A	400 V~	right	30 mA	AC	500 A	1000 A	10000 A	10000 A
4117 04	63 A	400 V~	right	30 mA	AC	630 A	1000 A	10000 A	10000 A
4117 05	80 A	400 V~	right	30 mA	AC	800 A	1000 A	10000 A	10000 A
LG992	100 A	400 V~	right	30 mA	AC	1000 A	1000 A	10000 A	10000 A
4117 12	25 A	400 V~	right	100 mA	AC	500 A	1000 A	10000 A	10000 A
4117 13	40 A	400 V~	right	100 mA	AC	500 A	1000 A	10000 A	10000 A
4117 14	63 A	400 V~	right	100 mA	AC	630 A	1000 A	10000 A	10000 A
4117 15	80 A	400 V~	right	100 mA	AC	800 A	1000 A	10000 A	10000 A
LG993	100 A	400 V~	right	100 mA	AC	1000 A	1000 A	10000 A	10000 A
4117 22	25 A	400 V~	right	300 mA	AC	500 A	1000 A	10000 A	10000 A
4117 23	40 A	400 V~	right	300 mA	AC	500 A	1000 A	10000 A	10000 A
4117 24	63 A	400 V~	right	300 mA	AC	630 A	1000 A	10000 A	10000 A
4117 25	80 A	400 V~	right	300 mA	AC	800 A	1000 A	10000 A	10000 A
LG994	100 A	400 V~	right	300 mA	AC	1000 A	1000 A	10000 A	10000 A
4117 32	25 A	400 V~	right	500 mA	AC	500 A	1000 A	10000 A	10000 A
4117 33	40 A	400 V~	right	500 mA	AC	500 A	1000 A	10000 A	10000 A
4117 34	63 A	400 V~	right	500 mA	AC	630 A	1000 A	10000 A	10000 A
4117 35	80 A	400 V~	right	500 mA	AC	800 A	1000 A	10000 A	10000 A
LG995	100 A	400 V~	right	500 mA	AC	1000 A	1000 A	10000 A	10000 A



LCIE – Laboratoire Central des Industries Electriques  
33, avenue du Général Leclerc – BP8  
FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)



Date: 19/02/2019

Signature: **Jean-François BRUEL**  
Certification Officer




## ANNEX (continued)

Reference DX <sup>3</sup> series	In	Un	Neutral position	IΔn	Type	I <sub>m</sub>	IΔm	I <sub>nc</sub>	IΔc
4117 59	25 A	400 V~	right	30 mA	A	500 A	1000 A	10000 A	10000 A
4117 60	40 A	400 V~	right	30 mA	A	500 A	1000 A	10000 A	10000 A
4117 61	63 A	400 V~	right	30 mA	A	630 A	1000 A	10000 A	10000 A
4117 62	80 A	400 V~	right	30 mA	A	800 A	1000 A	10000 A	10000 A
4117 63	100 A	400 V~	right	30 mA	A	1000 A	1000 A	10000 A	10000 A
4117 69	25 A	400 V~	right	100 mA	A	500 A	1000 A	10000 A	10000 A
4117 70	40 A	400 V~	right	100 mA	A	500 A	1000 A	10000 A	10000 A
4117 71	63 A	400 V~	right	100 mA	A	630 A	1000 A	10000 A	10000 A
4117 72	80 A	400 V~	right	100 mA	A	800 A	1000 A	10000 A	10000 A
4117 73	100 A	400 V~	right	100 mA	A	1000 A	1000 A	10000 A	10000 A
4117 79	25 A	400 V~	right	300 mA	A	500 A	1000 A	10000 A	10000 A
4117 80	40 A	400 V~	right	300 mA	A	500 A	1000 A	10000 A	10000 A
4117 81	63 A	400 V~	right	300 mA	A	630 A	1000 A	10000 A	10000 A
4117 82	80 A	400 V~	right	300 mA	A	800 A	1000 A	10000 A	10000 A
4117 83	100 A	400 V~	right	300 mA	A	1000 A	1000 A	10000 A	10000 A
4117 89	25 A	400 V~	right	500 mA	A	500 A	1000 A	10000 A	10000 A
4117 90	40 A	400 V~	right	500 mA	A	500 A	1000 A	10000 A	10000 A
4117 91	63 A	400 V~	right	500 mA	A	630 A	1000 A	10000 A	10000 A
4117 92	80 A	400 V~	right	500 mA	A	800 A	1000 A	10000 A	10000 A
4117 93	100 A	400 V~	right	500 mA	A	1000 A	1000 A	10000 A	10000 A



LCIE – Laboratoire Central des Industries Electriques  
33, avenue du Général Leclerc – BP8  
FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)



Date: 19/02/2019


Signature: **Jean-François BRUEL**  
Certification Officer

## ANNEX (continued)

Reference DX <sup>3</sup> series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
LG1118	25 A	400 V~	right	100 mA	AC-S	500 A	1000 A	10000 A	10000 A
LG996	40 A	400 V~	right	100 mA	AC-S	500 A	1000 A	10000 A	10000 A
LG997	63 A	400 V~	right	100 mA	AC-S	630 A	1000 A	10000 A	10000 A
LG1119	80 A	400 V~	right	100 mA	AC-S	800 A	1000 A	10000 A	10000 A
LG1120	100 A	400 V~	right	100 mA	AC-S	1000 A	1000 A	10000 A	10000 A
LG1121	25 A	400 V~	right	300 mA	AC-S	500 A	1000 A	10000 A	10000 A
4117 45	40 A	400 V~	right	300 mA	AC-S	500 A	1000 A	10000 A	10000 A
4117 46	63 A	400 V~	right	300 mA	AC-S	630 A	1000 A	10000 A	10000 A
LG1122	80 A	400 V~	right	300 mA	AC-S	800 A	1000 A	10000 A	10000 A
LG1123	100 A	400 V~	right	300 mA	AC-S	1000 A	1000 A	10000 A	10000 A
LG1124	25 A	400 V~	right	500 mA	AC-S	500 A	1000 A	10000 A	10000 A
LG1125	40 A	400 V~	right	500 mA	AC-S	500 A	1000 A	10000 A	10000 A
LG1126	63 A	400 V~	right	500 mA	AC-S	630 A	1000 A	10000 A	10000 A
LG1127	80 A	400 V~	right	500 mA	AC-S	800 A	1000 A	10000 A	10000 A
LG1128	100 A	400 V~	right	500 mA	AC-S	1000 A	1000 A	10000 A	10000 A
Reference DX <sup>3</sup> series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
LG1031	25 A	400 V~	right	100 mA	A-S	500 A	1000 A	10000 A	10000 A
LG1032	40 A	400 V~	right	100 mA	A-S	500 A	1000 A	10000 A	10000 A
LG1033	63 A	400 V~	right	100 mA	A-S	630 A	1000 A	10000 A	10000 A
LG1034	80 A	400 V~	right	100 mA	A-S	800 A	1000 A	10000 A	10000 A
LG1035	100 A	400 V~	right	100 mA	A-S	1000 A	1000 A	10000 A	10000 A
LG998	25 A	400 V~	right	300 mA	A-S	500 A	1000 A	10000 A	10000 A
4118 00	40 A	400 V~	right	300 mA	A-S	500 A	1000 A	10000 A	10000 A
4118 01	63 A	400 V~	right	300 mA	A-S	630 A	1000 A	10000 A	10000 A
LG999	80 A	400 V~	right	300 mA	A-S	800 A	1000 A	10000 A	10000 A
LG1000	100 A	400 V~	right	300 mA	A-S	1000 A	1000 A	10000 A	10000 A
LG1001	25 A	400 V~	right	500 mA	A-S	500 A	1000 A	10000 A	10000 A
LG1002	40 A	400 V~	right	500 mA	A-S	500 A	1000 A	10000 A	10000 A
LG1003	63 A	400 V~	right	500 mA	A-S	630 A	1000 A	10000 A	10000 A
LG1004	80 A	400 V~	right	500 mA	A-S	800 A	1000 A	10000 A	10000 A
LG1005	100 A	400 V~	right	500 mA	A-S	1000 A	1000 A	10000 A	10000 A



LCIE – Laboratoire Central des Industries Electriques  
33, avenue du Général Leclerc – BP8  
FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)



Date: 19/02/2019

Signature: **Jean-François BRUEL**  
Certification Officer


## ANNEX (continued)

Reference DX <sup>3</sup> series	I <sub>n</sub>	U <sub>n</sub>	Neutral position	I $\Delta$ n	Type	I <sub>m</sub>	I $\Delta$ m	I <sub>nc</sub>	I $\Delta$ c
LG3181	25 A	400 V~	right	30 mA	AC*	500 A	1000 A	10000 A	10000 A
LG3182	40 A	400 V~	right	30 mA	AC*	500 A	1000 A	10000 A	10000 A
LG3183	63 A	400 V~	right	30 mA	AC*	630 A	1000 A	10000 A	10000 A
LG3184	80 A	400 V~	right	30 mA	AC*	800 A	1000 A	10000 A	10000 A
LG3185	100 A	400 V~	right	30 mA	AC*	1000 A	1000 A	10000 A	10000 A
LG3187	25 A	400 V~	right	100 mA	AC*	500 A	1000 A	10000 A	10000 A
LG3188	40 A	400 V~	right	100 mA	AC*	500 A	1000 A	10000 A	10000 A
LG3189	63 A	400 V~	right	100 mA	AC*	630 A	1000 A	10000 A	10000 A
LG3190	80 A	400 V~	right	100 mA	AC*	800 A	1000 A	10000 A	10000 A
LG3191	100 A	400 V~	right	100 mA	AC*	1000 A	1000 A	10000 A	10000 A
LG3193	25 A	400 V~	right	300 mA	AC*	500 A	1000 A	10000 A	10000 A
LG3194	40 A	400 V~	right	300 mA	AC*	500 A	1000 A	10000 A	10000 A
LG3195	63 A	400 V~	right	300 mA	AC*	630 A	1000 A	10000 A	10000 A
LG3196	80 A	400 V~	right	300 mA	AC*	800 A	1000 A	10000 A	10000 A
LG3197	100 A	400 V~	right	300 mA	AC*	1000 A	1000 A	10000 A	10000 A

\* RCCB's dedicated to Austria market



LCIE – Laboratoire Central des Industries Electriques  
33, avenue du Général Leclerc – BP8  
FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)



Signature: **Jean-François BRUEL**  
Certification Officer


Date: 19/02/2019

## ANNEX (continued)

Reference DX <sup>3</sup> series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
4116 60	25 A	400 V~	left	30 mA	AC	500 A	1000 A	10000 A	10000 A
4116 61	40 A	400 V~	left	30 mA	AC	500 A	1000 A	10000 A	10000 A
4116 62	63 A	400 V~	left	30 mA	AC	630 A	1000 A	10000 A	10000 A
4116 63	80 A	400 V~	left	30 mA	AC	800 A	1000 A	10000 A	10000 A
LG1021	100 A	400 V~	left	30 mA	AC	1000 A	1000 A	10000 A	10000 A
LG3102	25 A	400 V~	left	100 mA	AC	500 A	1000 A	10000 A	10000 A
LG3103	40 A	400 V~	left	100 mA	AC	500 A	1000 A	10000 A	10000 A
LG3104	63 A	400 V~	left	100 mA	AC	630 A	1000 A	10000 A	10000 A
LG3105	80 A	400 V~	left	100 mA	AC	800 A	1000 A	10000 A	10000 A
LG3106	100 A	400 V~	left	100 mA	AC	1000 A	1000 A	10000 A	10000 A
4116 64	25 A	400 V~	left	300 mA	AC	500 A	1000 A	10000 A	10000 A
4116 65	40 A	400 V~	left	300 mA	AC	500 A	1000 A	10000 A	10000 A
4116 66	63 A	400 V~	left	300 mA	AC	630 A	1000 A	10000 A	10000 A
4116 67	80 A	400 V~	left	300 mA	AC	800 A	1000 A	10000 A	10000 A
LG1022	100 A	400 V~	left	300 mA	AC	1000 A	1000 A	10000 A	10000 A
LG3109	25 A	400 V~	left	500 mA	AC	500 A	1000 A	10000 A	10000 A
LG3110	40 A	400 V~	left	500 mA	AC	500 A	1000 A	10000 A	10000 A
LG3111	63 A	400 V~	left	500 mA	AC	630 A	1000 A	10000 A	10000 A
LG3112	80 A	400 V~	left	500 mA	AC	800 A	1000 A	10000 A	10000 A
LG3113	100 A	400 V~	left	500 mA	AC	1000 A	1000 A	10000 A	10000 A



LCIE – Laboratoire Central des Industries Electriques  
33, avenue du Général Leclerc – BP8  
FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)



Date: 19/02/2019

Signature: **Jean-François BRUEL**  
Certification Officer

## ANNEX (continued)

Reference DX <sup>3</sup> series	In	Un	Neutral position	IΔn	Type	I <sub>m</sub>	IΔm	I <sub>nc</sub>	IΔc
4116 74	25 A	400 V~	left	30 mA	A	500 A	1000 A	10000 A	10000 A
4116 75	40 A	400 V~	left	30 mA	A	500 A	1000 A	10000 A	10000 A
4116 76	63 A	400 V~	left	30 mA	A	630 A	1000 A	10000 A	10000 A
4116 77	80 A	400 V~	left	30 mA	A	800 A	1000 A	10000 A	10000 A
4116 78	100 A	400 V~	left	30 mA	A	1000 A	1000 A	10000 A	10000 A
LG3129	25 A	400 V~	left	100 mA	A	500 A	1000 A	10000 A	10000 A
LG3130	40 A	400 V~	left	100 mA	A	500 A	1000 A	10000 A	10000 A
LG3131	63 A	400 V~	left	100 mA	A	630 A	1000 A	10000 A	10000 A
LG3132	80 A	400 V~	left	100 mA	A	800 A	1000 A	10000 A	10000 A
LG3133	100 A	400 V~	left	100 mA	A	1000 A	1000 A	10000 A	10000 A
								10000 A	10000 A
4116 84	25 A	400 V~	left	300 mA	A	500 A	1000 A	10000 A	10000 A
4116 85	40 A	400 V~	left	300 mA	A	500 A	1000 A	10000 A	10000 A
4116 86	63 A	400 V~	left	300 mA	A	630 A	1000 A	10000 A	10000 A
4116 87	80 A	400 V~	left	300 mA	A	800 A	1000 A	10000 A	10000 A
4116 88	100 A	400 V~	left	300 mA	A	1000 A	1000 A	10000 A	10000 A
LG3136	25 A	400 V~	left	500 mA	A	500 A	1000 A	10000 A	10000 A
LG3137	40 A	400 V~	left	500 mA	A	500 A	1000 A	10000 A	10000 A
LG3138	63 A	400 V~	left	500 mA	A	630 A	1000 A	10000 A	10000 A
LG3139	80 A	400 V~	left	500 mA	A	800 A	1000 A	10000 A	10000 A
LG3140	100 A	400 V~	left	500 mA	A	1000 A	1000 A	10000 A	10000 A



LCIE – Laboratoire Central des Industries Electriques  
33, avenue du Général Leclerc – BP8  
FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)



Date: 19/02/2019


Signature: **Jean-François BRUEL**  
Certification Officer

## ANNEX (continued)

Reference DX <sup>3</sup> series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
LG3115	25 A	400 V~	left	100 mA	AC-S	500 A	1000 A	10000 A	10000 A
LG3116	40 A	400 V~	left	100 mA	AC-S	500 A	1000 A	10000 A	10000 A
LG3117	63 A	400 V~	left	100 mA	AC-S	630 A	1000 A	10000 A	10000 A
LG3118	80 A	400 V~	left	100 mA	AC-S	800 A	1000 A	10000 A	10000 A
LG3119	100 A	400 V~	left	100 mA	AC-S	1000 A	1000 A	10000 A	10000 A
LG1129	25 A	400 V~	left	300 mA	AC-S	500 A	1000 A	10000 A	10000 A
4116 68	40 A	400 V~	left	300 mA	AC-S	500 A	1000 A	10000 A	10000 A
4116 69	63 A	400 V~	left	300 mA	AC-S	630 A	1000 A	10000 A	10000 A
LG1130	80 A	400 V~	left	300 mA	AC-S	800 A	1000 A	10000 A	10000 A
LG1131	100 A	400 V~	left	300 mA	AC-S	1000 A	1000 A	10000 A	10000 A
LG3122	25 A	400 V~	left	500 mA	AC-S	500 A	1000 A	10000 A	10000 A
LG3123	40 A	400 V~	left	500 mA	AC-S	500 A	1000 A	10000 A	10000 A
LG3124	63 A	400 V~	left	500 mA	AC-S	630 A	1000 A	10000 A	10000 A
LG3125	80 A	400 V~	left	500 mA	AC-S	800 A	1000 A	10000 A	10000 A
LG3126	100 A	400 V~	left	500 mA	AC-S	1000 A	1000 A	10000 A	10000 A
Reference DX <sup>3</sup> series	In	Un	Neutral position	IΔn	Type	Im	IΔm	Inc	IΔc
LG3252	25 A	220/380 V~	left	30 mA	AC	500 A	1000 A	10000 A	10000 A
LG3253	40 A	220/380 V~	left	30 mA	AC	500 A	1000 A	10000 A	10000 A
LG3254	63 A	220/380 V~	left	30 mA	AC	630 A	1000 A	10000 A	10000 A
LG3255	80 A	220/380 V~	left	30 mA	AC	800 A	1000 A	10000 A	10000 A
LG3256	100 A	220/380 V~	left	30 mA	AC	1000 A	1000 A	10000 A	10000 A
LG3258	25 A	220/380 V~	left	300 mA	AC	500 A	1000 A	10000 A	10000 A
LG3259	40 A	220/380 V~	left	300 mA	AC	500 A	1000 A	10000 A	10000 A
LG3260	63 A	220/380 V~	left	300 mA	AC	630 A	1000 A	10000 A	10000 A
LG3261	80 A	220/380 V~	left	300 mA	AC	800 A	1000 A	10000 A	10000 A
LG3262	100 A	220/380 V~	left	300 mA	AC	1000 A	1000 A	10000 A	10000 A



LCIE – Laboratoire Central des Industries Electriques  
33, avenue du Général Leclerc – BP8  
FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)



Signature: **Jean-François BRUEL**  
Certification Officer

Date: 19/02/2019

## ANNEX (end)


Reference DX <sup>3</sup> series	In	Un	Neutral position	I $\Delta$ n	Type	Im	I $\Delta$ m	Inc	I $\Delta$ c
4118 32	25 A	220/380 V~	left	30 mA	A	500 A	1000 A	10000 A	10000 A
4118 33	40 A	220/380 V~	left	30 mA	A	500 A	1000 A	10000 A	10000 A
4118 34	63 A	220/380 V~	left	30 mA	A	630 A	1000 A	10000 A	10000 A
4118 35	80 A	220/380 V~	left	30 mA	A	800 A	1000 A	10000 A	10000 A
4118 36	100 A	220/380 V~	left	30 mA	A	1000 A	1000 A	10000 A	10000 A
4118 37	25 A	220/380 V~	left	300 mA	A	500 A	1000 A	10000 A	10000 A
4118 38	40 A	220/380 V~	left	300 mA	A	500 A	1000 A	10000 A	10000 A
4118 39	63 A	220/380 V~	left	300 mA	A	630 A	1000 A	10000 A	10000 A
4118 40	80 A	220/380 V~	left	300 mA	A	800 A	1000 A	10000 A	10000 A
4118 41	100 A	220/380 V~	left	300 mA	A	1000 A	1000 A	10000 A	10000 A

Products dedicated to Brazilian and Mexican market (voltage 220/380V)

Independent of line voltage :	Oui / yes
rated frequency : (Hz)	50 Hz
delay time	without or with S
nature of supply :	~
total number of poles :	4
Rated insulation voltage Ui : (V)	500 V~
Rated impulse withstand voltage Uimp : (V)	4 000 V
Utilisation range temperature : (°C)	-25 °C à/to +40 °C
Rated residual making and breaking capacity I $\Delta$ m : (A)	1 000 A
Rated conditional short-circuit current Inc : (A)	10 000 A
Rated conditional residual short-circuit current I $\Delta$ c : (A)	10 000 A
Short-circuit protection devices :	Fuse Gg of the same rated current
short-circuit tests :	35mm
Protection against external influences :	enclosed
Protection degree :	IP20
Material group :	II
Method of mounting :	panel board – on rail
Method of electrical connection :	
not associated with the mechanical-mounting	
Type of terminals :	pillar terminals
Nominal diameter of thread : (mm)	5
Operating means :	Lever



LCIE – Laboratoire Central des Industries Electriques  
 33, avenue du Général Leclerc – BP8  
 FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)



Date: 19/02/2019

 Signature: **Jean-François BRUEL**  
 Certification Officer