



Ref. Certif. No.

CN48885

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Flush-type 13A Switched socket-outlet with Earthing-contact and shutter; Flush-type 13A Switched socket-outlet with Earthing-contact, shutter and indicator lamp

Name and address of the applicant

TCL-Legrand International Electrical (Huizhou) Co., Ltd.
Bldg. B1-B3, East No.39 Hechang 6th Rd., HZZK Hi-tech Industrial Development Zone, Huizhou, Guangdong, P.R.China

Name and address of the manufacturer

TCL-Legrand International Electrical (Huizhou) Co., Ltd.
Bldg. B1-B3, East No.39 Hechang 6th Rd., HZZK Hi-tech Industrial Development Zone, Huizhou, Guangdong, P.R.China

Name and address of the factory

Note: When more than one factory, please report on page 2

TCL-Legrand International Electrical (Huizhou) Co., Ltd.
Bldg. B1-B3, East No.39 Hechang 6th Rd., HZZK Hi-tech Industrial Development Zone, Huizhou, Guangdong, P.R.China

Ratings and principal characteristics

13A 250V~; 13A 250V~

Trademark (if any)

Graphic Trademark, See the report

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

282432, 282432-C, 282432-C1, 282432-C2, 282432-C3, 282433, 282433-C, 282433-C1, 282433-C2, 282433-C3, 617146, 617346, 617446, 617646, 617746, 617846, 617141, 617341, 617441, 617641, 617741, 617841, K8/15/13-HK, K8/15/13-C-HK, K8/15/13-C1-HK, K8/15/13-C2-HK, K8/15/13-C3-HK, K8/15/13-C4-HK, K8/15/13/2-HK, K8/15/13/2-C-HK, K8/15/13/2-C1-HK, K8/15/13/2-C2-HK, K8/15/13/2-C3-HK, K8/15/13/2-C4-HK; 282480, 282480-C, 282480-C1, 282481, 282481-C, 282481-C1

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate

IEC60884-1(ed.3);am1;am2;IEC60884-2-3(ed.2)

This CB Test Certificate is issued by the National Certification Centre for CQC 2019-0951

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date:

Dec.16,2019

Signature:

Lu Mei