

# LICENCE

No. 19701 replaces No.19355

Issued to:  
 Applicant:  
**Legrand Group Belgium N.V.**  
**Kouterveldstraat 9, Ind. Zone**  
**1831 DIEGEM**  
**Belgium**

Licensee:  
**Legrand Group Belgium N.V.**  
**Kouterveldstraat 9, Ind. Zone**  
**1831 DIEGEM**  
**Belgium**



Product : circuit-breakers for overcurrent protection  
 Trade name(s) : LEGRAND  
 Type(s)/model(s) : Series TX<sup>3</sup> ( see appendix )


The product and any acceptable variation thereto is specified in the annex to this licence and the documents therein referred to.

SGS CEBEC hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard specified in annex
- an inspection of the production location
- a certification agreement with the number 178

SGS CEBEC hereby grants the right to use the CEBEC certification mark  
 The CEBEC certification mark may be applied to the product as specified in this licence for the duration of the CEBEC certification agreement and under the conditions of the CEBEC certification agreement.

This licence is issued on: 09/10/2015



Ir. G. Lana,  
 Certification Manager

© Only integral publication of this certificate, including the annex, is allowed  
 This certificate is only valid combined with the publication on the following web address: [www.sgs.com/ee](http://www.sgs.com/ee)



005-PROD



**SPECIFICATION OF THE CERTIFIED PRODUCT****Product data**

Product	:	circuit-breakers for overcurrent protection
Trade name(s)	:	LEGRAND
Type(s)/Model(s)	:	Series TX <sup>3</sup> ( see appendix )
rated short-circuit current (I <sub>cn</sub> )	:	3000 A
range of instantaneous tripping overcurrent (curve)	:	C
rated voltage (Un)	:	230 V/400 V - 1 P 400 V - 2 P, 3 P, 4 P
energy limiting class	:	3
rated frequency	:	50 Hz
method of mounting	:	DIN-RAIL fixation : 1 pole/module
terminals	:	pilar terminals
safety distance 'a'	:	35 mm

**Additional information**

See Appendix

**TESTS****Test requirements**

NBN EN 60898-1 based on EN 60898-1:2003 + corrigendum 2004-02 + corrigendum 2004 + A1:2004 + A11:2005 + A12:2008 + A13:2012

**Test results**

The test results are laid down in certification file ref.620538/01

**Remarks**

This certificate is based on certificates ref. CB IT-15106 & CB IT-15811 and test reports ref. PB14S0310214-01-00 to PB14S0310214-01-62 and PB15S0469155-04-00 to PB15S0469155-04-68


**Conclusion**

The examination proved that all test requirements were met.

Checked by, project leader : Zanutto Luigi - 09/10/2015

Department Manager,  
Product Certification :

Certification Manager :

A handwritten signature in blue ink, followed by the date '2015-10-09' written in blue ink.

**FACTORY LOCATION(S)**

Legrand Polska SP. Z O.O.  
ul. Warynskiego 20  
57200 ZABKOWICE SLASKIE  
Poland

Products references :

<i>Product reference</i>	<i>Serie</i>	<i>Number of poles</i>	<i>Type</i>	<i>In</i>	<i>Un</i>	<i>Limitation class</i>	<i>Icn</i>
403091	TX <sup>3</sup>	1 P	C	1 A	230/400 V~	3	3000A
403092	TX <sup>3</sup>	1 P	C	2 A	230/400 V~	3	3000A
403093	TX <sup>3</sup>	1 P	C	4 A	230/400 V~	3	3000A
403094	TX <sup>3</sup>	1 P	C	6 A	230/400 V~	3	3000A
403095	TX <sup>3</sup>	1 P	C	10 A	230/400 V~	3	3000A
403096	TX <sup>3</sup>	1 P	C	16 A	230/400 V~	3	3000A
403097	TX <sup>3</sup>	1 P	C	20 A	230/400 V~	3	3000A
403098	TX <sup>3</sup>	1 P	C	25 A	230/400 V~	3	3000A
403099	TX <sup>3</sup>	1 P	C	32 A	230/400 V~	3	3000A
403100	TX <sup>3</sup>	1 P	C	40 A	230/400 V~	3	3000A
403111	TX <sup>3</sup>	2 P	C	1 A	400 V ~	3	3000A
403112	TX <sup>3</sup>	2 P	C	2 A	400 V ~	3	3000A
403113	TX <sup>3</sup>	2 P	C	4 A	400 V ~	3	3000A
403114	TX <sup>3</sup>	2 P	C	6 A	400 V ~	3	3000A
403115	TX <sup>3</sup>	2 P	C	10 A	400 V ~	3	3000A
403116	TX <sup>3</sup>	2 P	C	16 A	400 V ~	3	3000A
403117	TX <sup>3</sup>	2 P	C	20 A	400 V ~	3	3000A
403118	TX <sup>3</sup>	2 P	C	25 A	400 V ~	3	3000A
403119	TX <sup>3</sup>	2 P	C	32 A	400 V ~	3	3000A
403120	TX <sup>3</sup>	2 P	C	40 A	400 V ~	3	3000A
403123	TX <sup>3</sup>	3 P	C	4 A	400 V ~	3	3000A
403124	TX <sup>3</sup>	3 P	C	6 A	400 V ~	3	3000A
403125	TX <sup>3</sup>	3 P	C	10 A	400 V ~	3	3000A
403126	TX <sup>3</sup>	3 P	C	16 A	400 V ~	3	3000A
403127	TX <sup>3</sup>	3 P	C	20 A	400 V ~	3	3000A
403128	TX <sup>3</sup>	3 P	C	25 A	400 V ~	3	3000A
403129	TX <sup>3</sup>	3 P	C	32 A	400 V ~	3	3000A
403130	TX <sup>3</sup>	3 P	C	40 A	400 V ~	3	3000A
403133	TX <sup>3</sup>	4 P	C	4 A	400 V ~	3	3000A
403134	TX <sup>3</sup>	4 P	C	6 A	400 V ~	3	3000A
403135	TX <sup>3</sup>	4 P	C	10 A	400 V ~	3	3000A
403136	TX <sup>3</sup>	4 P	C	16 A	400 V ~	3	3000A
403137	TX <sup>3</sup>	4 P	C	20 A	400 V ~	3	3000A
403138	TX <sup>3</sup>	4 P	C	25 A	400 V ~	3	3000A
403139	TX <sup>3</sup>	4 P	C	32 A	400 V ~	3	3000A
403140	TX <sup>3</sup>	4 P	C	40 A	400 V ~	3	3000A