

IEC**IECEE**

®

™

Ref. Certif. No.

FR_719910

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Plug
Rewirable plug

Name and address of the applicant

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX - FRANCE

Name and address of the manufacturer

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX - FRANCE

Name and address of the factory

NINGBO BANMEN ELECTRIC APPLIANCE CO., LTD.
East Industrial Zone, Guanhaiwei, Cixi City, 315314
Zhejiang Province - CHINA

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)

legrand

Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

0 504 09

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR 639186B dated 19/03/2013.
Update further to the evolution of the standard(s)
Update the list of product references
Update the list of components Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60884-1:2022

As shown in the Test Report Ref. No. which forms part of this Certificate

ABND-ESH-P22111816

This CB Test Certificate is issued by the National Certification Body

**LCIE**LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCEwww.lcie.frLABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSESSignature: 
Julien GAUTHIER
Certification Officer

Date: 06/09/2024

ANNEX

CLASSIFICATION


standard Sheet:	VII of CEE7
rated current (A)	16 A
rated load (W)	-
rated voltage (V)	250 V~
household voltage (V)	-
degree of protection	IP20
provision for earthing	with earthing contact (Solid plug pin)
method of connecting the cable	rewirable
type of terminals	Screw-type
type of connections	-
colour	Grey + White
plugs:	
class of equipment	I
entry of cable	lateral


type of components	manufacturer	Certification
Switch	Shenzhen Baokezhen Electronics Co. Ltd.	SE-S-2100460
Alt.	Cixi Minghe Xinghua Electric Appliance Fittings Factory	SE-S-2200608



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 06/09/2024



Signature:  Julien GAUTHIER
 Certification Officer