



Ref. Certif. No.

FR_704274/M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Cord outlet connecting box

Name and address of the applicant

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX
FRANCE

Name and address of the manufacturer

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX
FRANCE

Name and address of the factory

See annex

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR_704274 dated 07/11/2018. Update the list of product references

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60670-1:2015
IEC 60670-22:2003 + A1:2015

As shown in the Test Report Ref. No. which forms part of this Certificate

171876-763204

This CB Test Certificate is issued by the National Certification Body




LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 05/07/2021



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 863 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Signature: 
Julien Gauthier
Certification Officer

ANNEX

Name and address of the factories:**LEGRAND FRANCE**

128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX
FRANCE

LEGRAND MAGYARORSZAG VILLAMOSSAGI RENDSZEREK ZRT

IPARTELEPI UT 14 PF 10
6600 SZENTES
HUNGARY



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 05/07/2021



LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES


Signature: **Julien Gauthier**
Certification Officer

ANNEX (continued)


Type references	References							IP	Specificity
	White with claws		White without claws		Alu without claws		Black without claws		
	PRO	DIY	PRO	DIY	PRO	DIY	DIY		
6 00X 44			6 000 44		6 001 44			IP20	-
-	6 003 24			0 952 90				IP44	-
-		0 950 19						IP21	-
-	6 007 24		6 003 23					IP20	Without cover plate
6 00X 25			6 003 25		6 004 25			IP20	Without cover plate
				0 952 21		0 952 51	0 952 81		

Rated insulation voltage	250V ~
Rated connecting capacity	2,5 mm ²
Maximum number of conductors to be placed in the box	3 (12 mm maxi)

Nature of material	Composite	
Method of installation	Flush, semi-flush or embedded in	Walls ceilings or floors combustible and non-combustible
		Hollow walls, hollow ceilings, hollow floors or furniture
Type(s) of inlets (outlets)	with inlets for flexible cables without inlets (6 00X 44)	
Clamping means	With cable anchorage Without clamping means (6 00X 44)	
Minimum and maximum temperatures during installation	-5°C to + 60°C	
Boxes and enclosures for hollow walls and the like:	According to the degree of protection of the part mounted in the hollow wall	see above table
Method of fixing the terminals or connecting devices in the connecting box	Without fixing (for floating terminals or connecting devices)	



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr



Signature:  Julien Gauthier
 Certification Officer

Date: 05/07/2021

ANNEX (end)

ACCESSORIES – Cover plates

	Blanc	Dune	Plume	Atoll	Raisin	Aluminium	Noir velour
1 gang square	6 008 01 6 009 01 6 009 41*	6 008 11	6 008 21	6 008 31	6 009 31	6 008 51	6 008 61
2 gang square	6 008 02 6 009 02	6 008 12	6 008 22	6 008 32	6 009 32	6 008 52	6 008 62
3 gang square	6 008 03 6 009 03	6 008 13	6 008 23	6 008 33	6 009 33	6 008 53	6 008 63
4 gang square	6 008 04 6 009 04	6 008 14	6 008 24	6 008 34	6 009 34	6 008 54	6 008 64
2 gang square entraxe 57	6 008 07						

*sold by 100


Bague	Blanc	Style inox brossé	Style bois ébène	Style inox sombre	Blanc
	Chrome	Chrome	Chrome sombre	Chrome sombre	Chrome rosé
1 gang square	6 008 41	6 008 71	6 008 81	6 009 11	6 009 21
2 gang square	6 008 42	6 008 72	6 008 82	6 009 12	6 009 22
3 gang square	6 008 43	6 008 73	6 008 83	6 009 13	6 009 23

Bague	Blanc	Blanc	Blanc	Blanc	Blanc	Blanc	Aluminium	Noir velour	Style inox sombre	Style inox brossé
		Dune	Plume	Atoll	Chrome	Chrome rosé	Chrome	Chrome sombre	chrome sombre	Chrome
1 gang round	6 009 80	6 009 70	6 009 71	6 009 72	6 009 73	6 009 20	6 009 75	6 009 76	6 009 78	6 009 79



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
 33 avenue du Général Leclerc
 92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 05/07/2021



Signature: *Julien Gauthier*
 Certification Officer