



Ref. Certif. No.

SE-91834

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Circuit breakers
Name and address of the applicant	LEGRAND SNC. 128 avenue du Maréchal de Lattre, de Tassigny, FR-87045 Limoges cedex, FRANCE
Name and address of the manufacturer	Same as applicant
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	See page 2.
Ratings and principal characteristics	$U_e = 220-690V$ AC, $I_e = 400-630A$, 50-60Hz $U_i = 800V$, $U_{imp} = 8kV$, Pattern No. 3-4 See also page 2.
Trademark (if any)	Legrand
Customer's Testing Facility (CTF) Stage used	CTF Stage 2
Model / Type Ref.	DPX ³ -I 630
Additional information (if necessary may also be reported on page 2)	-
A sample of the product was tested and found to be in conformity with	IEC 60947-3:2008 + A1
As shown in the Test Report Ref. No. which forms part of this Certificate	1812381STO-00

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00

Date: 6 September 2018

intertek

Signature:

Bo Berglöf

ABF

Factories

Bticino S.P.A.

Via Folzoni 5, IT-24052 Azzano San Paolo, Bergamo
ITALY

Wuxi TCL Legrand, Low Voltage Electrical Co., Ltd.

No. 88, Ximei Road, New Zone Wuxi, Jiangsu Province
P.R.CHINA**Additional information (if necessary)**DPX³-I 630 - AC23A category

U_e (V)	I_e (A)	I_{cm} (kA)	I_{cw} (kA/s)
220-690	400	8	5 / 1

DPX³-I 630 - AC22A category

U_e (V)	I_e (A)	I_{cm} (kA)	I_{cw} (kA/s)
220-690	630	14	8 / 1

Date: 6 September 2018

Signature: 