

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Switch-disconnectors
Name and address of the applicant	Legrand France SA 128 Avenue du Marechal-de-Lattre de Tassigny, FR-87045 Limoges Cedex France
Name and address of the manufacturer	BTICINO S.p.A. – Legrand Group Viale Borri, 231 21100 – Varese (VA) Italy
Name and address of the factory	<input type="checkbox"/> Additional information on page 2 BTICINO S.p.A. – Legrand Group Via Dell'Industria, 22 80059 – Torre del Greco (NA) Italy
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	Ue: 415 V ac; Ui: 500 V ac; Uimp: 6 kV; Ie: 100 or 125 A; Ith: 100 or 125 A; Utilization category: AC-22A and/or AC-23A (see page 5 of Test Reports and/or Additional Sheet)
Trademark (if any)	legrand legrand
Customer's Testing Facility (CTF) Stage used	CTF Stage 2
Model / Type Ref.	Series DX ³ -IS, type reference 4 065 39, 4 065 47, 4 065 38 or 4 065 46 (see also page 2 of Test Reports or Additional Sheet)
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60947-1:2020, IEC 60947-3:2020
As shown in the Test Report Ref. No. which forms part of this Certificate	PB21-0071821-01-01 and PB21-0071821-01-02

This CB Test Certificate is issued by the National Certification Body

IMQ S.p.A.
Via Quintiliano 43, IT-20138 Milano, Italy

Description of the switch-disconnectors DX³-IS series

Type reference	Number of poles	Utilization category	Rated operational current (I _e)	Conventional free air thermal current (I _{th})	Test Report No.
4 065 39	3	AC-22A	125 A	125 A	PB21-0071821-01-01
		AC-23A	100 A		
4 065 47	4	AC-22A	125 A		
		AC-23A	100 A		
4 065 38	3	AC-22A	100 A	100 A	PB21-0071821-01-02
		AC-23A			
4 065 46	4	AC-22A			
		AC-23A			