Ref. Certif. No.

FR_623324/M2

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	**Boxes and enclosures for electrical accessories**
Name and address of the applicant	**LEGRAND FRANCE** 128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY 87045 LIMOGES CEDEX - FRANCE
Name and address of the manufacturer	**LEGRAND FRANCE** 128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY 87045 LIMOGES CEDEX - FRANCE
Name and address of the factory	
Note: *When more than one factory, please report on page 2*	☒ Additional Information on page 2
Ratings and principal characteristics	See Annex
Trademark (if any)	legrand®
Customer's Testing Facility (CTF) Stage used	/
Model / Type Ref.	Series SALBEI References: 7 67x 20
Additional information (if necessary may also be reported on page 2)	Supersedes CBTC no. FR 623324/M1 dated 01/04/2016. Addition of product references ☒ Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60670-1:2015 IEC 60670-22:2003 + A1:2015
As shown in the Test Report Ref. No. which forms part of this Certificate	137916-677933, 102524-605709, 154428-718586B, 154428-718586A

This CB Test Certificate is issued by the National Certification Body

LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES
S.A.S au capital de 15 745 984 €
RCS Nanterre B 408 363 174
33 Avenue du Général Leclerc
F – 92266 FONTENAY AUX ROSES

Date: 29/10/2018

Signature: **Jean-François BRUEL**
Certification Officer

ANNEX

Name and address of the factories:

EMB ELECTRICAL INDUSTRIES SAE
SECOND INDUSTRIAL ZONE - SADAT CITY AREA 18 - P.O. BOX 14
32958 MENOFIA – EGYPT

LEGRAND ELEKTRIK SANAYI A.S
GOSB GEBZE ORGANIZE SANAYI BOLGESI - IHSAN DEDE CADDESI N°112
41480 GEBZE KOCAELI - TURKEY

ANNEX (continued)

REFERENCES, RATINGS AND MAIN CHARACTERISTICS

Mechanisms

	References									
type reference	White	Aluminium	Anthracite	Ivory	Champagne	Matt Gold with claw	Pink with claws	Smoked Grey with claw	White Pearl with claw	Specifity
7 67x 20 NCO01	7 671 20	7 672 20	7 673 20	7 674 20	7 675 20	7 676 20	7 677 20	7 678 20	7 679 20	whitout plate

Rated insulation voltage	250V ~
Rated connecting capacity	2,5 mm²
Maximum number of conductors to be placed in the box	3 (12 mm maxi)

CLASSIFICATION

Nature of material:	Composite	
Method of installation	Flush, semi-flush or embedded in	Walls cellings or floors combustible and non-combustible
		Hollow walls, hollow cellings, hollow floors or furniture
Type(s) of inlets (oulets)	with inlets for flexible cables	
Clamping means	Avec serre-câbles	
Minimum and maximum temperatures during installation	De -5°C à + 60°C	
Boxes and enclosures for hollow walls and the like:	According to the degree of protection of the part mounted in the hollow wall	IP 20
Method of fixing the terminals or connecting devices in the connecting box	Without fixing (for floating terminals or connecting devices)	

LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES
S.A.S au capital de 15 745 000 €
RCS Nanterre B 408 363 174
33 Avenue du Général Leclerc
F – 92266 FONTENAY AUX ROSES

Date: 29/10/2018

Signature: **Jean-François BRUEL**
Certification Officer

ANNEX (continued)

Accessories :

Surface boxes

Type references	References	Designation
7 67x 47	7 671 47	1 gang white
	7 672 47	1 gang aluminium
	7 673 47	1 gang anthracite
	7 674 47	1 gang ivory
	7 675 47	1 gang champagne
	7 676 47	1 gang matt gold
	7 677 47	1 gang pink gold
	7 678 47	1 gang smoked grey
	7 679 47	1 gang pearl white
7 67x 48	7 671 48	2 gang white
	7 672 48	2 gang aluminium
	7 673 48	2 gang anthracite
	7 674 48	2 gang ivory
	7 675 48	2 gang champagne
	7 676 48	2 gang matt gold
	7 677 48	2 gang pink gold
	7 678 48	2 gang smoked grey
	7 679 48	2 gang pearl white

LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES
S.A.S au capital de 1 745 664 €
RCS Nanterre B 408 963 174
33 Avenue du Général Leclerc
F – 92266 FONTENAY AUX ROSES

Date: 29/10/2018

Signature: **Jean-François BRUEL**
Certification Officer

ANNEX (end)

Cover plates

		References										
Type references	Designation	White	Ivory	Aluminium	Anthracite	Champagne	Bright Wood	White Pearl	Matt Gold	Pink	Smoked Grey	Dark Wood
7 673 x1	1 gang	7 673 31	7 673 41	7 673 51	7 673 61	7 673 71	7 673 81					
7 673 x2	2 gang	7 673 32	7 673 42	7 673 52	7 673 62	7 673 72	7 673 82					
7 673 x3	3 gang	7 673 33	7 673 43	7 673 53	7 673 63	7 673 73	7 673 83					
7 673 x4	4 gang	7 673 34	7 673 44	7 673 54	7 674 64	7 673 74	7 673 84					
7 673 x5	5 gang	7 673 35	7 673 45	7 673 55	7 673 65	7 673 75	7 673 85					
7 67x 91	6 gang	7 671 91	7 674 91	7 672 91	7 673 91	7 675 91		7 679 91	7 676 91	7 677 91	7 678 91	
7 67x 92	6 gang						7 673 92					7 675 92
7 673 x6	1 gang IP44 IK07	7 673 36	7 673 46									
7 675 x1	1 gang							7 675 41	7 675 61	7 675 71	7 675 51	7 675 31
7 675 x2	2 gang							7 675 42	7 675 62	7 675 72	7 675 52	7 675 32
7 675 x3	3 gang							7 675 43	7 675 63	7 675 73	7 675 53	7 675 33
7 675 x4	4 gang							7 675 44	7 675 64	7 675 74	7 675 54	7 675 34
7 675 x5	5 gang							7 675 45	7 675 65	7 675 75	7 675 55	7 675 35
7 67x 90	1 gang label holder	7 671 90	7 674 90	7 672 90	7 673 90	7 675 90		7 679 90	7 676 90	7 677 90	7 678 90	