



Attestation of Conformity

Unscreened Category 6A ISO/IEC, EN & ANSI/TIA Connecting Hardware

Legrand Identification P/N SA61
Cat. 6A Unscreened Modular Jack
Electrical Transmission Performance

Legrand France SA
128 Avenue de Lattre de Tassigny, 87045,
Limoges Cedex, France

Attestation of Conformity No. 0473-3P-1200837

This unscreened ISO/IEC, EN & ANSI/TIA Connecting Hardware, having PCB identification HS01835AB C6A NGC, has been tested by 3P Third Party Testing and complies with the Category 6A performance requirements of edition 1.0 of ISO/IEC 11801-1:2017, CENELEC EN 50173-1:2018, the Category 6A requirements of ANSI/TIA-568.2-D:2018 and the requirements of edition 1.0 of IEC 60603-7-41:2010. The requirements are passed using the re-embedded vectors specified in ANSI/TIA-568.2-D:2018 and IEC 60512-27-100:2011. The Attestation of Conformity is valid for the actually tested connecting hardware sample and has full 3P marketing support for one year from the date printed on the certificate.

Hoersholm, 16 June 2020

A handwritten signature in blue ink, appearing to read "Ole Lambertsen", is written over a horizontal line.

Ole Lambertsen
Test Responsible

Hoersholm, 16 June 2020

A handwritten signature in blue ink, appearing to read "Jens Rytter Petersen", is written over a horizontal line.

Jens Rytter Petersen
General Manager