

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Multiway adaptor
Name and address of the applicant	LEGRAND FRANCE 128, Avenue du Maréchal de Lattre de Tassigny 87045 Limoges Cedex France
Name and address of the manufacturer	Same as applicant
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	Ningbo Banmen Electric Appliance Co., Ltd. East Industrial Zone, GuanHaiWei Cixi City, 315314, Zhejiang Province, China
Ratings and principal characteristics	See page 2
Trademark (if any)	LEGRAND
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	6 945 18, 6 945 19
Additional information (if necessary may also be reported on page 2)	-
A sample of the product was tested and found to be in conformity with	IEC 60884-1:2002+A1+A2 IEC 60884-2-5:2017
As shown in the Test Report Ref. No. which forms part of this Certificate	200602545SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

intertek
Signature: 

Date: 14 September, 2020

Hyden Li



Ref. Certif. No.

SE-102352

Ratings and principal characteristics

16A 230V~, Max. 3680W , IP20, non-rewirable, with three-way CEE 7 / III socket-outlet, with shutters, CEE 7 / VII plug, with solid pin.

Model 6 945 18: with light grey / white color for enclosure.

Model 6 945 19: with dark grey / black color for enclosure.

Date: 14 September, 2020

Signature: 