



Ref. Certif. No.

FR_707113/M3

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Fixed switched socket-outlet

Switched socket-outlets for fixed installations

Name and address of the applicant

Legrand Intelligent Electrical (Huizhou) Co., Ltd.
Bldg.B1-B3, East No.39 Hechang 6th Rd., HZZK Hi-tech
Industrial Development Zone, Huizhou, Guangdong - CHINA

Name and address of the manufacturer

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX- FRANCE

Name and address of the factory

Legrand Intelligent Electrical (Huizhou) Co., Ltd.
Bldg.B1-B3, East No.39 Hechang 6th Rd., HZZK Hi-tech
Industrial Development Zone, Huizhou, Guangdong - CHINA

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

See Annex

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR_707113/M2 dated 04/12/2020. Update the list of product references, Change the name of applicant and factory, Change the name and address of manufacturer

 Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60884-1:2002(ed.3) +A1:2006 +A2:2013
IEC 60884-2-3:2006

As shown in the Test Report Ref. No. which forms part of this Certificate

ARLI-ESH-P20121688

This CB Test Certificate is issued by the National Certification Body

LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.frLABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSESSignature: 
Julien Gauthier
Certification Officer

Date: 29/03/2021

ANNEX

References, ratings and main characteristics:

Reference	Description	Color code of of enclosure
617651	1G BS 15A SP SWTD SOCKET	White
617751	1G BS 15A SP SWTD SOCKET	Anthracite
617851	1G BS 15A SP SWTD SOCKET	Ivory
617652	1G BS 15A SP SWTD + LED Indicator light	White
617752	1G BS 15A SP SWTD + LED Indicator light	Anthracite
617852	1G BS 15A SP SWTD + LED Indicator light	Ivory
617653	2G BS 15A SP SWITCHED	White
617753	2G BS 15A SP SWITCHED	Anthracite
617853	2G BS 15A SP SWITCHED	Ivory
617654	1G BS 5A SWITCHED SOCKET	White
617754	1G BS 5A SWITCHED SOCKET	Anthracite
617854	1G BS 5A SWITCHED SOCKET	Ivory
282437	1G BS 15A SWITCHED SOCKET	White
282437-C	1G BS 15A SWITCHED SOCKET	Matt black
282437-C1	1G BS 15A SWITCHED SOCKET	Rose gold
282437-C2	1G BS 15A SWITCHED SOCKET	Champagne
282437-C3	1G BS 15A SWITCHED SOCKET	Dark silver
282438	1G BS 5A SWITCHED SOCKET	White
282438-C	1G BS 5A SWITCHED SOCKET	Matt black
282438-C1	1G BS 5A SWITCHED SOCKET	Rose gold
282438-C2	1G BS 5A SWITCHED SOCKET	Champagne
282438-C3	1G BS 5A SWITCHED SOCKET	Dark silver
617051	1G BS 15A SP SWITCHED SOCKET	White
617351	1G BS 15A SP SWITCHED SOCKET	Dark grey
617451	1G BS 15A SP SWITCHED SOCKET	Brown
617052	1G BS 15A SP SWITCHED SOCKET	White
617352	1G BS 15A SP SWITCHED SOCKET	Dark grey
617452	1G BS 15A SP SWITCHED SOCKET	Brown
617053	DOUBLE BS15 SW SOCKET OUTLET	White
617353	DOUBLE BS15 SW SOCKET OUTLET	Dark grey
617453	DOUBLE BS15 SW SOCKET OUTLET	Brown
617054	BS 5A SWITCHED SOCKET	White
617354	BS 5A SWITCHED SOCKET	Dark grey
617454	BS 5A SWITCHED SOCKET	Brown
281128MW	1G BS 15A SWITCHED SOCKET	Matt white
281128MG	1G BS 15A SWITCHED SOCKET	Matt grey
281128MB	1G BS 15A SWITCHED SOCKET	Matt black



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr



LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 246 171
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Signature: *Julien Gauthier*
Certification Officer

Date: 29/03/2021

ANNEX

Reference	Description	Color code of enclosure
281128DS	1G BS 15A SWITCHED SOCKET	Dark silver
281128CH	1G BS 15A SWITCHED SOCKET	Champagne
281128DB	1G BS 15A SWITCHED SOCKET	Dark bronze
281128BA	1G BS 15A SWITCHED SOCKET	Brushed aluminium
281128BB	1G BS 15A SWITCHED SOCKET	Brushed black
281129MW	1G BS 15A SWITCHED SOCKET +LED Indicator light	Matt white
281129MG	1G BS 15A SWITCHED SOCKET +LED Indicator light	Matt grey
281129MB	1G BS 15A SWITCHED SOCKET +LED Indicator light	Matt black
281129DS	1G BS 15A SWITCHED SOCKET +LED Indicator light	Dark silver
281129CH	1G BS 15A SWITCHED SOCKET +LED Indicator light	Champagne
281129DB	1G BS 15A SWITCHED SOCKET +LED Indicator light	Dark bronze
281129BA	1G BS 15A SWITCHED SOCKET +LED Indicator light	Brushed aluminium
281129BB	1G BS 15A SWITCHED SOCKET +LED Indicator light	Brushed black
281132MW	1G BS 5A SWITCHED SOCKET	Matt white
281132MG	1G BS 5A SWITCHED SOCKET	Matt grey
281132MB	1G BS 5A SWITCHED SOCKET	Matt black
281132DS	1G BS 5A SWITCHED SOCKET	Dark silver
281132CH	1G BS 5A SWITCHED SOCKET	Champagne
281132DB	1G BS 5A SWITCHED SOCKET	Dark bronze
281132BA	1G BS 5A SWITCHED SOCKET	Brushed aluminium
281132BB	1G BS 5A SWITCHED SOCKET	Brushed black



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 29/03/2021



LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 124
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Signature: *Julien Gauthier*
Certification Officer

ANNEX

standard Sheet:	standard sheet of BS 546
rated current (A) rated voltage (V)	15A or 5A 250V
degree of protection	IP20
provision for earthing	with earthing contact
method of connecting the cable	rewirable
type of terminals	screw-type
colour	See above
socket-outlets	
multiple socket-outlets number of socket-outlets	15A : 1 or 2 5A: 1
degree of protection against electric shock	normal protection
existence of shutters	with shutters
method of application - mounting	flush-type
method of installation	design A
Intended for circuits where	a single earthing circuit provides protective earthing
Switched socket-outlets without interlock	
According to the method of actuating the switch	rocker
According to the switching of the neutral	Unswitched neutral



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 29/03/2021



LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES

Signature:  **Julien Gauthier**
Certification Officer