

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Fixed switched socket-outlet

Switched socket-outlets without interlock for fixed installations

Name and address of the applicant

LEGRAND FRANCE128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY,
87045 LIMOGES CEDEX - FRANCE

Name and address of the manufacturer

LEGRAND FRANCE128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY,
87045 LIMOGES CEDEX - FRANCE

Name and address of the factory

LEGRAND FRANCE128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY,
87045 LIMOGES CEDEX - FRANCE

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

6 846 22, 6 846 29

Additional information (if necessary may also be reported on page 2)

 Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60884-1:2002(ed.3) +A1:2006 +A2:2013
IEC 60884-2-3:2006

As shown in the Test Report Ref. No. which forms part of this Certificate



ABND-ESH-P20090580

This CB Test Certificate is issued by the National Certification Body

LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 22/12/2020

Signature



LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 774
Fontenay aux Roses Cedex
F - 92266 FONTENAY AUX ROSES
Certification Officer

ANNEX

RATING AND MAIN CHARACTERISTICS

Reference	Range*	Number of socket-outlets	Description
6 846 22	PLEXO66 1G SP SW	1	PR.CDEE 13A OPAQUE BICOLORE
6 846 29	PLEXO66 1G SP SW	2	PRISE DOUBLE CDEE 13A BICOLORE

* The "Range" denotes applicant's categorization.

CLASSIFICATION

standard Sheet:	standard sheet of BS 1363-2
rated current (A)	13 A
rated voltage (V)	250 V~
degree of protection	IP66
provision for earthing	with earthing contact
method of connecting the cable	rewirable
type of terminals	screw-type
colour	Grey + Black
socket-outlets	
multiple socket-outlets	
number of socket-outlets	13A : 1 or 2
degree of protection against electric shock	increased protection
existence of shutters	with shutters
method of application - mounting	Surface-type
method of installation	design B
Intended for circuits where	a single earthing circuit provides protective earthing
Switched socket-outlets without interlock	
According to the method of actuating the switch	rocker
According to the switching of the neutral	unswitched neutral



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 22/12/2020



Signature: Jérôme REYSSON
Certification Officer