



Ref. Certif. No.

ES1842

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB
SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS
D'ESSAIS DES EQUIPEMENTS ELECTRIQUES (IECEE)
METHODE OC

CB TEST CERTIFICATE CERTIFICAT D'ESSAI OC

Product
Produit

LED LUMINAIRES FOR EMERGENCY LIGHTING

Name and address of the applicant
Nom et adresse du demandeurLEGRAND GROUP ESPAÑA, S.L.
CL HIERRO, 56
28850 TORREJON DE ARDOZ (Madrid - Spain)Name and address of the manufacturer
Nom et adresse du fabricantLEGRAND FRANCE LAGORD
ZA DES GREFFIÈRES; 1, RUE EUGÈNE FREYSSINET
F17140 LAGORD (France)Name and address of the factory
Nom et adresse de l'usine

SAME AS ABOVE

Note: when more than one factory, please report on page 2
Note: lorsque il y plus d'une usine, veuillez utiliser la 2^{ème} page Additional Information on page 2Ratings and principal characteristics
Valeurs nominales et caractéristiques principales

See Annex

Trademark (if any)
Marque de fabrique (si elle existe)

LEGRAND

Type of Manufacturer's Testing Laboratories used
Type de programme du laboratoire d'essais constructeur

-

Model / Type Ref.
Ref. de type

661640; 662640

Additional information (if necessary may also be reported on
page 2)
Les informations complémentaires (si nécessaire, peuvent être
indiqués sur la 2^{ème} page) Additional Information on page 2A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à laIEC 60598-1:2014
IEC 60598-2-22:2014As shown in the Test Report Ref. No. which forms part of this
Certificate
Comme indiqué dans le Rapport d'essais numéro de référence
qui constitue partie de ce Certificat

2016120782B1

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme National de CertificationAENOR INTERNACIONAL S.A.U.
Cl Génova, 6
ES-28004 MADRID (SPAIN)

Date: 2017-05-17

Signature: Avelino BRITO
General Manager

Product Certification Body accredited by ENAC, ref. nº 1/C-PR275

ANNEX TO CB CERTIFICATE N° ES1842

CERTIFIED REFERENCES AND THEIR MAIN RATINGS

Product: LED LUMINAIRES FOR EMERGENCY LIGHTING

Trade Mark: LEGRAND

Type reference	Rated voltage and frequency	N° lamps x rated power, type and lampholder	IP degree of protection	Power supply connection means	Protection against electric shocks (class)	Rated lumen output and duration
661640	230 V~; 50/60 Hz	LED 4 x 0,5 W	IP 42; IK 07	Terminals	Class II	100 lm - 3 h
662640	230 V~; 50/60 Hz	LED 4 x 0,5 W	IP 42; IK 07	Terminals	Class II	100 lm - 3 h

Classif. per holding surface material	Suitable for normally flammable surfaces
Battery features	4,8 V 2,0 Ah NiMH 4 cells
Additional information	Maintained, possible non maintained; Remote rest
General data	Electronic protection. URA-ONE