



Ref. Certif. No.

FR_721725/A1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCB's)

Name and address of the applicant

LEGRAND FRANCE
159 RUE JEAN JOANNON
ZI DES TROIS MOULINS
06606 ANTIBES - FRANCE

Name and address of the manufacturer

LEGRAND FRANCE
159 RUE JEAN JOANNON
ZI DES TROIS MOULINS
06606 ANTIBES - FRANCE

Name and address of the factory

Note: When more than one factory, please report on page 2

☒ Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

CTF3

Model / Type Ref.

RCCB 2P
Series: DX³, XC10, RX

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR_721725 dated 23/06/2025.
New version of the test Reports
☐ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61008-1:2010 +A1:2012 +A2:2013
IEC 61008-2-1:1990

As shown in the Test Report Ref. No. which forms part of this Certificate

TR n° 22971744-802925 Rev 01
TR n° 22971744-802925/1 Rev 01 to /34 Rev 01

This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 27/07/2026

Signature: **Julien CAUTHIER**
Certification Officer



ANNEX

Name and address of the factories:**LEGRAND FRANCE**

159 RUE JEAN JOANNON
ZI DES TROIS MOULINS
06606 ANTIBES
FRANCE

LEGRAND FRANCE

290 AVENUE DE COLMAR
67100 STRASBOURG
FRANCE

LEGRAND ELEKTRIK SANAYI A.S

GOSB GEBZE ORGANIZE SANAYI BOLGESI
IHSAN DEDE CADDESİ N°112
41480 GEBZE KOCAELI
TURKEY



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 27/07/2026

Signature: **Julien GAUTHIER**
Certification Officer

ANNEX

References, ratings and main characteristics:

References DX ³ Germanic series	I _n (A)	U _n (V~)	IΔn (mA)	Type	I _m	IΔm	I _{nc}	IΔc
4 343 37 4 345 10	16 A	230V~	10 mA	A	500 A	1000 A	10000A	10000A
8LG0380	25 A	230V~	10 mA	A	500 A	1000 A	10000A	10000A

References DX ³ Germanic series	I _n (A)	U _n (V~)	IΔn (mA)	Type	I _m	IΔm	I _{nc}	IΔc
8LG0381	16 A	230V~	30 mA	A	500 A	1000 A	10000A	10000A
4 343 39 4 345 11	25 A	230V~	30 mA	A	500 A	1000 A	10000A	10000A
4 343 40 4 345 12	40 A	230V~	30 mA	A	500 A	1000 A	10000A	10000A
4 343 41 4 345 13	63 A	230V~	30 mA	A	630 A	1000 A	10000A	10000A
4 343 42 4 345 14	80 A	230V~	30 mA	A	800 A	1000 A	10000A	10000A
8LG0382	100 A	230V~	30 mA	A	1000 A	1000 A	10000A	10000A
8LG0383	16 A	230V~	100 mA	A	500 A	1000 A	10000A	10000A
4 343 49	25 A	230V~	100 mA	A	500 A	1000 A	10000A	10000A
4 343 50	40 A	230V~	100 mA	A	500 A	1000 A	10000A	10000A
4 343 51	63 A	230V~	100 mA	A	630 A	1000 A	10000A	10000A
4 343 52	80 A	230V~	100 mA	A	800 A	1000 A	10000A	10000A
8LG0384	100 A	230V~	100 mA	A	1000 A	1000 A	10000A	10000A
8LG0385	16 A	230V~	300 mA	A	500 A	1000 A	10000A	10000A
4 343 59	25 A	230V~	300 mA	A	500 A	1000 A	10000A	10000A
4 343 60 4 345 22	40 A	230V~	300 mA	A	500 A	1000 A	10000A	10000A
4 343 61 4 345 23	63 A	230V~	300 mA	A	630 A	1000 A	10000A	10000A
4 343 62 4 345 24	80 A	230V~	300 mA	A	800 A	1000 A	10000A	10000A
8LG0386	100 A	230V~	300 mA	A	1000 A	1000 A	10000A	10000A
8LG0387	16 A	230V~	500 mA	A	500 A	1000 A	10000A	10000A
4 343 69	25 A	230V~	500 mA	A	500 A	1000 A	10000A	10000A
4 343 70	40 A	230V~	500 mA	A	500 A	1000 A	10000A	10000A
8LG0388	63 A	230V~	500 mA	A	630 A	1000 A	10000A	10000A
8LG0389	80 A	230V~	500 mA	A	800 A	1000 A	10000A	10000A
8LG0390	100 A	230V~	500 mA	A	1000 A	1000 A	10000A	10000A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 27/07/2026

Signature: Julien Gauthier
Certification Officer



ANNEX

References DX ³ Germanic series	I _n (A)	U _n (V~)	IΔn (mA)	Type	I _m	IΔm	I _{nc}	IΔc
4 342 97	16 A	230V~	10 mA	AC	500 A	1000 A	10000A	10000A
8LG0354	25 A	230V~	10 mA	AC	500 A	1000 A	10000A	10000A

References DX ³ Germanic series	I _n (A)	U _n (V~)	IΔn (mA)	Type	I _m	IΔm	I _{nc}	IΔc
8LG0355	16 A	230V~	30 mA	AC	500 A	1000 A	10000A	10000A
4 342 99	25 A	230V~	30 mA	AC	500 A	1000 A	10000A	10000A
4 343 00	40 A	230V~	30 mA	AC	500 A	1000 A	10000A	10000A
4 343 01	63 A	230V~	30 mA	AC	630 A	1000 A	10000A	10000A
4 343 02	80 A	230V~	30 mA	AC	800 A	1000 A	10000A	10000A
4 343 03	100 A	230V~	30 mA	AC	1000 A	1000 A	10000A	10000A
8LG0356	16 A	230V~	100 mA	AC	500 A	1000 A	10000A	10000A
4 343 09	25 A	230V~	100 mA	AC	500 A	1000 A	10000A	10000A
4 343 10	40 A	230V~	100 mA	AC	500 A	1000 A	10000A	10000A
4 343 11	63 A	230V~	100 mA	AC	630 A	1000 A	10000A	10000A
4 343 12	80 A	230V~	100 mA	AC	800 A	1000 A	10000A	10000A
4 343 13	100 A	230V~	100 mA	AC	1000 A	1000 A	10000A	10000A
8LG0357	16 A	230V~	300 mA	AC	500 A	1000 A	10000A	10000A
4 343 19	25 A	230V~	300 mA	AC	500 A	1000 A	10000A	10000A
4 343 20	40 A	230V~	300 mA	AC	500 A	1000 A	10000A	10000A
4 343 21	63 A	230V~	300 mA	AC	630 A	1000 A	10000A	10000A
4 343 22	80 A	230V~	300 mA	AC	800 A	1000 A	10000A	10000A
4 343 23	100 A	230V~	300 mA	AC	1000 A	1000 A	10000A	10000A
8LG0358	16 A	230V~	500 mA	AC	500 A	1000 A	10000A	10000A
8LG0359	25 A	230V~	500 mA	AC	500 A	1000 A	10000A	10000A
8LG0360	40 A	230V~	500 mA	AC	500 A	1000 A	10000A	10000A
8LG0361	63 A	230V~	500 mA	AC	630 A	1000 A	10000A	10000A
8LG0362	80 A	230V~	500 mA	AC	800 A	1000 A	10000A	10000A
8LG0363	100 A	230V~	500 mA	AC	1000 A	1000 A	10000A	10000A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 27/07/2026

Signature: Julien CAUTHER
Certification Officer


ANNEX

References DX ³ Germanic series	I _n (A)	U _n (V~)	IΔn (mA)	Type	I _m	IΔm	I _{nc}	IΔc
8LG0391	16 A	230V~	100 mA	A-S	500 A	1000 A	10000A	10000A
8LG0392	25 A	230V~	100 mA	A-S	500 A	1000 A	10000A	10000A
8LG0393	40 A	230V~	100 mA	A-S	500 A	1000 A	10000A	10000A
8LG0394	63 A	230V~	100 mA	A-S	630 A	1000 A	10000A	10000A
8LG0395	80 A	230V~	100 mA	A-S	800 A	1000 A	10000A	10000A
8LG0396	100 A	230V~	100 mA	A-S	1000 A	1000 A	10000A	10000A
8LG0397	16 A	230V~	300 mA	A-S	500 A	1000 A	10000A	10000A
8LG0398	25 A	230V~	300 mA	A-S	500 A	1000 A	10000A	10000A
8LG0399 4 345 27	40 A	230V~	300 mA	A-S	500 A	1000 A	10000A	10000A
4 343 77 4 345 28	63 A	230V~	300 mA	A-S	630 A	1000 A	10000A	10000A
8LG0400	80 A	230V~	300 mA	A-S	800 A	1000 A	10000A	10000A
8LG0401	100 A	230V~	300 mA	A-S	1000 A	1000 A	10000A	10000A
8LG0402	16 A	230V~	500 mA	A-S	500 A	1000 A	10000A	10000A
8LG0403	25 A	230V~	500 mA	A-S	500 A	1000 A	10000A	10000A
8LG0404	40 A	230V~	500 mA	A-S	500 A	1000 A	10000A	10000A
8LG0405	63 A	230V~	500 mA	A-S	630 A	1000 A	10000A	10000A
8LG0406	80 A	230V~	500 mA	A-S	800 A	1000 A	10000A	10000A
8LG0407	100 A	230V~	500 mA	A-S	1000 A	1000 A	10000A	10000A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 27/07/2026

Signature: Julien
Certification Officer


ANNEX

References DX ³ Germanic series	I _n (A)	U _n (V~)	IΔn (mA)	Type	I _m	IΔm	I _{nc}	IΔc
8LG0364	16 A	230V~	100 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0365	25 A	230V~	100 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0366	40 A	230V~	100 mA	AC-S	500 A	1000 A	10000A	10000A
4 343 26	63 A	230V~	100 mA	AC-S	630 A	1000 A	10000A	10000A
8LG0367	80 A	230V~	100 mA	AC-S	800 A	1000 A	10000A	10000A
8LG0368	100 A	230V~	100 mA	AC-S	1000 A	1000 A	10000A	10000A
8LG0369	16 A	230V~	300 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0370	25 A	230V~	300 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0371	40 A	230V~	300 mA	AC-S	500 A	1000 A	10000A	10000A
4 343 27	63 A	230V~	300 mA	AC-S	630 A	1000 A	10000A	10000A
8LG0372	80 A	230V~	300 mA	AC-S	800 A	1000 A	10000A	10000A
8LG0373	100 A	230V~	300 mA	AC-S	1000 A	1000 A	10000A	10000A
8LG0374	16 A	230V~	500 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0375	25 A	230V~	500 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0376	40 A	230V~	500 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0377	63 A	230V~	500 mA	AC-S	630 A	1000 A	10000A	10000A
8LG0378	80 A	230V~	500 mA	AC-S	800 A	1000 A	10000A	10000A
8LG0379	100 A	230V~	500 mA	AC-S	1000 A	1000 A	10000A	10000A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 27/07/2026

Signature: Julien GAUTHIER
Certification Officer


ANNEX

References DX ³ Germanic series	In (A)	Un (V~)	IΔn (mA)	Type	Im	IΔm	Inc	IΔc
8LG0452	16 A	127/220V~	30 mA	A	500 A	1000 A	10000A	10000A
8LG0453	25 A	127/220V~	30 mA	A	500 A	1000 A	10000A	10000A
8LG0454	40 A	127/220V~	30 mA	A	500 A	1000 A	10000A	10000A
8LG0455	63 A	127/220V~	30 mA	A	630 A	1000 A	10000A	10000A
8LG0456	80 A	127/220V~	30 mA	A	800 A	1000 A	10000A	10000A
8LG0457	100 A	127/220V~	30 mA	A	1000 A	1000 A	10000A	10000A
8LG0458	16 A	127/220V~	300 mA	A	500 A	1000 A	10000A	10000A
8LG0459	25 A	127/220V~	300 mA	A	500 A	1000 A	10000A	10000A
8LG0460	40 A	127/220V~	300 mA	A	500 A	1000 A	10000A	10000A
8LG0461	63 A	127/220V~	300 mA	A	630 A	1000 A	10000A	10000A
8LG0462	80 A	127/220V~	300 mA	A	800 A	1000 A	10000A	10000A
8LG0463	100 A	127/220V~	300 mA	A	1000 A	1000 A	10000A	10000A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 27/07/2026

Signature: Julien SAUTHIER
Certification Officer


ANNEX


References DX ³ Germanic series	I _n (A)	U _n (V~)	IΔn (mA)	Type	I _m	IΔm	I _{nc}	IΔc
8LG0440	16 A	127/220V~	30 mA	AC	500 A	1000 A	10000A	10000A
8LG0441	25 A	127/220V~	30 mA	AC	500 A	1000 A	10000A	10000A
8LG0442	40 A	127/220V~	30 mA	AC	500 A	1000 A	10000A	10000A
8LG0443	63 A	127/220V~	30 mA	AC	630 A	1000 A	10000A	10000A
8LG0444	80 A	127/220V~	30 mA	AC	800 A	1000 A	10000A	10000A
8LG0445	100 A	127/220V~	30 mA	AC	1000 A	1000 A	10000A	10000A
8LG0446	16 A	127/220V~	300 mA	AC	500 A	1000 A	10000A	10000A
8LG0447	25 A	127/220V~	300 mA	AC	500 A	1000 A	10000A	10000A
8LG0448	40 A	127/220V~	300 mA	AC	500 A	1000 A	10000A	10000A
8LG0449	63 A	127/220V~	300 mA	AC	630 A	1000 A	10000A	10000A
8LG0450	80 A	127/220V~	300 mA	AC	800 A	1000 A	10000A	10000A
8LG0451	100 A	127/220V~	300 mA	AC	1000 A	1000 A	10000A	10000A

References DX ³ Latin series	I _n (A)	U _n (V~)	IΔn (mA)	Type	I _m	IΔm	I _{nc}	IΔc
8LG0502	16 A	230V~	10 mA	A	500 A	1000 A	10000A	10000A
8LG0503	25 A	230V~	10 mA	A	500 A	1000 A	10000A	10000A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 27/07/2026

Signature: Julien Gauthier
Certification Officer


ANNEX

References DX ³ Latin series	In (A)	Un (V~)	IΔn (mA)	Type	Im	IΔm	Inc	IΔc
8LG0504	16 A	230V~	30 mA	A	500 A	1000 A	10000A	10000A
4 342 85	25 A	230V~	30 mA	A	500 A	1000 A	10000A	10000A
4 342 86	40 A	230V~	30 mA	A	500 A	1000 A	10000A	10000A
8LG0505	63 A	230V~	30 mA	A	630 A	1000 A	10000A	10000A
8LG0506	80 A	230V~	30 mA	A	800 A	1000 A	10000A	10000A
8LG0507	100 A	230V~	30 mA	A	1000 A	1000 A	10000A	10000A
8LG0508	16 A	230V~	100 mA	A	500 A	1000 A	10000A	10000A
8LG0509	25 A	230V~	100 mA	A	500 A	1000 A	10000A	10000A
8LG0510	40 A	230V~	100 mA	A	500 A	1000 A	10000A	10000A
8LG0511	63 A	230V~	100 mA	A	630 A	1000 A	10000A	10000A
8LG0512	80 A	230V~	100 mA	A	800 A	1000 A	10000A	10000A
8LG0513	100 A	230V~	100 mA	A	1000 A	1000 A	10000A	10000A
8LG0514	16 A	230V~	300 mA	A	500 A	1000 A	10000A	10000A
8LG0515	25 A	230V~	300 mA	A	500 A	1000 A	10000A	10000A
8LG0516	40 A	230V~	300 mA	A	500 A	1000 A	10000A	10000A
8LG0517	63 A	230V~	300 mA	A	630 A	1000 A	10000A	10000A
8LG0518	80 A	230V~	300 mA	A	800 A	1000 A	10000A	10000A
8LG0519	100 A	230V~	300 mA	A	1000 A	1000 A	10000A	10000A
8LG0520	16 A	230V~	500 mA	A	500 A	1000 A	10000A	10000A
8LG0521	25 A	230V~	500 mA	A	500 A	1000 A	10000A	10000A
8LG0522	40 A	230V~	500 mA	A	500 A	1000 A	10000A	10000A
8LG0523	63 A	230V~	500 mA	A	630 A	1000 A	10000A	10000A
8LG0524	80 A	230V~	500 mA	A	800 A	1000 A	10000A	10000A
8LG0525	100 A	230V~	500 mA	A	1000 A	1000 A	10000A	10000A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 27/07/2026

Signature: **Julien GAUTHIER**
Certification Officer


ANNEX

References DX ³ Latin series	In (A)	Un (V~)	IΔn (mA)	Type	Im	IΔm	Inc	IΔc
8LG0464	16 A	230V~	10 mA	AC	500 A	1000 A	10000A	10000A
8LG0465	25 A	230V~	10 mA	AC	500 A	1000 A	10000A	10000A

References DX ³ Latin series	In (A)	Un (V~)	IΔn (mA)	Type	Im	IΔm	Inc	IΔc
8LG0466	16 A	230V~	30 mA	AC	500 A	1000 A	10000A	10000A
4 342 70 4 342 82	25 A	230V~	30 mA	AC	500 A	1000 A	10000A	10000A
4 342 71 4 342 83	40 A	230V~	30 mA	AC	500 A	1000 A	10000A	10000A
4 342 72	63 A	230V~	30 mA	AC	630 A	1000 A	10000A	10000A
8LG0467	80 A	230V~	30 mA	AC	800 A	1000 A	10000A	10000A
8LG0468	100 A	230V~	30 mA	AC	1000 A	1000 A	10000A	10000A
8LG0469	16 A	230V~	100 mA	AC	500 A	1000 A	10000A	10000A
8LG0470	25 A	230V~	100 mA	AC	500 A	1000 A	10000A	10000A
8LG0471	40 A	230V~	100 mA	AC	500 A	1000 A	10000A	10000A
8LG0472	63 A	230V~	100 mA	AC	630 A	1000 A	10000A	10000A
8LG0473	80 A	230V~	100 mA	AC	800 A	1000 A	10000A	10000A
8LG0474	100 A	230V~	100 mA	AC	1000 A	1000 A	10000A	10000A
8LG0475	16 A	230V~	300 mA	AC	500 A	1000 A	10000A	10000A
4 342 88	25 A	230V~	300 mA	AC	500 A	1000 A	10000A	10000A
4 342 89	40 A	230V~	300 mA	AC	500 A	1000 A	10000A	10000A
4 342 90	63 A	230V~	300 mA	AC	630 A	1000 A	10000A	10000A
8LG0476	80 A	230V~	300 mA	AC	800 A	1000 A	10000A	10000A
8LG0477	100 A	230V~	300 mA	AC	1000 A	1000 A	10000A	10000A
8LG0478	16 A	230V~	500 mA	AC	500 A	1000 A	10000A	10000A
8LG0479	25 A	230V~	500 mA	AC	500 A	1000 A	10000A	10000A
8LG0480	40 A	230V~	500 mA	AC	500 A	1000 A	10000A	10000A
8LG0481	63 A	230V~	500 mA	AC	630 A	1000 A	10000A	10000A
8LG0482	80 A	230V~	500 mA	AC	800 A	1000 A	10000A	10000A
8LG0483	100 A	230V~	500 mA	AC	1000 A	1000 A	10000A	10000A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 27/07/2026

Signature: Julien GAUTHIER
Certification Officer



ANNEX

References DX ³ Latin series	In (A)	Un (V~)	IΔn (mA)	Type	Im	IΔm	Inc	IΔc
8LG0526	16 A	230V~	100 mA	A-S	500 A	1000 A	10000A	10000A
8LG0527	25 A	230V~	100 mA	A-S	500 A	1000 A	10000A	10000A
8LG0528	40 A	230V~	100 mA	A-S	500 A	1000 A	10000A	10000A
8LG0529	63 A	230V~	100 mA	A-S	630 A	1000 A	10000A	10000A
8LG0530	80 A	230V~	100 mA	A-S	800 A	1000 A	10000A	10000A
8LG0531	100 A	230V~	100 mA	A-S	1000 A	1000 A	10000A	10000A
8LG0532	16 A	230V~	300 mA	A-S	500 A	1000 A	10000A	10000A
8LG0533	25 A	230V~	300 mA	A-S	500 A	1000 A	10000A	10000A
8LG0534	40 A	230V~	300 mA	A-S	500 A	1000 A	10000A	10000A
8LG0535	63 A	230V~	300 mA	A-S	630 A	1000 A	10000A	10000A
8LG0536	80 A	230V~	300 mA	A-S	800 A	1000 A	10000A	10000A
8LG0537	100 A	230V~	300 mA	A-S	1000 A	1000 A	10000A	10000A
8LG0538	16 A	230V~	500 mA	A-S	500 A	1000 A	10000A	10000A
8LG0539	25 A	230V~	500 mA	A-S	500 A	1000 A	10000A	10000A
8LG0540	40 A	230V~	500 mA	A-S	500 A	1000 A	10000A	10000A
8LG0541	63 A	230V~	500 mA	A-S	630 A	1000 A	10000A	10000A
8LG0542	80 A	230V~	500 mA	A-S	800 A	1000 A	10000A	10000A
8LG0543	100 A	230V~	500 mA	A-S	1000 A	1000 A	10000A	10000A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 27/07/2026

Signature: **Julien Gauthier**
Certification Officer


ANNEX

References DX ³ Latin series	In (A)	Un (V~)	IΔn (mA)	Type	Im	IΔm	Inc	IΔc
8LG0484	16 A	230V~	100 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0485	25 A	230V~	100 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0486	40 A	230V~	100 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0487	63 A	230V~	100 mA	AC-S	630 A	1000 A	10000A	10000A
8LG0488	80 A	230V~	100 mA	AC-S	800 A	1000 A	10000A	10000A
8LG0489	100 A	230V~	100 mA	AC-S	1000 A	1000 A	10000A	10000A
8LG0490	16 A	230V~	300 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0491	25 A	230V~	300 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0492	40 A	230V~	300 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0493	63 A	230V~	300 mA	AC-S	630 A	1000 A	10000A	10000A
8LG0494	80 A	230V~	300 mA	AC-S	800 A	1000 A	10000A	10000A
8LG0495	100 A	230V~	300 mA	AC-S	1000 A	1000 A	10000A	10000A
8LG0496	16 A	230V~	500 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0497	25 A	230V~	500 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0498	40 A	230V~	500 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0499	63 A	230V~	500 mA	AC-S	630 A	1000 A	10000A	10000A
8LG0500	80 A	230V~	500 mA	AC-S	800 A	1000 A	10000A	10000A
8LG0501	100 A	230V~	500 mA	AC-S	1000 A	1000 A	10000A	10000A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 27/07/2026

Signature: **Julien GAUTHIER**
Certification Officer



ANNEX

References DX ³ Latin series	In (A)	Un (V~)	IΔn (mA)	Type	Im	IΔm	Inc	IΔc
8LG0592	16 A	127/220V~	30 mA	A	500 A	1000 A	10000A	10000A
8LG0593	25 A	127/220V~	30 mA	A	500 A	1000 A	10000A	10000A
8LG0594	40 A	127/220V~	30 mA	A	500 A	1000 A	10000A	10000A
8LG0595	63 A	127/220V~	30 mA	A	630 A	1000 A	10000A	10000A
8LG0596	80 A	127/220V~	30 mA	A	800 A	1000 A	10000A	10000A
8LG0597	100 A	127/220V~	30 mA	A	1000 A	1000 A	10000A	10000A
8LG0598	16 A	127/220V~	300 mA	A	500 A	1000 A	10000A	10000A
8LG0599	25 A	127/220V~	300 mA	A	500 A	1000 A	10000A	10000A
8LG0600	40 A	127/220V~	300 mA	A	500 A	1000 A	10000A	10000A
8LG0601	63 A	127/220V~	300 mA	A	630 A	1000 A	10000A	10000A
8LG0602	80 A	127/220V~	300 mA	A	800 A	1000 A	10000A	10000A
8LG0603	100 A	127/220V~	300 mA	A	1000 A	1000 A	10000A	10000A

References DX ³ Latin series	In (A)	Un (V~)	IΔn (mA)	Type	Im	IΔm	Inc	IΔc
8LG0580	16 A	127/220V~	30 mA	AC	500 A	1000 A	10000A	10000A
8LG0581	25 A	127/220V~	30 mA	AC	500 A	1000 A	10000A	10000A
8LG0582	40 A	127/220V~	30 mA	AC	500 A	1000 A	10000A	10000A
8LG0583	63 A	127/220V~	30 mA	AC	630 A	1000 A	10000A	10000A
8LG0584	80 A	127/220V~	30 mA	AC	800 A	1000 A	10000A	10000A
8LG0585	100 A	127/220V~	30 mA	AC	1000 A	1000 A	10000A	10000A
8LG0586	16 A	127/220V~	300 mA	AC	500 A	1000 A	10000A	10000A
8LG0587	25 A	127/220V~	300 mA	AC	500 A	1000 A	10000A	10000A
8LG0588	40 A	127/220V~	300 mA	AC	500 A	1000 A	10000A	10000A
8LG0589	63 A	127/220V~	300 mA	AC	630 A	1000 A	10000A	10000A
8LG0590	80 A	127/220V~	300 mA	AC	800 A	1000 A	10000A	10000A
8LG0591	100 A	127/220V~	300 mA	AC	1000 A	1000 A	10000A	10000A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 27/07/2026

Signature: Julien GAUTHIER
Certification Officer


ANNEX

References XC10 series	In (A)	Un (V~)	IΔn (mA)	Type	Im	IΔm	Inc	IΔc
LG7768	16 A	230V~	30 mA	A	500 A	1000 A	10000A	10000A
4 332 24	25 A	230V~	30 mA	A	500 A	1000 A	10000A	10000A
4 332 25	40 A	230V~	30 mA	A	500 A	1000 A	10000A	10000A
4 332 26	63 A	230V~	30 mA	A	630 A	1000 A	10000A	10000A
4 332 27	80 A	230V~	30 mA	A	800 A	1000 A	10000A	10000A
LG7769	100 A	230V~	30 mA	A	1000 A	1000 A	10000A	10000A
LG7770	16 A	230V~	300 mA	A	500 A	1000 A	10000A	10000A
4 332 28	25 A	230V~	300 mA	A	500 A	1000 A	10000A	10000A
4 332 29	40 A	230V~	300 mA	A	500 A	1000 A	10000A	10000A
4 332 30	63 A	230V~	300 mA	A	630 A	1000 A	10000A	10000A
4 332 31	80 A	230V~	300 mA	A	800 A	1000 A	1000A	1000A
LG7771	100 A	230V~	300 mA	A	1000 A	1000 A	1000A	1000A

References XC10 series	In (A)	Un (V~)	IΔn (mA)	Type	Im	IΔm	Inc	IΔc
LG7772	16 A	230V~	30 mA	AC	500 A	1000 A	10000A	10000A
4 331 82	25 A	230V~	30 mA	AC	500 A	1000 A	10000A	10000A
4 331 83	40 A	230V~	30 mA	AC	500 A	1000 A	10000A	10000A
4 331 84	63 A	230V~	30 mA	AC	630 A	1000 A	10000A	10000A
4 331 85	80 A	230V~	30 mA	AC	800 A	1000 A	10000A	10000A
LG7773	100 A	230V~	30 mA	AC	1000 A	1000 A	10000A	10000A
LG7774	16 A	230V~	300 mA	AC	500 A	1000 A	10000A	10000A
4 331 86	25 A	230V~	300 mA	AC	500 A	1000 A	10000A	10000A
4 331 87	40 A	230V~	300 mA	AC	500 A	1000 A	10000A	10000A
4 331 88	63 A	230V~	300 mA	AC	630 A	1000 A	10000A	10000A
4 331 89	80 A	230V~	300 mA	AC	800 A	1000 A	10000A	10000A
LG7775	100 A	230V~	300 mA	AC	1000 A	1000 A	1000A	1000A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 27/07/2026

Signature: **Julien GAUTHIER**
Certification Officer


ANNEX

References RX series	In (A)	Un (V~)	IΔn (mA)	Type	Im	IΔm	Inc	IΔc
8LG0638	16 A	230V~	10 mA	A	500 A	1000 A	10000A	10000A
8LG0639	25 A	230V~	10 mA	A	500 A	1000 A	10000A	10000A
8LG0640	16 A	230V~	30 mA	A	500 A	1000 A	10000A	10000A
4 320 36	25 A	230V~	30 mA	A	500 A	1000 A	10000A	10000A
4 325 35 4 320 37	40 A	230V~	30 mA	A	500 A	1000 A	10000A	10000A
4 325 36 4 320 38	63 A	230V~	30 mA	A	630 A	1000 A	10000A	10000A
8LG0641	80 A	230V~	30 mA	A	800 A	1000 A	10000A	10000A
8LG0642	100 A	230V~	30 mA	A	1000 A	1000 A	10000A	10000A
8LG0643	16 A	230V~	100 mA	A	500 A	1000 A	10000A	10000A
8LG0644	25 A	230V~	100 mA	A	500 A	1000 A	10000A	10000A
8LG0645	40 A	230V~	100 mA	A	500 A	1000 A	10000A	10000A
8LG0646	63 A	230V~	100 mA	A	630 A	1000 A	10000A	10000A
8LG0647	80 A	230V~	100 mA	A	800 A	1000 A	10000A	10000A
8LG0648	100 A	230V~	100 mA	A	1000 A	1000 A	10000A	10000A
8LG0649	16 A	230V~	300 mA	A	500 A	1000 A	10000A	10000A
8LG0650	25 A	230V~	300 mA	A	500 A	1000 A	10000A	10000A
8LG0806 4 325 37	40 A	230V~	300 mA	A	500 A	1000 A	10000A	10000A
8LG0807 4 325 38	63 A	230V~	300 mA	A	630 A	1000 A	10000A	10000A
8LG0651	80 A	230V~	300 mA	A	800 A	1000 A	10000A	10000A
8LG0652	100 A	230V~	300 mA	A	1000 A	1000 A	10000A	10000A
8LG0653	16 A	230V~	500 mA	A	500 A	1000 A	10000A	10000A
8LG0654	25 A	230V~	500 mA	A	500 A	1000 A	10000A	10000A
8LG0655	40 A	230V~	500 mA	A	500 A	1000 A	10000A	10000A
8LG0656	63 A	230V~	500 mA	A	630 A	1000 A	10000A	10000A
8LG0657	80 A	230V~	500 mA	A	800 A	1000 A	10000A	10000A
8LG0658	100 A	230V~	500 mA	A	1000 A	1000 A	10000A	10000A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 27/07/2026

Signature: Julien GAUTHIER
Certification Officer


ANNEX

References RX series	In (A)	Un (V~)	IΔn (mA)	Type	Im	IΔm	Inc	IΔc
8LG0604	16 A	230V~	10 mA	AC	500 A	1000 A	10000A	10000A
8LG0605	25 A	230V~	10 mA	AC	500 A	1000 A	10000A	10000A
8LG0606	16 A	230V~	30 mA	AC	500 A	1000 A	10000A	10000A
4 320 24	25 A	230V~	30 mA	AC	500 A	1000 A	10000A	10000A
4 320 25	40 A	230V~	30 mA	AC	500 A	1000 A	10000A	10000A
4 320 26	63 A	230V~	30 mA	AC	630 A	1000 A	10000A	10000A
4 320 27	80 A	230V~	30 mA	AC	800 A	1000 A	10000A	10000A
8LG0607	100 A	230V~	30 mA	AC	1000 A	1000 A	10000A	10000A
8LG0608	16 A	230V~	100 mA	AC	500 A	1000 A	10000A	10000A
4 320 28	25 A	230V~	100 mA	AC	500 A	1000 A	10000A	10000A
4 320 29	40 A	230V~	100 mA	AC	500 A	1000 A	10000A	10000A
4 320 30	63 A	230V~	100 mA	AC	630 A	1000 A	10000A	10000A
8LG0609	80 A	230V~	100 mA	AC	800 A	1000 A	10000A	10000A
8LG0610	100 A	230V~	100 mA	AC	1000 A	1000 A	10000A	10000A
8LG0611	16 A	230V~	300 mA	AC	500 A	1000 A	10000A	10000A
4 320 32	25 A	230V~	300 mA	AC	500 A	1000 A	10000A	10000A
4 320 33	40 A	230V~	300 mA	AC	500 A	1000 A	10000A	10000A
4 320 34	63 A	230V~	300 mA	AC	630 A	1000 A	10000A	10000A
8LG0612	80 A	230V~	300 mA	AC	800 A	1000 A	10000A	10000A
8LG0613	100 A	230V~	300 mA	AC	1000 A	1000 A	10000A	10000A
8LG0614	16 A	230V~	500 mA	AC	500 A	1000 A	10000A	10000A
8LG0615	25 A	230V~	500 mA	AC	500 A	1000 A	10000A	10000A
8LG0616	40 A	230V~	500 mA	AC	500 A	1000 A	10000A	10000A
8LG0617	63 A	230V~	500 mA	AC	630 A	1000 A	10000A	10000A
8LG0618	80 A	230V~	500 mA	AC	800 A	1000 A	10000A	10000A
8LG0619	100 A	230V~	500 mA	AC	1000 A	1000 A	10000A	10000A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 27/07/2026

Signature: Julien GAUTHIER
Certification Officer


ANNEX

References RX series	In (A)	Un (V~)	IΔn (mA)	Type	Im	IΔm	Inc	IΔc
8LG0805	16 A	230V~	30 mA	A	500 A	1000 A	6000 A	6000 A
4 320 59	25 A	230V~	30 mA	A	500 A	1000 A	6000 A	6000 A
4 320 60	40 A	230V~	30 mA	A	500 A	1000 A	6000 A	6000 A
8LG0714	63 A	230V~	30 mA	A	630 A	1000 A	6000 A	6000 A
8LG0715	80 A	230V~	30 mA	A	800 A	1000 A	6000 A	6000 A
8LG0716	100 A	230V~	30 mA	A	1000 A	1000 A	6000 A	6000 A
8LG0801	16 A	230V~	30 mA	AC	500 A	1000 A	6000 A	6000 A
4 320 56	25 A	230V~	30 mA	AC	500 A	1000 A	6000 A	6000 A
4 320 57	40 A	230V~	30 mA	AC	500 A	1000 A	6000 A	6000 A
8LG0802	63 A	230V~	30 mA	AC	630 A	1000 A	6000 A	6000 A
8LG0803	80 A	230V~	30 mA	AC	800 A	1000 A	6000 A	6000 A
8LG0804	100 A	230V~	30 mA	AC	1000 A	1000 A	6000 A	6000 A

References RX series	In (A)	Un (V~)	IΔn (mA)	Type	Im	IΔm	Inc	IΔc
8LG0659	16 A	230V~	100 mA	A-S	500 A	1000 A	10000A	10000A
8LG0660	25 A	230V~	100 mA	A-S	500 A	1000 A	10000A	10000A
8LG0661	40 A	230V~	100 mA	A-S	500 A	1000 A	10000A	10000A
8LG0662	63 A	230V~	100 mA	A-S	630 A	1000 A	10000A	10000A
8LG0663	80 A	230V~	100 mA	A-S	800 A	1000 A	10000A	10000A
8LG0664	100 A	230V~	100 mA	A-S	1000 A	1000 A	10000A	10000A
8LG0665	16 A	230V~	300 mA	A-S	500 A	1000 A	10000A	10000A
8LG0666	25 A	230V~	300 mA	A-S	500 A	1000 A	10000A	10000A
8LG0667	40 A	230V~	300 mA	A-S	500 A	1000 A	10000A	10000A
8LG0668	63 A	230V~	300 mA	A-S	630 A	1000 A	10000A	10000A
8LG0669	80 A	230V~	300 mA	A-S	800 A	1000 A	10000A	10000A
8LG0670	100 A	230V~	300 mA	A-S	1000 A	1000 A	10000A	10000A
8LG0671	16 A	230V~	500 mA	A-S	500 A	1000 A	10000A	10000A
8LG0672	25 A	230V~	500 mA	A-S	500 A	1000 A	10000A	10000A
8LG0673	40 A	230V~	500 mA	A-S	500 A	1000 A	10000A	10000A
8LG0674	63 A	230V~	500 mA	A-S	630 A	1000 A	10000A	10000A
8LG0675	80 A	230V~	500 mA	A-S	800 A	1000 A	10000A	10000A
8LG0676	100 A	230V~	500 mA	A-S	1000 A	1000 A	10000A	10000A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 27/07/2026

Signature: **Julien GAUTHIER**
Certification Officer


ANNEX


References RX series	In (A)	Un (V~)	IΔn (mA)	Type	Im	IΔm	Inc	IΔc
8LG0620	16 A	230V~	100 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0621	25 A	230V~	100 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0622	40 A	230V~	100 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0623	63 A	230V~	100 mA	AC-S	630 A	1000 A	10000A	10000A
8LG0624	80 A	230V~	100 mA	AC-S	800 A	1000 A	10000A	10000A
8LG0625	100 A	230V~	100 mA	AC-S	1000 A	1000 A	10000A	10000A
8LG0626	16 A	230V~	300 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0627	25 A	230V~	300 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0628	40 A	230V~	300 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0629	63 A	230V~	300 mA	AC-S	630 A	1000 A	10000A	10000A
8LG0630	80 A	230V~	300 mA	AC-S	800 A	1000 A	10000A	10000A
8LG0631	100 A	230V~	300 mA	AC-S	1000 A	1000 A	10000A	10000A
8LG0632	16 A	230V~	500 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0633	25 A	230V~	500 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0634	40 A	230V~	500 mA	AC-S	500 A	1000 A	10000A	10000A
8LG0635	63 A	230V~	500 mA	AC-S	630 A	1000 A	10000A	10000A
8LG0636	80 A	230V~	500 mA	AC-S	800 A	1000 A	10000A	10000A
8LG0637	100 A	230V~	500 mA	AC-S	1000 A	1000 A	10000A	10000A

References RX series	In (A)	Un (V~)	IΔn (mA)	Type	Im	IΔm	Inc	IΔc
8LG0725	16 A	127/220V~	30 mA	A	500 A	1000 A	10000A	10000A
8LG0726	25 A	127/220V~	30 mA	A	500 A	1000 A	10000A	10000A
8LG0727	40 A	127/220V~	30 mA	A	500 A	1000 A	10000A	10000A
8LG0728	63 A	127/220V~	30 mA	A	630 A	1000 A	10000A	10000A
8LG0729	80 A	127/220V~	30 mA	A	800 A	1000 A	10000A	10000A
8LG0730	100 A	127/220V~	30 mA	A	1000 A	1000 A	10000A	10000A
8LG0731	16 A	127/220V~	300 mA	A	500 A	1000 A	10000A	10000A
8LG0732	25 A	127/220V~	300 mA	A	500 A	1000 A	10000A	10000A
8LG0733	40 A	127/220V~	300 mA	A	500 A	1000 A	10000A	10000A
8LG0734	63 A	127/220V~	300 mA	A	630 A	1000 A	10000A	10000A
8LG0735	80 A	127/220V~	300 mA	A	800 A	1000 A	10000A	10000A
8LG0736	100 A	127/220V~	300 mA	A	1000 A	1000 A	10000A	10000A



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 27/07/2026

Signature: Julien GARNIER
Certification officer


ANNEX

References RX series	In (A)	Un (V~)	IΔn (mA)	Type	Im	IΔm	Inc	IΔc
8LG0713	16 A	127/220V~	30 mA	AC	500 A	1000 A	10000A	10000A
4 320 86	25 A	127/220V~	30 mA	AC	500 A	1000 A	10000A	10000A
4 320 87	40 A	127/220V~	30 mA	AC	500 A	1000 A	10000A	10000A
4 320 88	63 A	127/220V~	30 mA	AC	630 A	1000 A	10000A	10000A
8LG0717	80 A	127/220V~	30 mA	AC	800 A	1000 A	10000A	10000A
8LG0718	100 A	127/220V~	30 mA	AC	1000 A	1000 A	10000A	10000A
8LG0719	16 A	127/220V~	300 mA	AC	500 A	1000 A	10000A	10000A
8LG0720	25 A	127/220V~	300 mA	AC	500 A	1000 A	10000A	10000A
8LG0721	40 A	127/220V~	300 mA	AC	500 A	1000 A	10000A	10000A
8LG0722	63 A	127/220V~	300 mA	AC	630 A	1000 A	10000A	10000A
8LG0723	80 A	127/220V~	300 mA	AC	800 A	1000 A	10000A	10000A
8LG0724	100 A	127/220V~	300 mA	AC	1000 A	1000 A	10000A	10000A

Characteristics	Values
Independent of line voltage	yes
Rated voltage	230 V~ and 127/220V~
Rated frequency	50 Hz
Rated current	16A, 25A, 40A, 63A, 80A, 100A
Rated residual operating current	0.010, 0.030, 0.100, 0.300, 0.500 A
Type	AC – AC-S – A – A-S
Delay time	without, with (type S)
Nature of supply	~
Number of poles	2
Rated insulation voltage	250 V
Rated impulse withstand voltage, Uimp (V)	4 000V
Utilisation range temperature (°C)	-25 °C à/to +40 °C
Breaking and making capacity	500 A, 630 A, 800 A, 1000 A
Rated residual making and breaking capacity	1 000 A
Rated residual operating current	10 000 A, 6000 A (Range Vivienda)
Rated conditional residual short-circuit current	10 000 A, 6000 A (Range Vivienda)
Grid distance (short-circuit tests)	35 mm
IP degree	IP20
Material group	II
Method of installation	panel board, distribution board, on rail
Type of terminals	pillar terminal
Nominal diameter of thread	5 mm



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 27/07/2026

Signature: Julien Gauthier

