



Ref. Certif. No.

AT 5098

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Surge protective device

Name and address of the applicant

Legrand France
128 Avenue du Maréchal de Lattre de Tassigny,
87045 Limoges Cedex, France

Name and address of the manufacturer

Legrand France
128 Avenue du Maréchal de Lattre de Tassigny,
87045 Limoges Cedex, France

Name and address of the factory

Legrand Polska Sp.z.o.o.
ul. Warynskiego 20,
57-200 Zabkowice Slaskie, Poland

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

L-N: $U_c = AC 320 V$; $I_n = 25 kA$; $I_{imp} = 12,5 kA$; $I_{max} = 60 kA$;
 $U_p \leq 1,5 kV$ (Class I); $U_p \leq 1,9 kV$ (Class II).
N-PE: $U_c = AC 255 V$; $I_n = 50 kA$; $I_{imp} = 50 kA$; $I_{max} = 60 kA$;
 $U_p \leq 1,5 kV$

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

--

Model / Type Ref.

4 122 70, 4 122 71, 4 122 72, 4 122 73, 4 122 74, 4 122 75, 4 122 76,
4 122 77, plug-in unit: 4 123 03

Additional information (if necessary may also be reported on page 2)

See test report for information about National and/or Group Differences.

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 61643-11:2011

As shown in the Test Report Ref. No. which forms part of this Certificate

CTI-CB 1149-1, CTI-CB 1149-2, CTI-CB 1149-3

This CB Test Certificate is issued by the National Certification Body



Österreichischer Verband für Elektrotechnik

OVE Certification

Kahlenberger Str. 2A, 1190 Wien, Austria

T. Neumayer
Digitally signed by T. Neumayer
Email=t.neumayer@ove.at



Date: 2024-05-08

Signature: Dipl.-Ing. T. Neumayer