Ref. Certif. No.

FR_722772

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	**Multiple cord extension set**
Name and address of the applicant	**LEGRAND FRANCE** 128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY 87045 LIMOGES CEDEX - FRANCE
Name and address of the manufacturer	**LEGRAND FRANCE** 128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY 87045 LIMOGES CEDEX - FRANCE
Name and address of the factory	**NINGBO BANMEN ELECTRIC APPLIANCE CO., LTD.** East Industrial Zone, Guanhaiwei Cixi City, 315314, Zhejiang Province - CHINA
Note: *When more than one factory, please report on page 2*	☐ Additional Information on page 2
Ratings and principal characteristics	See Annex
Trademark / Brand (if any)	legrand
Customer's Testing Facility (CTF) Stage used	/
Model / Type Ref.	See Annex
Additional information (if necessary may also be reported on page 2)	☐ Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60884-1:2022
As shown in the Test Report Ref. No. which forms part of this Certificate	ABND-ESH-P25032093

This CB Test Certificate is issued by the National Certification Body

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 10/10/2025

Signature: Julien GAUTHIER
Certification Officer

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES
S.A. au capital de 15 245 984 €
RCS Nanterre B 408 363 744
33, avenue du Général Leclerc
F - 92260 FONTENAY AUX ROSES

ANNEX

References, ratings and main characteristics:

Model	Reference	Number of socket-outlets	With SPD	Color of enclosure
RNP11U	6 944 28	3	Y	WHITE/BLACK
	6 944 29	5	Y	WHITE/BLACK
	6 944 30	3	Y	BLACK
	6 944 31	5	Y	BLACK
	6 944 40	3	N	WHITE/BLACK
	6 944 41	5	N	WHITE/BLACK
	6 944 42	3	N	BLACK
	6 944 43	5	N	BLACK
N = Not include this function; Y = include this function.				

CLASSIFICATION

standard Sheet:	Standard sheet III of CEE 7 (socket-outlet) / Standard sheet VII of CEE 7 (Plug)
rated current (A) rated load (W) rated voltage (V) household voltage (V)	16A 3680W 250V 230V
degree of protection	IP20
provision for earthing	with earthing contact
method of connecting the cable	Non-rewirable
type of terminals	-
type of connections	Soldered / welded / other (riveted)
colour	See above
socket-outlets	
multiple socket-outlets number of socket-outlets	16A : 3, 5
degree of protection against electric shock	normal protection
existence of shutters	with shutters
method of application - mounting	portable type
method of installation	-
plugs:	
class of equipment	I
entry of cable	lateral

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 10/10/2025

Signature: Julien GAUTHIER
Certification Officer

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
33 avenue du Général Leclerc
92260 FONTENAY AUX ROSES

ANNEX

Type of components	Manufacturer	Certification
Plug	Legrand France	VDE 40018331 CB FR FR_719911
Cable	Legrand France	VDE 40017697
Switch	Cixi City Minghe Xinghua	SE-S-2200608
Alt.	Shenzhen Baokezhen Electronics Co., Ltd.	SE-S-2100460
SPD (surge protection)	Legrand France	LCIE test report No. ABND-ESH-P20071436
USB charger	Legrand France	Intertek test report No. 250506041SZN-001

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE
33 avenue du Général Leclerc
92260 Fontenay-aux-Roses, FRANCE
www.lcie.fr

Date: 10/10/2025

Signature: Julien GAUTHIER
Certification Officer

LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSES