

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Fixed switched socket-outlet

Name and address of the applicant

TCL Legrand International electrical (Huizhou) Co Ltd
Bldg.B1-B3, East No.39 Hechang 6th Rd., HZZK Hi-tech
Industrial Development Zone
Huizhou, Guangdong - CHINA

Name and address of the manufacturer

LEGRAND FRANCE
128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY
87045 LIMOGES CEDEX- FRANCE

Name and address of the factory

TCL Legrand International electrical (Huizhou) Co Ltd
Bldg.B1-B3, East No.39 Hechang 6th Rd., HZZK Hi-tech
Industrial Development Zone
Huizhou, Guangdong - CHINA

Note: When more than one factory, please report on page 2

 Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

See Annex

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR_708240 dated 31/03/2020. Addition of product references

 Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60884-1:2002(ed.3) +A1:2006 +A2:2013
IEC 60884-2-3:2006

As shown in the Test Report Ref. No. which forms part of this Certificate

ARLI-ESH-P20061151

This CB Test Certificate is issued by the National Certification Body

LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 10/07/2020

LABORATOIRE CENTRAL DES
INDUSTRIES ELECTRIQUES
S.A.S au capital de 15.745.984 €
RCS Nanterre B 408 363 174
33 avenue du Général Leclerc
F - 92266 FONTENAY AUX ROSESSignature: Julien GAUTHIER
Certification Officer

ANNEX

References, ratings and main characteristics:

Reference	Group*	Product description	Color of enclosure
282441	G15	1G BS 13A SWITCHED SOCKET WITH 1 USB TYPE A CHARGER	WHITE
282441-C	G15	1G BS 13A SWITCHED SOCKET WITH 1 USB TYPE A CHARGER	MATT BLACK
282441-C1	G15	1G BS 13A SWITCHED SOCKET WITH 1 USB TYPE A CHARGER	ROSE GOLD
282441-C2	G15	1G BS 13A SWITCHED SOCKET WITH 1 USB TYPE A CHARGER	CHAMPAGNE
282441-C3	G15	1G BS 13A SWITCHED SOCKET WITH 1 USB TYPE A CHARGER	DARK SILVER
617058	G15	1G BS 13A SWITCHED SOCKET WITH 1 USB TYPE A CHARGER	WHITE
617358	G15	1G BS 13A SWITCHED SOCKET WITH 1 USB TYPE A CHARGER	GREY
617458	G15	1G BS 13A SWITCHED SOCKET WITH 1 USB TYPE A CHARGER	BROWN
617658	G15	1G BS 13A SWITCHED SOCKET WITH 1 USB TYPE A CHARGER	WHITE
617758	G15	1G BS 13A SWITCHED SOCKET WITH 1 USB TYPE A CHARGER	ANTHRACITE
617858	G15	1G BS 13A SWITCHED SOCKET WITH 1 USB TYPE A CHARGER	IVORY
K8/15/13/U-HK	G15	1G BS 13A SWITCHED SOCKET WITH 1 USB TYPE A CHARGER	WHITE
K8/15/13/U-C-HK	G15	1G BS 13A SWITCHED SOCKET WITH 1 USB TYPE A CHARGER	MATT BLACK
K8/15/13/U-C1-HK	G15	1G BS 13A SWITCHED SOCKET WITH 1 USB TYPE A CHARGER	ROSE GOLD
K8/15/13/U-C2-HK	G15	1G BS 13A SWITCHED SOCKET WITH 1 USB TYPE A CHARGER	CHAMPAGNE
K8/15/13/U-C3-HK	G15	1G BS 13A SWITCHED SOCKET WITH 1 USB TYPE A CHARGER	DARK SILVER
K8/15/13/U-C4-HK	G15	1G BS 13A SWITCHED SOCKET WITH 1 USB TYPE A CHARGER	PINK
570080	G15	1G BS 13A SWITCHED SOCKET WITH 1 USB TYPE A CHARGER The reference for cover plate equipped: 575134	SOFT ALU
571080	G15	1G BS 13A SWITCHED SOCKET WITH 1 USB TYPE A CHARGER The reference for cover plate equipped: 575136	CHAMPAGNE

* The "group" denotes applicant's categorization.



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 10/07/2020

Signature: Julien GAUTHIER
Certification Officer

CLASSIFICATION

standard Sheet:	standard sheet of BS 1363-2
rated current (A)	13 A
rated voltage (V)	250 V~
degree of protection	IP20
provision for earthing	with earthing contact
method of connecting the cable	rewirable
type of terminals	screw-type
colour	white, matt black, rose gold, champagne, dark silver, grey, brown, anthracite, ivory, pink, soft alu
socket-outlets	
multiple socket-outlets number of socket-outlets	13A : 1
degree of protection against electric shock	normal protection
existence of shutters	with shutters
method of application - mounting	flush-type
method of installation	design A
Intended for circuits where	a single earthing circuit provides protective earthing
Switched socket-outlets without interlock	
According to the method of actuating the switch	rocker
According to the switching of the neutral	unswitched neutral

type of components	manufacturer	Conformity
USB charger	TCL-Legrand International Electrical(Huizhou) Co., Ltd	LCIE test report No. ARLI-19SE0497VTSHR-R1



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 10/07/2020

Signature: Julien GAUTHIER
Certification Officer