

Ref. Certif. No.
SE-84291A1/M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME


CB TEST CERTIFICATE

Product	Switch for fixed installation
Name and address of the applicant	Legrand (Beijing) Electrical Co., Ltd No. 4 Chaoqian Road, Changping Kejiyuanqu, Beijing, CHINA
Name and address of the manufacturer	Same as applicant
Name and address of the factory <i>Note: When more than one factory, please report on page 2</i>	Same as applicant
Ratings and principal characteristics	250V~, 10AX
Trademark (if any)	legrand
Customer's Testing Facility (CTF) Stage used	-
Model / Type Ref.	281008, 281009, 282008, 283008, 283009, 283208, 283209, 283408, 283409, 283808
Additional information (if necessary may also be reported on page 2)	This certificate replaces CB certificate SE-84291M1, dated 25 January 2017. A new certificate has been issued due to adding the ILAC mark in the test report.
A sample of the product was tested and found to be in conformity with	IEC 60669-1:1998 and A1 + A2
As shown in the Test Report Ref. No. which forms part of this Certificate	160702525SHA-001, 160702525SHA-001 M1, 160702525SHA-001 A1

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00

Date: 22 August 2017



Signature:
Gary Hu