

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME


CB TEST CERTIFICATE

Product	SELF-CONTAINED LUMINAIRES FOR EMERGENCY LIGHTING
Name and address of the applicant	LEGRAND FRANCE 128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY 87045 LIMOGES CEDEX - FRANCE
Name and address of the manufacturer	LEGRAND FRANCE 128 AVENUE DU MARECHAL DE LATTRE DE TASSIGNY 87045 LIMOGES CEDEX - FRANCE
Name and address of the factory	LEGRAND FRANCE 1 RUE HENRI FREYSSINET 17140 LAGORD - FRANCE
Note: When more than one factory, please report on page 2	<input type="checkbox"/> Additional Information on page 2
Ratings and principal characteristics	6 621 15, 6 621 20, 6 621 40 : NM 6 621 22, 6 621 42 : C See Annex
Trademark (if any)	LEGRAND
Customer's Testing Facility (CTF) Stage used	/
Model / Type Ref.	Range U33 6 621 15, 6 621 20, 6 621 22, 6 621 40, 6 621 42
Additional information (if necessary may also be reported on page 2)	<input checked="" type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60598-1:2014 IEC 60598-2-22:2014 (ed.4)
As shown in the Test Report Ref. No. which forms part of this Certificate	149413-705933 A

This CB Test Certificate is issued by the National Certification Body

LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 01/12/2017

Signature: **Rémi HANOI**
Certification Officer

ANNEX

Caractéristiques / Characteristics :

Caractéristiques / Characteristics	Valeur / Value
Tension assignée / Rated voltage	230V~
Nature du courant / Nature of supply	AC
Fréquence assignée / Rated frequency	50/60 Hz
Puissance assignée / Rated power	/
Classe de protection contre les chocs électriques / Class of protection from electric shock	II
Degré IP / IP degree	42
Degré IK / IK degree	07
Flux assigné / Rated lumen output	6 621 15 : 250 lm à 1h 6 621 20 : 250 lm à 1h 6 621 22 : 250/120 lm à 1h 6 621 40 : 350 lm à 1h 6 621 42 : 250/120 lm à 1h
Nature accumulateur (Type, Nombre, Tension, Capacité) / Battery type	6 621 15, 6 621 20, 6 621 22 : Ni-Cd [(4 x 1,2 / 1,5 Ah) + (2 x 1,2 / 1,5 Ah)] BYD SC1500mAh Ni-Cd [(4 x 1,2 / 1,6 Ah) + (2 x 1,2 / 1,6 Ah)] ARTS ENERGY VNT Cs U 6 621 40, 6 621 42 : Ni-Cd [2 x (4 x 1,2 V) / 1,5Ah] BYD SC1500mAh Ni-Cd [2 x (4 x 1,2 V) / 1,6Ah] ARTS ENERGY VNT Cs U
Lampe de secours (nature, nombre) / Emergency lamp (type, number)	6 621 15 : 1 tube x 8 W 6 621 20 : 1 tube x 8 W 6 621 22 : 2 tubes x 8 W 6 621 40 : 1 tube x 8 W 6 621 42 : 2 tubes x 8 W



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 01/12/2017

Signature: Rémi HANOT
Certification Officer

