



Ref. Certif. No.

SE-111974

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Three and four poles Switch Disconnecter

Name and address of the applicant

LEGRAND FRANCE
128, Avenue du Maréchal de Lattre de Tassigny
87045 Limoges Cedex
FRANCE

Name and address of the manufacturer

Novateur Electrical & Digital Systems Private Limited
A-2 MIDC Industiral Area, Malegaon Village, Sinnar, Nashik
422113 Maharashtra
INDIA

Name and address of the factory

Same as manufacturer

Note: When more than one factory, please report on page 2

☐ Additional Information on page 2

Ratings and principal characteristics

$U_e=250$ Vdc and 690Vac (50.0-60.0Hz) – $I_e=25A, 32A, 40A, 50A, 63A$ $I_{cw}=1,5kA$ (1.00s) $I_{cm}=2.10kA$,
Pattern No. 3 and 4

Trademark / Brand (if any)

Legrand

Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

DSX63

Additional information (if necessary may also be reported on page 2)

☒ Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-3:2020

As shown in the Test Report Ref. No. which forms part of this Certificate

2026738STO-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden

Date: 04 September, 2023

intertek

Signature:

Fredrik Wennersten

Additional information

Characteristics:

Voltage ratings $U_e=250\text{VDC}$, 690VAC (50-60Hz)Rated current $I_e=25\text{A}$, 32A , 40A , 50A , 63A $U_{imp} = 8\text{kV}$ $U_i = 690\text{V}$

Utilization category	U_e (V)	I_e (A)	I_{cm} (kA)	I_{cw} (1s) (kA)
AC-23A/B	415	63	2,1	1,5
AC-23A/B	500	25	2,1	1,5
AC-22A/B	500	63	2,1	1,5
AC-21A/B	690	63	2,1	1,5
AC-22A/B	690	40	2,1	1,5
DC-21A/B	250	50	2,1	1,5
DC-22A/B	250	40	2,1	1,5
DC-23A/B	250	25	2,1	1,5

Date: 04 September, 2023

Signature:

