

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

"CELIANE" socket-outlets with side-earthing contacts

Name and address of the applicant

LEGRAND France  
128 Avenue du Maréchal de Lattre de Tassigny 87045 Limoges  
Cedex  
France

Name and address of the manufacturer

LEGRAND France  
128 Avenue du Maréchal de Lattre de Tassigny 87045 Limoges  
Cedex  
France

Name and address of the factory

Note: When more than one factory, please report on page 2

See additional page(s) for the listing of 2 factories

Ratings and principal characteristics

250 V~; 16 A  
Function: 2P+E, PRO  
CM0120, CB0122, CT0122, CN0122: Screwless type (rigid/flex)  
CM0121, CM0123: Screw type (rigid/flex)

Trademark / Brand (if any)

LEGRAND

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

CM0120, CB0122, CT0122, CN0122, CM0121 and  
CM0123 (Tamper proof)  
CM0120, CM0121: mechanism only.  
CM0122, CT0122, CN0122: without frame and cover plate.  
CM0123: tamperproof, without frame and cover plate.Additional information (if necessary may also be  
reported on page 2)

For further details and accessories see CB Test Report.

A sample of the product was tested and found  
to be in conformity with

IEC 60884-1:2022

As shown in the Test Report Ref. No. which  
forms part of this Certificate

HU24SUKO 001

This CB Test Certificate is issued by the National Certification Body

TÜV Rheinland InterCert Kft., MEEI Division  
H-1143 Budapest, Gizella út 51-57., Hungary  
Web: www.tuv.com

Date: 2025-02-06

Signature:



Tötös Tamás László

**Factories :**

1. LEGRAND France  
128 Avenue du Maréchal de Lattre de Tassigny 87045 Limoges Cedex  
France
2. LEGRAND Magyarország Villamossági Rendszerek ZRt.  
Ipartelepi út 14. 6600 Szentes  
Hungary