

CB TEST CERTIFICATE

Ref. Certificate No.

IT-8320-M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by: IMQ SpA


Product: Circuit breakers for overcurrent protection for household installations

Applicant: BTICINO SPA VIA MESSINA 38 Italy
20154 MILANO

Manufacturer: BTICINO SPA VIALE BORRI 231 Italy
21100 VARESE

Factory: B.B.T. SARL ZONE INDUSTRIELLE Tunisia
1111 JEBEL OUST
ZAGHOUAN

Rating and principal characteristics: 230V - 50/60Hz - type C - 50/60Hz - 1P+N
(see additional sheet)

Trade mark (if any): 

Model/Type reference: Series Mosaic 45; Mosaic (see additional sheet)

Additional information: This CBTC is a Modification of CBTC IT-8320 of 2009-05-06 and they must be read in conjunction. Modification introduced: extension to new models described in the additional sheet.

Sample of product tested to be in conformity with IEC: 60898-1(ed.1);am1;am2

Test Report Ref. No: 03LK00001/00 - 03LK00001/01 - 03LK00001/02 - 03LK00001/03

This CB Test Certificate is issued by the National Certification Body:

IMQ SpA
Via Quintiliano 43 I-20138 Milano, Italy

Signed by: Mauro Casari

Date of issue: 2010-03-18



Annex to CBTC No. IT-8320-M1

Description of the range of the circuit breakers for overcurrent protection for household installation

| In | Icn | Poles | Series | Type reference | Colour of the frontal surface |
|-----|-------|-------|-----------|----------------|-------------------------------|
| 6A | 1500A | 1P+N | Mosaic 45 | 74451 | White |
| 10A | 3000A | 1P+N | Mosaic 45 | 74452 | White |
| 16A | 3000A | 1P+N | Mosaic 45 | 74453 | White |
| 10A | 3000A | 1P+N | Mosaic | 77521 | Grey-White |
| 16A | 3000A | 1P+N | Mosaic | 77522 | Grey-White |

